

FLORIDA BUILDING COMMISSION'S

Fire Technical Advisory Committee

**December 7, 2004
8:00 A.M. - 10:00 A.M.
Rosen Centre Hotel
9840 International Drive
Orlando, Florida 32819
888-782-9722**

Meeting Report

1. Member present: Nick D'Andrea, Joe Belcher, Hamid Bahadori, Jeff Gross
John Calpini, Dale Greiner, Jim Schock.
2. Discussed and provided recommendation on the following request for Declaratory
Statements as follows:
DCA04-DEC-230 by Patricia Weeks of Blair Home Construction

Question: Is it the intent of the Florida Building Code to require smoke detectors
inside the sleeping areas as well as outside the sleeping areas ?

Answer: Yes, chapter 553.88 F.S. adopts NFPA-72 as the minimum alarm standard
for the state, and NFPA -72 requires smoke detectors be installed in sleeping rooms as
well as other locations as per Section 905.2.2 of the FBC.

3. Adjourned at 8:30 A.M.

Note: This document is available to any person requiring materials in alternate format
upon request. Contact the Department of Community Affairs, 2555 Shumard Oak
Boulevard, Tallahassee, Florida 32399-2100 or call 850-487-1824.