

Response to DCA04-DEC-123

See DCA04-DEC-070: separate approval of custom fabricated buildings is not required for Rule 9B-72. Steel deck diaphragms, siding, sheathing, windows, doors and other structural components are subject to Rule 9B-72.