

DEPARTMENT OF COMMUNITY AFFAIRS

FLORIDA BUILDING COMMISSION

NOTICE IS HEREBY GIVEN that the Florida Building Commission has issued a Declaratory Statement in response to a request received from Miami-Dade County Building Department, on December 5, 2003, amended on March 26, 2004 and supplemented on April 14, 2004. It was assigned the number DCA03-DEC-325. The Commission determined that a conditioned space located beneath an insulated roof is not an attic, and that this conditioned space may share the air-conditioning system used to air-condition the building or residence. A copy of the Declaratory Statement be obtained by writing: Paula P. Ford, Commission Clerk, Department of Community Affairs, 2555 Shumard Oak Boulevard, Tallahassee, Florida 32399-2100.