



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

Code Change Cycle: 2013 Triennial Original Modification 7/1/2012 - 8/2/2012 Motion Goldsmith – 2nd Warseck Vote:9Y-1N Motion to reconsider Goldsmith – 2nd Warseck

Motion to accept: Ross 2nd Cone – Vote 10Y-0N

TAC: Roofing **Total Mods for this TAC:** 260

SubCode: Building

15-Roof Assemblies and Rooftop Structures

<u>Mod #</u>	<u>Chapter</u>	<u>Section</u>	<u>Proponent</u>	<u>Summary</u>	Pending Review	
5258	15	1502	Mark Zehnal	Provides current Florida-specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Swope
5341	15	1503.2 Flashing	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Cone
5340	15	1503.2.1 Locations.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Cone
5345	15	1503.4 Roof drainage.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Cone

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5342	15	1503.4.1 Secondary (emergency overlays)	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N
Motion to reconsider Warseck 2 nd Buckner Vote 10-0						Second: Swope
5344	15	1503.4.2 Scuppers.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N
						Second: Swope
5343	15	1503.4.2.1 Overflow scuppers.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N
						Second: Goldsmith
5346	15	1503.5 Roof ventilation.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N
						Second: Swope
5347	15	1503.6 Crickets and saddles.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 6Y-4N
NAR – not Florida specific.						Second: Buckner

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC: 260				
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5260	15	1503	Mark Zehnal	Provides current Florida-specific criteria		
<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	
Withdrawn by proponent.				TAC Vote:	Second:	
5348	15	1504.1.1 Wind resistance of asphalt shingles.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
				TAC Vote: 10Y-0N	Second: Swope	
5349	15	1504.3.2 Metal panel roof systems.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
				TAC Vote: 10Y-0N	Second: Goldsmith	
5350	15	1504.5 Edge securement for low-slope roofs.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
				TAC Vote: 10Y-0N	Second: Goldsmith	
5351	15	1504.6 Physical properties.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
				TAC Vote: 10Y-0N	Second: Swope	

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5352	15	1504.6 Physical properties.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10-Y-0N Second: Goldsmith
Should reference 1504.7 not 1504.6						
5353	15	1504.8 Aggregate.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5354	15	1504.9 Margin of Safety.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent in favor of mod 5686.						
5686	15	1504.9	James L. Buckner P.E.@CBUCK Engineering	To reinstate the margin of safety from the 2007 and 2010 FBC that is applicable to the roof assemblies performance requirements, section 1504.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5262	15	1504	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5355	15	1505.2 Class A roof assemblies.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 6Y-4N Second: Swope
No data that technically supported Florida specific need.						
5356	15	1505.7 Special purpose roofs.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-N Second: Swope
5264	15	1505	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5357	15	1506.5 Nails.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5358	15	1506.6 Screws.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5359	15	1506.7 Clips.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5266	15	1506	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5270	15	1507.10 Built-up roofs.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Goldsmith
5409	15	1507.10.3 Red rosin paper.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5280	15	1507.17 Photovoltaic modules/shingle	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input checked="" type="checkbox"/> s. AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5410	15	1507.17 Photovoltaic modules/shingle	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Withdrawn by proponent.							

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5360	15	1507.2.3 Underlayment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria. Provide correct Types for previously approved ASTM D 4869.	

Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	-------------------------	----------------------

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5361	15	1507.2.5 Asphalt shingles.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	-------------------------	----------------------

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5362	15	1507.2.6.1	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	


Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	-------------------------	----------------------

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5364	15	1507.2.7 Attachment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	-------------------------	----------------------

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5363	15	1507.2.7.1 Wind Resistance of Asphalt Shingles	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Cone

Mod needs rework and consideration of public comment and TAC is in favor of the intent of the mod.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5368	15	1507.2.8 Underlayment application.	Mark Zehnal	Provides current 2010 Florida Building Code -specific slope criteria addressed in DEC Statement DCA08-DEC-331 and removes unnecessary language.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Swope

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5562	15	1507.2.8 Underlayment application.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Cone

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5365	15	1507.2.8.1 High wind attachment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 8Y-1N **Second:** Swope

Motion to reconsider Swope 2nd Zehnal Vote 9Y-0N
New 2nd swope Vote 9Y-0N


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5569	15	1507.2.8.1 High wind attachment.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	

Comment AS AM NAR W I **TAC Vote:** **Second:**

Withdrawn by proponent.

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5367	15	1507.2.8.2 Ice barrier	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Swope
5370	15	1507.2.9.1 Base and counter flashing.	Mark Zehnal	Provides current 2010 Florida Building Code -specific slope criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
Clean up computer symbols.						
5371	15	1507.2.9.2 Valleys.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5372	15	1507.2.9.3 Drip edge.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5273	15	1507.3 Clay and concrete tile.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Swope
Swope withdrew 2 nd . Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5587	15	1507.3 Clay and concrete tile.	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Swope
Staff to remove reference to specific edition of the FRSA/TRI Manual. Needs general work on formatting as well as consistency throughout.						
5373	15	1507.3.1 Deck requirements.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5374	15	1507.3.2 Deck slope.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5588	15	1507.3.2	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Swope
Withdrawn by proponent.						
5378	15	1507.3.3 Underlayment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5375	15	1507.3.3.1 Slope and underlayment requirements.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5590	15	1507.3.3.1	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR to allow proponent to correct reference standard.						
5376	15	1507.3.3.2 High-slope roofs.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5377	15	1507.3.3.3 High wind attachment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5570	15	1507.3.3.3 High wind attachment.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5589	15	1507.3.3	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR to correct reference standard. Also just because it was previously in the FBC Code is not a rationale to carry it forward.						
5380	15	1507.3.6 Fasteners.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5591	15	1507.3.6	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR to correct reference standard.						
5798	15	1507.3.6	Randall Shackelford	Adds methods for determining corrosion resistance of screws for roof tile.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5381	15	1507.3.7 Attachment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Cone
2 nd withdrawn. Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5592	15	1507.3.7	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR to correct reference standard.						
5382	15	1507.3.8 Application.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5593	15	1507.3.8	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR to correct reference standard.						
5384	15	1507.3.9 Flashing.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5594	15	1507.3.9	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR to correct reference standard.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5275	15	1507.4 Metal roof panels.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0-9 Second: Swope
Cone motion to table. 2 nd - Boyer Removed from table. Duplicative						
5385	15	1507.4.4 Attachment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5563	15	1507.4.5 Underlayment and high wind.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5386	15	1507.4.5 Underlayment	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR - Inconsistent with action taken on mod 5563.						
5276	15	1507.5 Metal roof shingles.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9-0 Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5387	15	1507.5.2.1	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0 Second: Swope
5388	15	1507.5.3 Underlayment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9-0 Second: Swope
5564	15	1507.5.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0 Second: Swope
5389	15	1507.5.4 Ice barrier.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-1N Second: Swope
Doesn't take into consider consideration North Florida conditions.						
5390	15	1507.5.7 Flashing.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-1N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5278	15	1507.6 Mineral-surfaced roll roofing.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion Zehnal 2 nd Warseck to table. Vote 10Y-0N Motion to untable 2 nd Ross Vote 10Y-0N 2 nd Cone – 0Y-10N NAR – duplicative to previous action.						
5392	15	1507.6.3 Underlayment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5565	15	1507.6.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5391	15	1507.6.3.1 Underlayment and high wind.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5394	15	1507.6.4 Ice barrier.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC: 260					
Mod #	Chapter	Section	Proponent	Summary			Pending Review
5395	15	1507.6.5 Material standards.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Cone
5281	15	1507.7 Slate shingles.	Mark Zehnal	Provides current Florida-specific criteria			
<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Motion to Table Zehnal 2 nd Ross ...Vote 10Y-0N Motion to untable Zehnal 2 nd Boyer Vote 10Y-0N 2 nd Swope – Vote 0Y-10N NAR – duplicative based on previous action of the TAC.							
5396	15	1507.7.3 Underlayment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
5566	15	1507.7.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
5398	15	1507.7.4 Ice barrier.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N	Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC: 260					
Mod # 5399	Chapter 15	Section 1507.7.7 Flashing.	Proponent Mark Zehnal	Summary Provides current 2010 Florida Building Code specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
Mod # 5286	Chapter 15	Section 1507.8 Wood shingles.	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Motion to table Zehnal 2 nd Boyer – Vote 10Y-0N Motion to untable Zehnal 2 nd Cone Vote- 10Y-0N 2 nd Cone – 0Y-10N NAR – duplicative.							
Mod # 5400	Chapter 15	Section 1507.8.1.1 Solid sheathing required.	Proponent Mark Zehnal	Summary Provides current 2010 Florida Building Code specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
Mod # 5401	Chapter 15	Section 1507.8.3 Underlayment.	Proponent Mark Zehnal	Summary Provides current 2010 Florida Building Code specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
Mod # 5567	Chapter 15	Section 1507.8.3 Underlayment.	Proponent Mark Zehnal	Summary Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5402	15	1507.8.4 Ice barrier.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Swope
5403	15	1507.8.8 Flashing.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5284	15	1507.9 Wood shakes.	Mark Zehnal	Provides current Florida-specific criteria	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Zehnal motion to table 2 nd Swope – Vote 10Y-0N Motion to untable Zehnal 2 nd Cone – Vote 10Y-0N 2 nd Swope Vote 0Y-10N. NAR - duplicative					
5404	15	1507.9.1.1 Solid sheathing required.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5405	15	1507.9.2 Deck slope.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Swope
NAR -No Florida specific aspects or data to support the rationale.					

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5406	15	1507.9.3 Underlayment.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5568	15	1507.9.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5407	15	1507.9.4 Ice barrier.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Swope
5408	15	1507.9.9 Flashing.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5268	15	1507	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion to table Zehnal 2 nd Ross – Vote 10Y-0N Motion to untable Zehnal 2 nd Ross – Vote 10Y-0N 2 nd Zehnal Vote – 0Y-10N NAR – duplicative based on previous action.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5738	15	1508.1 General	Deborah Lawson	Use of above-deck thermal insulation -- adds Factory Mutual reference for cellular concrete.	

Comment AS AM NAR W I **TAC Vote:** **Second:**

Motion to table Cone 2nd Swope Vote 10Y-0N
 Motion to untable Zehnal 2nd Warseck – Vote 10Y-0N.
 2nd – Cone – Vote 1Y-9N \

NAR – needs a reference standard, belongs in ch 19, and concern with language “or equivalent”.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5739	15	1508.2 Material Standards for Roof Insulation	Deborah Lawson	Adds Lightweight Insulating Concrete and appropriate ASTM reference to chart of “material standards for roof insulation.”	

Comment AS AM NAR W I **TAC Vote:** **Second:**

Motion to table Cone 2nd Swope – Vote 10Y-0N
 Motion Warseck to untable, 2nd Cone – 10Y-0N.
 2nd – Cone Vote 10Y-0N

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5411	15	1509.6.4 Equipment and appliances on roof	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 6Y-4N **Second:** Cone

NAR due to duplicity and no Florida specific to support modification.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5412	15	1509.6.5 Mechanical units.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 6Y-3N **Second:** Swope

NAR – belongs in Mechanical code and there does not appear to have Florida specific rationale.


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5288	15	1509	Mark Zehnal	Provides current Florida-specific criteria	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Warseck

NAR – duplicative.

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC: 260				
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5413	15	1510.3 Recovering versus replacement.	Mark Zehnal	Provides current 2010 Florida Building Code specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5291	15	1510	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion to table Zehnal 2 nd Cone. Vote- 10Y-0N Motion to untable zehnal 2 nd Goldsmith Vote 10Y-0N. 2 nd Goldsmith – Vote 0Y-10N NAR – duplicative.						
5731	15	1510	Katherine Cleary	Vague code language. Set forth an allowable moisture by weight content roof membrane and insulation will give determine the suitability of the existing roof to receive a re-roof or a re-cover.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 2Y-8N Second: Warseck
NAR – lack of Florida specificity, and needs supportive documentation, however the concept is supportive with issues met.						
5944	15	1512	Craig Chown	Existing codes are not germane to new technology EPOX-Z roof coatings. Standards needed for "real world" conditions to protect the public include ASTM D5894 (weatherability); ASTM D1635 (permeability); ASTM D714 (blistering); ASTM D1654 (corrosion resistance); ASTM D4214 (chalking).		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y10-N Second: Cone
NAR outside the scope of Florida product approval system and no Florida specific need.						
5465	15	1514.4	Michael Goolsby	Section Formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC: 260				
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4958	15	1515.2.2.1	Michael Goolsby	Establish minimum roof slopes consistent with base code		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
4959	15	1516	Michael Goolsby	Roof Fire Classification		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Cone
5742	15	1517.3 through 1517.6	Deborah Lawson	Existing section 1917 is a Florida-specific code not in the base code. It is of importance to Florida including HVHZs. FRDA believes LWIC is more appropriate to address in the Roofing Insulation Code since it is a roofing insulation material.		
<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 2Y-8N Second: Cone
NAR – not Florida specific.						
5746	15	1519.5.3 Lightweight insulating concrete.	Deborah Lawson	Technical correction to terminology.		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Ross
5925	15	1519.5.3 Lightweight insulating concrete.	Deborah Lawson	Technical correction to terminology.		
<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260	
Mod # 5749	Chapter 15	Section 1521.20	Proponent Deborah Lawson	Summary Technical correction to terminology.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Goldsmith
Mod # 5748	Chapter 15	Section 1521.7	Proponent Deborah Lawson	Summary Technical correction to terminology.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Ross
Mod # 4960	Chapter 15	Section 1522	Proponent Michael Goolsby	Summary Elevation of rooftop equipment	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y – 2N Second: Zehnal
Mod # 5612	Chapter 15	Section Table 1503.2	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Warseck
NAR – duplicative.						
Mod # 5414	Chapter 15	Section TABLE 1507.4.3(1) METAL ROOF COVERINGS	Proponent Mark Zehnal	Summary Provides current 2010 Florida Building Code specific criteria.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – believed to be duplicative.						

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

35-Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Pending Review
6020	35	ASTM	Craig Chown	Includes ASTM reference standards for cool roof coating products as a supplement to proposals under Section 1512.5 in a related modification.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: No 2 nd – dies.
Mod #	Chapter	Section	Proponent	Summary	Pending Review
5586	35	SECTION - REFERENCED STANDARDS	Mark Zehnal	Provides update to previous Commission approved code referenced standard.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

SubCode: Existing Building

1-Scope and Administration

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5140	1	101	Ken Cureton	Modify SECTION 101.6 ADD SECTION 101.8	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5937	2	202	Ken Cureton	Modify SECTION 202 (Roofing TAC)	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

4-Prescriptive Compliance Method

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5940	4	412	Ken Cureton	Add SECTION 412		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal

7-Alterations - Level 1

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4967	7	[B]706.1	Michael Goolsby	Section formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Ross
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5244	7	711.7.2	Mark Zehnal	Include ASTM D 4869 Type II & Type IV as underlayment option to correlate with underlayment's available in Chapter 9 of the Florida Residential Code and clarify fastening installation language.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5239	7	711	Mark Zehnal	Move current Florida-specific criteria to Residential Code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Ross

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5241	7	711	Mark Zehnal	Provides current Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 0Y-10N Second: Zehnal</p> <p>NAR – duplicative.</p>					


SubCode: Residential

9-Roof Assemblies

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5631	9	R901.1	Michael Goolsby	Section formatting	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					
5297	9	R901	Mark Zehnal	Provides current Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					
5472	9	R902.1 Roofing covering materials.	Mark Zehnal	Provides current 2010 FBC Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 6Y-4N Second: Swope</p> <p>NAR – No data presented to cause reclassification and changes the foundation code.</p>					

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5298	9	R902	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Swope
NAR – does not provide data to support reclassification and changes the base code.						
5473	9	R903.2.1 Locations.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Warseck
5474	9	R903.2.2 Crickets and saddles.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 6Y-4N Second: Goldsmith
NAR - No Florida specific requirement and consistent with action on the building code companion.						
5475	9	R903.2.3 Membrane flashings.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5478	9	R903.4 Roof drainage.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260
Mod # 5476	Chapter 9	Section R903.4.1	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria	Pending Review
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 7Y- 3N Second: Cone</p> <p>NAR – no Florida specific requirement.</p>					
Mod # 5477	Chapter 9	Section R903.4.2 One and two family dwellings, and private	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria	Pending Review
<p>Comment <input type="checkbox"/> AS <input checked="" type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 5Y- 5N Second: Swope</p> <p>NAR – no Florida specific.</p>					
Mod # 5299	Chapter 9	Section R903	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria	Pending Review
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 0Y– 10N Second: Zehnal</p> <p>NAR – duplicative.</p>					
Mod # 5482	Chapter 9	Section R904.4 Product identification	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria	Pending Review
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second: Goldsmith</p> <p>Motion to table Ross, 2nd Goldsmith – vote 9Y-1N Motion to untable Ross 2nd Swope – Vote 10Y -0N Withdrawn by proponent.</p>					
Mod # 5483	Chapter 9	Section R904.4 Product identification	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria	Pending Review
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second: Goldsmith</p> <p>2nd withdrawn by Goldsmith Motion to table Cone 2nd Ross 10Y-0N Motion to untable Ross 2nd Swope 10Y-0N Withdrawn by proponent.</p>					

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5479	9	R904.4.1 Nails.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Motion to table Cone 2nd Ross 10Y-0N Motion to table Cone 2nd Ross 10Y-0N Motion to untable Ross 2nd Swope 10Y-0N Withdrawn by proponent.</p>					
5480	9	R904.4.2 Screws.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Motion to table Cone 2nd Ross 10Y-0N Motion to table Cone 2nd Ross 10Y-0N Motion to untable Ross 2nd Swope 10Y-0N Withdrawn by proponent.</p>					
5481	9	R904.4.3 Clips.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Motion to table Cone 2nd Ross 10Y-0N Motion to table Cone 2nd Ross 10Y-0N Motion to untable Ross 2nd Swope 10Y-0N Withdrawn by proponent.</p>					
5300	9	R904	Mark Zehnal	Provides current Florida-specific criteria	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Goldsmith</p>					
5306	9	R905.10 Metal roof panels.	Mark Zehnal	Provides current Florida-specific criteria	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 0Y-10N Second: Zehnal</p> <p>NAR – duplicative.</p>					

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5541	9	R905.10.2.1 Underlayment	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Swope

NAR – no Florida specific rationale.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5542	9	R905.10.3 Material standards.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	

Comment AS AM NAR W I **TAC Vote:** **Second:** Ross

Motion to table Zehnal 10Y-0N
Motin to untable – Zehnal 2nd Ross Vote 10Y-0N
2nd to for a neg vote Cone Vote 0Y-10N
NAR - duplicative

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5544	9	R905.10.4 Attachment.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Swope

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5543	9	R905.10.4.1 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	


Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Cone

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5561	9	R905.10.5 Underlayment and high wind.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Cone

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5545	9	R905.10.5.1 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5309	9	R905.11 Modified bitumen roofing.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5547	9	R905.11.3 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5310	9	R905.12 Thermoset single-ply roofing.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5548	9	R905.12.3 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5311	9	R905.13 Thermoplastic single-ply	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5549	9	R905.13.3 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5313	9	R905.14 Sprayed polyurethane foam	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5550	9	R905.14.3 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5305	9	R905.15 Liquid-applied roofing.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260
Mod # 5551	Chapter 9	Section R905.15.3 Application.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					
TAC Vote:					Second:
Mod # 5552	Chapter 9	Section R905.16 Photovoltaic modules/shingle	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input checked="" type="checkbox"/> s. AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Swope
Mod # 5302	Chapter 9	Section R905.16	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					
TAC Vote:					Second:
Mod # 5553	Chapter 9	Section R905.17 SOLAR PHOTOVOLTAIC C PANELS/MODU LES	Proponent Mark Zehnal	Summary Provides requirements for Photovoltaic Systems not considered with Integrated Roofing Photovoltaic. Incorporates intent of foundation code in chapter 15 of IBC- Section 1511.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Swope
Mod # 5484	Chapter 9	Section R905.2.2 Slope.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Cone

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5485	9	R905.2.3 Underlayment.	Mark Zehnal	Provides current Florida-specific criteria for shingle underlayment. Provide correct Types for previously approved ASTM D 4869.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5486	9	R905.2.4.1 Wind resistance of asphalt shingles	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5487	9	R905.2.6.1 Wind Resistance of Asphalt Shingles.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
Motion to reconsider Cone 2 nd Zehnal 2nd Cone – Vote 0Y-10N						
5490	9	R905.2.7 Underlayment application.	Mark Zehnal	Provides current Florida-specific slope criteria addressed in DEC Statement DCA08-DEC-331 and removes unnecessary language.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR – in difference to 5555.						
5555	9	R905.2.7 Underlayment Application.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5488	9	R905.2.7.1 Ice barrier.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Cone
5489	9	R905.2.7.2 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5491	9	R905.2.8.1 Base and cap flashing.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5492	9	R905.2.8.2 Valleys.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5493	9	R905.2.8.3 Sidewall flashing.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5494	9	R905.2.8.5 Drip edge.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Cone
5304	9	R905.3 Clay and concrete tile.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – duplicative.						
5505	9	R905.3 Clay and concrete tile.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5602	9	R905.3 Clay and concrete tile.	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – changing the manual.						
5495	9	R905.3.1 Deck requirements.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5496	9	R905.3.2 Deck slope.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5601	9	R905.3.2	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR for the purpose of correcting the manual.						
5500	9	R905.3.3 Underlayment.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5497	9	R905.3.3.1 Low slope roofs.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5599	9	R905.3.3.1	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – typographical error.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5498	9	R905.3.3.2 High slope roofs	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5499	9	R905.3.3.3 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 4Y-6N Second: Brown
NAR –needs to be clarified.						
5600	9	R905.3.3	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y10N Second: Swope
NAR – reference standard needs to be corrected						
5501	9	R905.3.6 Fasteners.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5598	9	R905.3.6	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – title issue.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5799	9	R905.3.6	Randall Shackelford	Adds methods for determining corrosion resistance of screws for roof tile.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Goldsmith
5503	9	R905.3.7 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote:
					Second:
5502	9	R905.3.7.1 Hip and ridge tiles	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote:
					Second:
5596	9	R905.3.7.1	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – title issue.					TAC Vote: 0Y-10N
					Second: Zehnal
5597	9	R905.3.7	Mark Zehnal	Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – title issue.					TAC Vote: 0Y-10N
					Second: Zehnal

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260	
Mod # 5504	Chapter 9	Section R905.3.8 Flashing.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.		Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
Mod # 5595	Chapter 9	Section R905.3.8	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – title issue.						
Mod # 5603	Chapter 9	Section R905.3	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria including update to previous Commission approved code referenced standard.		Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – title issue.						
Mod # 5307	Chapter 9	Section R905.4 Metal roof shingles.	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria		Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – formatting clarification/duplicative.						
Mod # 5556	Chapter 9	Section R905.4.3 Underlayment.	Proponent Mark Zehnal	Summary Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Cone

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260		
Mod # 5506	Chapter 9	Section R905.4.3.1 Ice barrier.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N	Second: Cone
Mod # 5507	Chapter 9	Section R905.4.3.2 Underlayment and high winds.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Cone
NAR – formatting.							
Mod # 5508	Chapter 9	Section R905.4.4 Material standards.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Swope
Mod # 5509	Chapter 9	Section R905.4.5 Application.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second: Swope
Motion to amend – restore the word “be”. Warseck 2 nd – Zehnal Vote 10Y-0N Motion to approve – Warseck 2 nd Zehnal Vote 10Y-0N							
Mod # 5510	Chapter 9	Section R905.4.6 Flashing.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N	Second: Warseck

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5308	9	R905.5 Mineral-surfaced roll roofing.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – duplicative.						
5513	9	R905.5.3 Underlayment.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria. Provide correct Types for previously approved ASTM D 4869.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5557	9	R905.5.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5511	9	R905.5.3.1 Ice barrier.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5512	9	R905.5.3.2 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5514	9	R905.5.4 Material standards.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5312	9	R905.6 Slate and slate-type shingles.	Mark Zehnal	Provides current Florida-specific criteria	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – duplicative.					
5558	9	R905.6.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
NAR – formatting and ice barrier/North Florida issue.					
5515	9	R905.6.3.1 Ice barrier.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 7Y-2N Second: Swope
5516	9	R905.6.3.2 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Boyer
NAR – duplicative.					

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260
Mod # 5518	Chapter 9	Section R905.6.6 Flashing.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Cone
Mod # 5519	Chapter 9	Section R905.6.7	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
Mod # 5315	Chapter 9	Section R905.7 Wood shingles.	Proponent Mark Zehnal	Summary Provides current Florida-specific criteria	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR – duplicative.					
Mod # 5520	Chapter 9	Section R905.7.1.1 Solid sheathing required.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Swope
Mod # 5559	Chapter 9	Section R905.7.3 Underlayment..	Proponent Mark Zehnal	Summary Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Swope
NAR – additional data required.					

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing		Total Mods for this TAC:			260
Mod # 5521	Chapter 9	Section R905.7.3.1 Ice barrier.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 8Y-2N					Second: Swope
Mod # 5522	Chapter 9	Section R905.7.3.2 Underlayment and high winds.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 8Y-2N					Second: Swope
Mod # 5523	Chapter 9	Section R905.7.5 Application.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Swope
Mod # 5525	Chapter 9	Section R905.7.6 Valley flashing	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Swope
Mod # 5524	Chapter 9	Section R905.7.6.1 Fasteners.	Proponent Mark Zehnal	Summary Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Swope

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5526	9	R905.7.7 Label required	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5527	9	R905.7.8 Flashing.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Swope
<p>Warseck motion to amend to change flashing size to 8" 2nd-Goldsmith Vote not taken – Motion and 2nd withdrawn. Cone motion to change .017mm to .019mm which was not caught in glitch last time. 2nd Zehnal. Vote 10Y-0N Vote to approve as amended 10Y-0N</p>						
5528	9	R905.7.9 Label required	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Zehnal
5314	9	R905.8 Wood shakes.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Zehnal
<p>NAR – duplicative.</p>						
5529	9	R905.8.1.1 Solid sheathing required.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5539	9	R905.8.10 Flashing.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review	
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
<p>Motion to amend .017mm to .019mm Cone 2nd Warseck Vote 10Y-0N Motion to approve mod as amended. Zehnal 2nd Cone – Vote 10Y-0N</p>						
5530	9	R905.8.2 Deck slope.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Zehnal
5560	9	R905.8.3 Underlayment.	Mark Zehnal	Incorporates intent of foundation code for attachment of underlayment in high wind section and unifies installation guidelines of underlayment with current Florida-specific criteria.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
<p>NAR – to correct the reference standard. Un-strike the exception.</p>						
5531	9	R905.8.3.1 Ice barrier.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Cone
5532	9	R905.8.3.2 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-2N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5533	9	R905.8.3.2 Underlayment and high winds.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 7Y-2N Second: Zehnal
5534	9	R905.8.4 Interlayment.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Zehnal
Motion to reconsider Cone 2 nd Swope - Vote 10Y-0N vacates previous action. 2 nd Cone - Vote 10Y-0N						
5535	9	R905.8.6 Application.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
5537	9	R905.8.7 Shake placement	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Cone
5536	9	R905.8.7.1 Fasteners.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5538	9	R905.8.8 Valley flashing.	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Swope
5303	9	R905.9 Built-up roofs.	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-oN Second: Goldsmith
5540	9	R905.9.2.1	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Goldsmith
Withdrawn by proponent.						
5301	9	R905	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Boyer
NAR – formatting and other issues.						
5554	9	R907 REROOFING	Mark Zehnal	Moves current Florida-specific criteria from Existing Buildings volume used in residential reroofing to the Residential volume.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Swope
NAR – formatting corrections.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review


TAC: Roofing		Total Mods for this TAC: 260				
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5316	9	R907	Mark Zehnal	Provides current Florida-specific criteria		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Cone
NAR – inconsistent with prior action.						
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5546	9	TABLE R905.11.2 MODIFIED BITUMEN ROOFING MATERIAL	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Swope
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5517	9	TABLE R905.6.5 SLATE SHINGLE HEADWAP	Mark Zehnal	Provides and carries forward current 2010 FBC Florida-specific criteria. bottom of table should be (Slope greater than or equal to 20:12) will not take when submitted.		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Zehnal
Motion to amend Cone 2 nd Warseck - Staff to correct to state “= or greater than” Vote 10Y-0N Motion to additional amendment Ross 2 nd Buckner – to readmit table as in 2010 FBC, Residential – Vote 10Y-0N Motion to approve as double amended Zehnal 2 nd Swope – 10Y-0N						

23-Solar Energy Systems

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4980	23	2301.2.2	Michael Goolsby	Section formatting		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Zehnal
Motion to amend to correct parenthetical statement – 2 nd Ross – Vote 10Y-0N Motion to approve as amended Warseck 2 nd Buckner Vote 10Y-0N.						

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4982	23	2302.2.1	Michael Goolsby	Section formatting	

Comment AS AM NAR W I **TAC Vote:** **Second:** Zehnal

Motion to amend to correct parenthetical statement – Staff to correct – Cone 2nd Warseck – Vote – 10Y-0N
 Motion to approve as amended Cone 2nd Goldsmith – Vote 10Y-0N

44-HVHZ

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5008	44	4401	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Goldsmith

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5009	44	4402	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Goldsmith

45-Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5604	45	SECTION - REFERENCED STANDARDS	Mark Zehnal	Provides update to previous Commission approved code referenced standard.	


Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Cone

SubCode: Test Protocols

1-110

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5035	1	15	Jaime Gascon	Correlating reference weathering standards with latest versions already adopted in base code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Goldsmith

1-114

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5037	1	2.7	Jaime Gascon	Correlating reference weathering standards with latest versions already adopted in base code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Goldsmith

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5039	1	8.7	Jaime Gascon	Correlating reference weathering standards with latest versions already adopted in base code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Goldsmith


1-131

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5040	1	2 & 10.17 & 10.18	Jaime Gascon	Correlating reference weathering standards with latest versions already adopted in base code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Goldsmith

1-138

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Roofing

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Roofing **Total Mods for this TAC:** 260

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5042	1	2 & 8.4 & 9.3	Jaime Gascon	Correlating reference weathering standards with latest versions already adopted in base code.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I					TAC Vote: 10Y-0N Second: Goldsmith

1-143

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5044	1	2 & 7.11	Jaime Gascon	Correlating reference weathering standards with latest versions already adopted in base code.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I					TAC Vote: 10Y-0N Second: Zehnal

Search Criteria

Modification #: ALL Code Change Cycle: ALL Chapter & Topic: ALL Date Submitted From: ALL TAC: R Commission Action: ALL Proponent First Name: ALL Related Modifications: ALL	Code Version: 2013 Sub Code: ALL Section: ALL Date Submitted To: ALL TAC Recommendation: ALL Proponent Last Name: ALL Text of Modification: ALL Affects HVHZ: ALL
--	--

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)