



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

Code Change Cycle: 2013 Triennial Original Modification 7/1/2012 - 8/2/2012

Motion to Approve -

TAC: Structural

Total Mods for this TAC: 236


SubCode: Building

2-Definitions

<u>Mod #</u>	<u>Chapter</u>	<u>Section</u>	<u>Proponent</u>	<u>Summary</u>	<u>Pending Review</u>		
5190	2	202	Joe Bigelow	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code			
<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Withdrawn by proponent.							
5633	2	202	Dwight Wilkes	Reason: The overall intent of this proposal is to clarify the requirements for tubular daylighting devices, within the context of skylights and sloped glazing.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
5726	2	202	Joseph Belcher	Brings forward definition of screen enclosure.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
5727	2	202	Joseph Belcher	Brings forward definition of screen enclosure.			
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5936	2	202	Joseph Belcher	Retains definition of awning as companion to Mod 5932	

Comment AS AM NAR W I

TAC Vote: 0Y-10N

Second: Glenn

NAR – TAC supports the mod in concept with a comma added after the word “moveable” and to consider the word ‘fixed’ for ‘rigid’ -

14-Exterior Walls

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4926	14	1401.1	Michael Goolsby	Delete HVHZ Sections	

Comment AS AM NAR W I

TAC Vote: 10Y-0N

Second: Glenn

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5733	14	1404.13	Joseph Belcher	Provides reference to labeling requirements for manufactured soffits.	

Comment AS AM NAR W I

TAC Vote: 10Y-0N

Second: Macomber

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4801	14	1404.5.1	Michael Goolsby	Section formatting	

Comment AS AM NAR W I

TAC Vote: 10Y-0N

Second: Strawn


As submitted with consideration for computer error.

TAC Recommendations Key

AS = Approved as Submitted

AM = Approved as Modified **NAR** = No Affirmative Recommendation

W = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236				
Mod # 4931	Chapter 14	Section 1405.1	Proponent Michael Goolsby	Summary Section formatting	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
Mod # 5728	Chapter 14	Section 1405.1	Proponent Joseph Belcher	Summary Brings forward modifications to AAMA 1402.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Kim
Mod # 4932	Chapter 14	Section 1405.17	Proponent Michael Goolsby	Summary Section formatting	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Gascon
Mod # 4922	Chapter 14	Section 1410	Proponent Oriol Haage	Summary Delete HVHZ Sections	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
Mod # 4933	Chapter 14	Section Table 1405.2	Proponent Michael Goolsby	Summary Section formatting	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Gascon

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural

Total Mods for this TAC: 236

16-Structural Design

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5425	16	1601.1	Michael Goolsby	Section formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll
5116	16	1605	Suzanne Davis	Section 1605.3.1.1 Declaratory statement determined by the Commission. To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Parrino
NAR – already covered by the reference standard.						
5118	16	1609 Wind Loads	Suzanne Davis	Figure 1609 A, B, C Wind Maps added To be consistent with the 2010 FBC Wind maps to continue to provide for improved resolution for the maps and to implement the Commission plan to update the 2013 Code		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – to allow staff to correct title and note 1.						
5121	16	1609.1 Exceptions	Suzanne Davis	Update Exception 5 to be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Kim
AM - Correct formatting/underline.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5608	Chapter 16	Section 1609.1.1	Proponent T Stafford	Summary Correlation with the 2010 FBC and ASCE 7-10 wind speeds.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Macomber
Mod # 5732	Chapter 16	Section 1609.1.1	Proponent Joseph Belcher	Summary This mod provides a reference to section 2002.4 for the determination of wind loads on screen enclosures.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5667	Chapter 16	Section 1609.1.2.1	Proponent Joseph Belcher	Summary Adds impact resistant covering as option to protect louvers.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 7Y-3N	Second: Glenn
NAR – creates a life safety issue for essential facilities.							
Mod # 5951	Chapter 16	Section 1609.1.2.1	Proponent Amanda Hickman	Summary Corrects misprint in 2012 IBC on AMCA 540 - test standard for louvers.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5668	Chapter 16	Section 1609.1.2.2	Proponent Joseph Belcher	Summary Provides correlation between ASTM E 1996, FBCB, and ASCE 7-10 regarding Wind Zone 4.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 2Y-8N	Second: Glenn
NAR – Weakens the code.							

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC:		236	
Mod # 5759	Chapter 16	Section 1609.1.2.3	Proponent Jim Heise	Summary Section 1609.1.2.4 Impact resistant coverings. Add text to read as shown.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.					
Mod # 5669	Chapter 16	Section 1609.1.2.4	Proponent Joseph Belcher	Summary Establishes factor of safety for testing of impact resistant coverings and provides reference to labeling requirements for impact resistant coverings.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-1N Second: Kim
Mod # 5715	Chapter 16	Section 1609.1.2.5	Proponent Joseph Belcher	Summary Retains alternate for testing side-hinged steel exterior doors.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 4Y-6N Second: Glenn
NAR - No Florida specific need					
Mod # 5707	Chapter 16	Section 1609.1.2	Proponent Joseph Belcher	Summary Retains provisions related to glazed opening protection; impact standards; statutory provisions related to storage sheds; and opening protection for sunrooms.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – for correction of the grammatical and punctuation issues and possibly correcting section numbers.					
Mod # 5607	Chapter 16	Section 1609.1	Proponent T Stafford	Summary Clarifies the applicable wind loads for soffits.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion to table Gascon 2 nd Carroll Vote 10Y-0N Motion to remove from table Glenn based on need for NAR - 2 nd Gascon Vote 0Y-10N based on action on 5734.					

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5734	Chapter 16	Section 1609.1	Proponent Joseph Belcher	Summary Carries forward provision stipulating exterior wall coverings and soffits to be designed to resist C&C loads and reference to labeling requirements for soffits.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Macomber
Mod # 5613	Chapter 16	Section 1609.4.2	Proponent T Stafford	Summary Reinstates the open patch limitations for Surface Roughness C from the 2010 FBCB.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Lavrich
Mod # 5321	Chapter 16	Section 1609.7	Proponent Joseph Hetzel	Summary Inclusion of garage door / rolling door wind load Table.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Glenn
NAR – to clarify the table.							
Mod # 5643	Chapter 16	Section 1616.3	Proponent Bonnie Manley	Summary This proposal, submitted on behalf of the steel industry, revises the requirements for the deflection of structural roofing and siding made of formed metal sheets to be more consistent with current testing requirements found in the FBC.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Glenn
NAR – basis of waiting for support data and proponent to submit the data that is currently in testing to be presented prior to February Commission meeting. If data is not made available, suggest mod to be denied.							
Mod # 5433	Chapter 16	Section 1616.5	Proponent Michael Goolsby	Summary Add reference for Table 1607.1 footnote	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5429	Chapter 16	Section 1617	Proponent Michael Goolsby	Summary Delete HVHZ Section to adopt base code provisions	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5427	Chapter 16	Section 1618.9	Proponent Michael Goolsby	Summary Delete HVHZ Section to adopt base code provisions	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll
Mod # 5954	Chapter 16	Section 1626.1	Proponent Amanda Hickman	Summary Adds AMCA 540 to HWHZ section of the code.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Gascon
NAR – add cycling requirements for the HVHZ in the standard.							
Mod # 5955	Chapter 16	Section 1626.1	Proponent Amanda Hickman	Summary Adds AMCA 540 to HWHZ section of the code and clarifies language.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Kim
NAR – based on action on previous mod 5954.							
Mod # 5253	Chapter 16	Section 1626.2	Proponent Jaime Gascon	Summary Correlation to TAS201 and TAS203 and specify large missile speeds for essential facilities - Building Category IV.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Lavrich

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5729	16	Table 1604.3	Joseph Belcher	Adds screen enclosures to table; adds oercebtagge if solids for screen walls.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5949	16	Table 1604.5	Joseph Belcher	Retains screen enclosures as low hazard to humn life.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5431	16	Table 1607.1 footnotes	Michael Goolsby	Section formatting	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5610	16	Table 1609.1.2	T Stafford	Correlation with wind speeds in ASCE 7-10.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll
5611	16	Table 1609.1.2	T Stafford	Correlation with wind speeds in ASCE 7-10.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

17-Structural Tests and Special Inspections

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5324	17	1702, 1710.5.3	Joseph Hetzel	Inclusion of garage door labeling language.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5149	17	1702-09 Definitions	Suzanne Davis	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5024	17	1710 & 1711	Jaime Gascon	Reinstates all the exterior window and door assemblies' structural performance and standards from the 2010 FBC that are applicable to the HVHZ and are structural wind-related.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-9N Second: Gascon
NAR – proponent wishes to make some clarifications in the mod.						
5325	17	1710.5.2	Joseph Hetzel	Clarifies test requirements for sectional garage doors and rolling doors.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Gascon

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5582	17	1710.5	Dwight Wilkes	Reinstates exterior window and door assemblies structural performance and standards from the 2010 FBC and introduces language submitted to the ICC for inclusion into the 2015 IBC, thru modification to the Florida base code the 2012 IBC Proposals S173 and S172	Second: Lavrich	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-9N
NAR – based on proponents request to work with Jamie Gascon of Miami-Dade regarding the mod.						
5615	17	1710.5	T Stafford	Correlation with ASCE 7-10. Clarifies the appropriate reduction of design pressures for the purposes of testing of products that are and have been historically tested using allowable or nominal wind loads.	Second: Strawn	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N
5855	17	1710.5	James Bell	Component approvals are essential to door openings that are made of component. Hardware items such as hinges, locks, exit devices and bolts are the structural components and need to be rates and have quality assurance.	Second: Kim	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 4Y-6N
NAR – weakens the code.						
6007	17	1710.5	Kari Hebrank	Add new exception for custom doors. Allows accepted engineering practices such as rational or comparative analysis for one-of-a-kind custom doors. This language has been incorporated into every version of the Florida Building Code since 2002.	Second: Glenn	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 4Y-6N
NAR – weakens the code.						
6012	17	1710.5	Kari Hebrank	This proposed modification will allow approved door components to be interchanged in exterior door assemblies provided that the door components provide equal or greater performance. This change has been part of the 2004, 2007 and 2010 Florida Building Code.	Second: Glenn	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 4Y-6N
NAR – weakens the code. Proponent did not provide Florida specifics justification.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5635	17	1710.6	Dwight Wilkes	Reason: The overall intent of this proposal is to clarify the requirements for tubular daylighting devices, within the context of skylights and sloped glazing.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-9N Second: Carroll
NAR – no Florida specific need and this mod will lose the regulation of Tubular Daylight Devices.						
5712	17	1710.8	Joseph Belcher	Adds requirements labeling and installation of hurricane resistant coverings.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
5737	17	1710.9.4	Joseph Belcher	Brings forward existing provisions for soffit installation and testing.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Macomber
5736	17	1710.9	Joseph Belcher	Brings currently required labeling provisions for soffits forward.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
5623	17	1710	Dwight Wilkes	Reinstates the exterior window and door structural performance, standards and label from the 2010 FBC with modifications to clarify Existing FBC 1715.5.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – at proponents request to remove dates from mod language.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5760	17	1715.5.4.2	Jim Heise	1715.5.4.2 Masonry, concrete or other structural substrate. Add to read as shown.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Parrino</p> <p>Staff to correct typo in data.</p>					

18-Soils and Foundations

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4930	18	1801.1	Michael Goolsby	Remove guidance to HVHZ sections deleted as non-wind related.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Lavrich</p>					

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4934	18	1801.2	Michael Goolsby	Section formatting	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Lavrich</p>					

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4935	18	1806.1	Michael Goolsby	Section formatting	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Lavrich</p>					

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236			
Mod # 5958	Chapter 18	Section 1807.2.4	Proponent Joseph Belcher	Summary Retains criteria for design and construction of reinforced masonry retaining walls.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Parrino
Mod # 5007	Chapter 18	Section 1808.3	Proponent Michael Goolsby	Summary Section formatting	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Carroll
Mod # 4936	Chapter 18	Section 1810.3.9.4.1	Proponent Michael Goolsby	Summary Section formatting	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					
Staff clean up spacing.					
					TAC Vote:
					Second: Gascon
Mod # 4937	Chapter 18	Section 1810.3.9.4.2	Proponent Michael Goolsby	Summary Section formatting	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					
					TAC Vote:
					Second:
Mod # 5801	Chapter 18	Section 1816.1.7	Proponent Steven Dwinell	Summary Modify language to state that contracts offered for termite protection comply with Chapter 482, F.S., the Florida Structural Pest Control Act.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – weakens the base document .					
Motion to reconsider Gascon – 2 nd Glenn Vote 6Y-4N					
Vote - 6Y-4N					
NAR – weakens the base document.					
					TAC Vote: 4Y-6N
					Second: Macomber

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



TAC: Structural **Total Mods for this TAC:** 236


19-Concrete

<u>Mod #</u>	<u>Chapter</u>	<u>Section</u>	<u>Proponent</u>	<u>Summary</u>	Pending Review	
4943	19	1901.1	Michael Goolsby	Delete HVHZ Sections		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4942	19	1908.4	Michael Goolsby	Section Formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5619	19	1913	T Stafford	Reinstates requirements that gable endwalls be structurally continuous between points of lateral support. This language currently exists in the 2010 FBCB.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4941	19	1927 and 1928	Michael Goolsby	Deletion of HVHZ sections		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll

20-Aluminum

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5795	20	2001 and 2002	Joseph Belcher	Retains FBC design criteria for aluminum structures.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
5762	20	2002.6	Jim Heise	without this, screen enclosures can be misinterpreted as "window"; products as has occurred in other states		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – at the proponent's request.						
5792	20	2002.6	Joseph Belcher	Carries forward adoption of AAMA 2100; Carries forward and updates sunroom categories.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second:
Motion to table until after 5893 Lavrich 2 nd Gascon Vote 10Y-0N Motion to untable Glenn 2 nd Lavrich Vote 10Y-0N 2 nd Glen for NAR – NAR at proponents request to make corrections.						
4955	20	2003.6.3	Michael Goolsby	Formatting HVHZ reference necessary to maintain base code continuity.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll
4956	20	2003.8.2.1	Michael Goolsby	Section Formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5781	20	Table 2002.4	Joseph Belcher	Brings forward the table providing design wind pressures for screened enclosures.	

<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Withdrawn by proponent in favor of 5905.							

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5905	20	Table 2002.4	Joseph Belcher	Revises Note c of Mod 5781	

<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N	Second: Lavrich
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	------------------------	------------------------

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5789	20	Table 2002.4A	Joseph Belcher	Brings forward table with height adjustment factors for screen enclosure design.	

<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	-------------------------	------------------------


21-Masonry

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4957	21	2101.1	Michael Goolsby	Section Formatting	

<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll
----------------	--	-----------------------------	------------------------------	----------------------------	----------------------------	-------------------------	------------------------

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5974	Chapter 21	Section 2107.1	Proponent Joseph Belcher	Summary Retains exception to inspection requirements of adopted standard.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 1Y-9N	Second: Glenn
NAR – not required.							
Mod # 5962	Chapter 21	Section 2107.2	Proponent Joseph Belcher	Summary Clarifies application of MSJC and corrects erroneous reference to a section in MSJC.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll
Mod # 5963	Chapter 21	Section 2107.4	Proponent Joseph Belcher	Summary Deletes an unnecessary change to the MSJC.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Parrino
Mod # 5975	Chapter 21	Section 2107.4	Proponent Joseph Belcher	Summary Modify Mod 5963 to show section as reserved, rather than deleted.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5977	Chapter 21	Section 2107.4	Proponent Joseph Belcher	Summary Retains gamma factors for calculating lap length for development of bars in tension and compression.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Parrino

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod #	Chapter	Section	Proponent	Summary	Pending Review		
5979	21	2107.5	Joseph Belcher	Reinstates provision within MSJC dealing with lateral ties in pilasters.			
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll
5987	21	2107.5	Joseph Belcher	Revision of Mod 5979 to remove Section of TMS 402/ACI 530/ASCE 5, Section 1.15 from Mod as the Section is unchanged and was included solely for reference, not direct inclusion in the code.			
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Withdrawn by proponent.							
5973	21	2108.1	Joseph Belcher	Retains exception to inspection requirements of adopted standard.			
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Glenn
NAR – at proponents request.							
5980	21	2108.4	Joseph Belcher	Retains gamma factors for determining development length of reinforcement for strength design.			
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Parrino
5649	21	2109.1.1	T Stafford	This proposal reinstates the limit on using empirical design of masonry to areas where the Vult wind speed equals or exceeds 115 mph.			
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Macomber
Vult and other areas indicated through comments should be underlined. Proponent to correct.							

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5620	21	2114	T Stafford	Reinstates requirements that gable endwalls be structurally continuous between points of lateral support. This language currently exists in the 2010 FBCB.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
5982	21	2122.1	Joseph Belcher	Update section of standard cited.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Macomber
5981	21	2122.2.1	Joseph Belcher	Clarification of intent of section.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Gascon
NAR - Needs editorial changes/corrections.						
5993	21	2122.2.3	Joseph Belcher	Updates Section citation.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll
5983	21	2122.4	Joseph Belcher	Modifies reinforcement details.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236


Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5990	21	2122.5	Joseph Belcher	Modifies provisions related to concentrated loads.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Gascon
5991	21	2122.8.2	Joseph Belcher	Clarification and update of cited section number.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5992	21	2122.8.8	Joseph Belcher	Clarification and and adoption of TMS 602/ ACI 530.1/ ASCE 6 Section 3.5.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino

22-Steel

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4947	22	2201.1	Michael Goolsby	Section Formatting		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Glenn
Motion to approve as amended – with A4 Glenn, 2 nd Carroll Vote 10Y-0N						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5319	22	2201.1	Bonnie Manley	This proposal, submitted on behalf of the steel industry, clarifies the relationship between the HVHZ provisions and the model base code.	

Comment AS AM NAR W I

TAC Vote: **Second:**

Based on written documentation to be withdrawn by a representative of the proponent.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4948	22	2204.1	Michael Goolsby	Section Formatting	

Comment AS AM NAR W I

TAC Vote: 10Y-0N **Second:** Carroll

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4944	22	2210	Thomas Sputo	Add Standard for composite steel deck slabs to Section 2210	

Comment AS AM NAR W I

TAC Vote: 10Y-0N **Second:** Kim

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5621	22	2212	T Stafford	Reinstates requirements that gable endwalls be structurally continuous between points of lateral support. This language currently exists in the 2010 FBCB.	

Comment AS AM NAR W I

TAC Vote: 10Y-0N **Second:** Carroll

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4993	22	2214.3.3	Thomas Sputo	Delete reference to ASCE 3, an outdated standard for composite deck that was removed from the 2012 IBC, and which, as explained in Proposal 4944, will be replaced in the 2015 IBC by ANSI/SDI C-2011.	


Comment AS AM NAR W I

TAC Vote: 0Y-10N **Second:** Glenn

NAR – to correlate with the Miami-Dade and other interested parties and Mod 4927.

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5327	22	2214	Bonnie Manley	This proposal, submitted on behalf of the steel industry, builds on the changes already recommended in the FL Supplement. It coordinates Section 2214 with the base model code.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – correlation for consistency.						
5366	22	2215	Bonnie Manley	This proposal, submitted on behalf of the steel industry, updates Section 2215.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion to table all mods proposed by Bonnie Manley 5366-5471 by Glenn 2 nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2 nd Macomber 10Y-0N Motion to NAR by proponent 2 nd by Carroll 0Y-10N to allow for coordination.						
5369	22	2217	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a section reference based upon changes recommended in a proposal for Section 2214.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion to table all mods proposed by Bonnie Manley 5366-5471 by Glenn 2 nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2 nd Macomber 10Y-0N Motion to NAR by proponent 2 nd by Carroll 0Y-10N to allow for coordination.						
5379	22	2221.1	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a section reference based upon changes recommended in a proposal for Section 2214.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Motion to table all mods proposed by Bonnie Manley 5366-5471 by Glenn 2 nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2 nd Macomber 10Y-0N Motion to NAR by proponent 2 nd by Carroll 0Y-10N to allow for coordination						
5470	22	2221.6.2	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects the requirements on end support and anchorage of steel joists.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Parrino
Motion to table all mods proposed by Bonnie Manley by Glenn 2 nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2 nd Macomber 10Y-0N Motion to approve A1 as replacement for original mod Parrino 2 nd Carroll Vote 0Y-9N NAR – editorial corrections in preference for A1						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5383	22	2221.6.3	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a section reference based upon changes recommended in an alternate proposal for Section 2214.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>
5461	22	2222.1	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a section reference based upon changes recommended in an proposal for Section 2214.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>
5462	22	2222.2	Bonnie Manley	This proposal, submitted on behalf of the steel industry, recommends deletion of Section 2222.2.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>
5644	22	2222.4.4	Bonnie Manley	This proposal, submitted on behalf of the steel industry, coordinates with the Chapter 16 changes recommended in Mod. 5643 by removing a redundant requirement in Chapter 22.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Withdrawn by proponent.</p>					<p>TAC Vote: Second:</p>
5464	22	2222.4	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a reference based upon changes recommended in a proposal for Section 2214.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5466	22	2222.6.1	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a reference section based upon changes recommended in a proposal for Section 2214.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>
5469	22	2222.7	Bonnie Manley	This proposal, submitted on behalf of the steel industry, deletes a section reference based upon changes recommended in an proposal for Section 2214.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>
5471	22	2223.2	Bonnie Manley	This proposal, submitted on behalf of the steel industry, corrects a section reference based upon changes recommended in an proposal for Section 2214.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table all mods proposed by Bonnie Manley by Glenn 2nd Kim Vote 10Y-0N Motion to untable all mods proposed by Bonnie Manley by Glenn 2nd Macomber 10Y-0N NAR as requested by the proponent and for correlation</p>					<p>TAC Vote: 0Y-9N Second: Carroll</p>

23-Wood

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4945	23	2301.1	Michael Goolsby	Section Formatting	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p>					<p>TAC Vote: 10Y-0N Second: Gascon</p>

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5622	Chapter 23	Section 2304.3.4	Proponent T Stafford	Summary Reinstates requirements that gable endwalls be structurally continuous between points of lateral support. This language currently exists in the 2010 FBCB.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5671	Chapter 23	Section 2304.7.2.1	Proponent T Stafford	Summary Requires the use of ring shank nails for roof decking attachment. This language will achieve consistency between the FBCB and FBCR. The FBCR has required the roof decking to be attached with ring shank nails since the 2006 Supplement to the 2004 code.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 5Y-5Y	Second: Carroll
NAR – weakens the code and discriminatory against design.							
Mod # 5650	Chapter 23	Section 2308.2	Proponent T Stafford	Summary This proposal reinstates the limit on using conventional wood frame construction to areas where the Vult wind speed equals or exceeds 115 mph.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N	Second: Carroll
Mod # 4946	Chapter 23	Section 2325.1	Proponent Michael Goolsby	Summary Section Formatting	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N	Second: Lavrich

24-Glass and Glazing

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5025	Chapter 24	Section 2401.1	Proponent Michael Goolsby	Summary Section formatting	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N	Second: Lavrich
Mod # 5764	Chapter 24	Section 2403.1	Proponent Jim Heise	Summary Section 2403.1 Identification is revised to read as follows:	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N	Second: Glenn
Mod # 5026	Chapter 24	Section 2404.1	Proponent Michael Goolsby	Summary Section Formatting	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N	Second: Parrino
Mod # 5636	Chapter 24	Section 2404.2, 2405.5, 2405.5.1, 2405.5.2	Proponent Dwight Wilkes	Summary Reason: The overall intent of this proposal is to clarify the requirements for tubular daylighting devices, within the context of skylights and sloped glazing.	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-9N	Second: Glenn
NAR – consistency with previous action and justify Florida specific need.							
Mod # 5027	Chapter 24	Section 2404.3.1 and 2404.3.3	Proponent Michael Goolsby	Summary Section formatting	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N	Second: Gascon

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236			
Mod # 5028	Chapter 24	Section 2404.3.5	Proponent Michael Goolsby	Summary Section formatting	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N
					Second: Gascon
Mod # 5584	Chapter 24	Section 2404	Proponent Dwight Wilkes	Summary This proposal is to coordinate the glass design load equations of Chapter 24 with those of Chapter 16, to the change of design wind load model from Allowable Stress Design to Strength Design in ASCE 7-10. These revisions were not carried back to the glass design load equations of Chapter 24.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – for proponent to make corrections.					TAC Vote: 0Y-9N
					Second: Carroll
Mod # 5647	Chapter 24	Section 2404	Proponent T Stafford	Summary Correlation with ASCE 7-10. Clarifies the appropriate reduction of design pressures for protocols that are and have been historically tested using allowable or nominal wind loads.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – correlation and to correct strike thru.					TAC Vote: 0Y-9N
					Second: Glenn
Mod # 5029	Chapter 24	Section 2407.1.4.2	Proponent Michael Goolsby	Summary Section formatting	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N
					Second: Carroll

25-Gvpsum Board Plaster

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4940	25	2501.1.1	Michael Goolsby	Deletion of HVHZ sections		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4939	25	2516, 2516 and 2517	Michael Goolsby	Deletion of HVHZ sections necessary to utilize base code provisions.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5648	25	Table 2508.5	T Stafford	Clarifies that the shear values for gypsum board diaphragms are allowable (ASD) values.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn


26-Plastic

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5221	26	2603	Suzanne Davis	Removal of figure 2603.8. To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino

39-Special Construction

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236


<u>Mod #</u>	<u>Chapter</u>	<u>Section</u>	<u>Proponent</u>	<u>Summary</u>	Pending Review	
5932	39	3105	Joseph Belcher	Retains provisions for awnings and canopies.		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
5226	39	3114 Airport Noise	Suzanne Davis	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn

35-Referenced Standards

<u>Mod #</u>	<u>Chapter</u>	<u>Section</u>	<u>Proponent</u>	<u>Summary</u>	Pending Review	
5830	35	AAF	Joseph Belcher	Retains information for adopted AAF Guide.		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
6023	35	ANSI	Randall Shackelford	Fixes an error in the 2012 IBC by correcting the ASTM Standard for testing of joist hangers and connectors and allowing the option of using the newest standard for testing		
<u>Comment</u>	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Carroll
NAR – to correlate with companion changes.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
6021	35	ASTM	Joseph Belcher	Updates standards.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
5893	35	Chapter 35	Joseph Belcher	Updates AAMA/NPEA/NSA 2100—11		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
5674	35	Standards	Dwight Wilkes	As the Base Code [2012 IBC] only recognizes two [2] AAMA standards and the Florida 2010 Code has eleven [11] standards with multiple editions, this modification is bring into the 2013 Florida Building Code the existing standards in Florida and to remove outdated and include current standards.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – for proponent to clarify mod as TAC comments have suggested.						


SubCode: Existing Building

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5142	2	202	Ken Cureton	Modify SECTION 202 (Structural TAC)		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236


Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5854	2	202	Jim Heise	give clear definition of "sunroom";		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
Correct item 2 - "of" to "or" fixed glass						
5889	2	202	T Stafford	New definitions for correlation with proposed new Chapter 17.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Glenn
NAR – for staff to provide comments on needed language required by law that was withdrawn in a previous mod.						
5961	2	202	Jim Heise	brings forward the definition of sunroom		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
This mod supersedes the action on mod 5854.						

4-Prescriptive Compliance Method

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4962	4	[B]402.4	Michael Goolsby	Section formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4963	4	[B]403.4	Michael Goolsby	Section formatting	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Lavrich

With correction from IBC.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4965	4	[B]404.2.1	Michael Goolsby	Section formatting	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Lavrich

With correction from IBC.

5-Classification of Work

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5890	5	510	T Stafford	Charging language is added to provided direction to Chapter 17 for retrofits.	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Lavrich

NAR – needs corrections to situations.

6-Repairs


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5757	6	606.4	Joseph Hetzel	Continues requirements for garage door, exterior door, skylight, and operable and inoperable window replacement.	

Comment AS AM NAR W I **TAC Vote:** **Second:**

7-Alterations - Level 1

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
4966	7	[B]706.3.2	Michael Goolsby	Section formatting		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5147	7	706	Ken Cureton	Add SECTIONS 706.1.1, 706.4 and 706.5		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-1N Second: Strawn

10-Change of Occupancy

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5875	10	1007	Ken Cureton	Modify SECTION 1007.1		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5878	10	1007	Ken Cureton	Modify SECTION 1007.2		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Kim
NAR - Needs to correct citation reference from 1616.2 to 1620.1...see comments.						

11-Additions

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5869	11	1103	Ken Cureton	Modify Section 1103.2	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Glenn

NAR –reference to definition in Ch 2 needs to be correlated.

16-Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5888	16	New Chapter 17	T Stafford	Relocates the retrofit provisions in the appendix of the IEBC to new Chapter 17 for consistency with the 2010 FBCEB. This proposal also includes updates to the version in the appendix of the IEBC.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Glenn

SubCode: Mechanical

3-General Regulations

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5222	3	301.15	Ann Stanton	Repropose Florida-specific wind resistance equipment criteria.	

Comment AS AM NAR W I **TAC Vote:** 7Y-3N **Second:** Glenn


NAR – this is already addressed in the base code and not Florida specific.

SubCode: Residential

2-Definitions

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5678	2	202	T Stafford	This proposal part of a series of proposals that reinstate the ultimate wind speed maps in the FBCR. This language is currently contained in the 2010 FBCR. No new requirements are being proposed.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to table until after mod 5681 Lavrich 2nd Carroll Vote 10Y-0N Motion to untable Carroll 2nd Lavrich Vote 10Y-0N 2nd to approve as submitted Strawn Vote 10Y-0N</p>					<p>TAC Vote: Second:</p>
5793	2	202	Joseph Belcher	Retains FBC definition of sunroom.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p>					<p>TAC Vote: 10Y-0N Second: Carroll</p>

3-Building Planning

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5822	3	308.1	Jim Heise	Identification to maintain that laminated glass, when used for other than safety glazing, be permanently identified	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p>					<p>TAC Vote: 10Y-0N Second: Strawn</p>
5651	3	R301.1.1	Dwight Wilkes	To recognize the standard for aluminum design as an alternative provision and provide the current edition AAMA 2100-10 . American Architectural Manufacturers Association (AAMA) National Patio Enclosure Association (NPEA) & National Sunroom Association (NSA) 2100 – Specification for Sunrooms.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>NAR – based on proponents requests to include additional language.</p>					<p>TAC Vote: 0Y-10N Second: Lavrich</p>

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5790	3	R301.2.1.1.1	Joseph Belcher	Brings forward language adopting AAF Guide to Aluminum Constructicon in High Wind Areas; Adds language pemitting design per FBCB.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N Second: Kim
5791	3	R301.2.1.1.2	Joseph Belcher	Carries forward adoption of AAMA 2100; Carries forward and updates sunroom categories.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Glenn
5998	3	R301.2.1.1	Joseph Belcher	Retains MAF Guide to Concrete Masonry Residential Construction in High Wind Areas; Retains reference to prescriptive provisions of Chapter 6 for concrete masonry construction; Adds TMS 402/ACI 530/ASCE 5 and TMS 602/ACI 530.1/ASCE 6 as design option.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Note comments to include Florida Building Code, "Building".					TAC Vote: 9Y-0N Second: Parrino
5721	3	R301.2.1.2.1	Joseph Belcher	Modifies ASTM E 1996 Wind Zone definitions to correlate with wind speeds of ASCE 7-10 and FBCR.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – for the purpose of negative roll call at proponents request which has no table.					TAC Vote: 0Y-9N Second: Glenn
5663	3	R301.2.1.2	Dwight Wilkes	To recognize the standard editions for AAMA 506-06 or 08 or 11 Voluntary Specifications for Impact and Cycle Testing of Fenestration Products.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Figure # to be corrected. As submitted references a figure that does not exist. Should reference R301.2.(4)c.					TAC Vote: 9Y-1N Second: Strawn

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5718	3	R301.2.1.2	Joseph Belcher	Modifies opening protection to bring forward currently permitted standards.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Glenn

The action on this mod supersedes the action on previous mod 5663

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5694	3	R301.2.1.4	T Stafford	The proposal reinstates the surface roughness and exposure category definitions from the 2010 FBCR.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Strawn

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5700	3	R301.2.1.6	T Stafford	Correlation with ASCE 7-10.	

Comment AS AM NAR W I **TAC Vote:** **Second:**

Motion to table Parrino 2nd Strawn Vote 10Y-0N
Motion to untable Lavrich 2nd Parrino Vote 10Y-0N
2nd to approve as submitted Macomber Vote 10Y-0N

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5328	3	R301.2.1	Joseph Hetzel	Inclusion of a garage door wind load Table.	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Glenn

NAR – proponent requests NAR based on action taken on 5321.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5681	3	R301.2.1	T Stafford	This proposal part of a series of proposals that reinstate the ultimate wind speed maps in the FBCR. This language is currently contained in the 2010 FBCR. No new requirements are being proposed.	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Lavrich

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236			
Mod # 5743	Chapter 3	Section R301.9	Proponent Joseph Belcher	Summary Relocates existing wall covering and soffit design criteria from R617.4 to R301.9; adds reference to C&C load tables.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Glenn
Mod # 5745	Chapter 3	Section R301.9	Proponent Joseph Belcher	Summary Relocates existing wall covering and soffit design criteria from R617.4 to R301.9; adds reference to C&C load tables.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote:
					Second:
Mod # 5416	Chapter 3	Section R318.7	Proponent Jack Glenn	Summary Reformat the Termite Inspection requirements by moving section R704 to a new Section R381.7	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Carroll
Mod # 5432	Chapter 3	Section SECTION R301 - DESIGN CRITERIA	Proponent Ken Cureton	Summary Modify SECTION R301.2.1.2	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Kim
Mod # 5430	Chapter 3	Section SECTION R301-DESIGN CRITERIA	Proponent Ken Cureton	Summary Modify SECTION R301	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N
					Second: Glenn

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Building Codes and Standards

Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5441	3	SECTION R324 - AIRPORT NOISE	Ken Cureton	Add SECTION R324		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Kim
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5702	3	Table R301.2(2)	T Stafford	Correlation with ASCE 7-10. Reinstates the component and cladding load table from the 2010 FBCR.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Strawn
Hand written notes to be added by proponent.						


4-Foundations

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5626	4	R401.1	Michael Goolsby	Section formatting		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5780	4	R401.2	T Stafford	This proposal reinstates the foundation requirements from the 2010 FBCR.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn

5-Floors

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236


Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5627	5	R501.1	Michael Goolsby	Section formatting		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5984	5	R502	T Stafford	Deletes the prescriptive wood framing construction provisions that do not apply to high wind areas.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
6000	5	R505	T Stafford	Deletes the prescriptive steel framing construction provisions that do not apply to high wind areas.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich

6-Wall Construction

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5950	6	606.16	Jim Heise	Masonry opening tolerances		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5960	Chapter 6	Section 612.12.2	Proponent Jim Heise	Summary maximum sealant joints for Masonry Rough Openings	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Lavrich
Mod # 5956	Chapter 6	Section 612.12	Proponent Jim Heise	Summary Flashing, sealants and weatherstripping	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Macomber
Mod # 5769	Chapter 6	Section 612.1	Proponent Jim Heise	Summary Exterior window and door flashing	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Glenn
NAR – at the request of proponent to correct language.							
Mod # 5953	Chapter 6	Section 612.2	Proponent Jim Heise	Summary performance criteria for windows and doors	Pending Review		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Strawn
NAR - Proponent to correct word "designed" to "design".							
Mod # 4972	Chapter 6	Section R601.1	Proponent Michael Goolsby	Summary Reinstate a code section erroneously removed	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Carroll

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC:		236			
Mod # 5986	Chapter 6	Section R602	Proponent T Stafford	Summary Deletes the prescriptive wood framing construction provisions for wall framing that do not apply to high wind areas.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 6001	Chapter 6	Section R603	Proponent T Stafford	Summary Deletes the prescriptive steel framing construction provisions that do not apply to high wind areas.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 6017	Chapter 6	Section R606; R614	Proponent Joseph Belcher	Summary Adds prescriptive provisions suitable for Florida's wind loads as contained in previous editions of the FBCR for concrete masonry construction.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5701	Chapter 6	Section R612.2	Proponent T Stafford	Summary Correlation with ASCE 7-10.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second: 10Y-0N
Mod # 5329	Chapter 6	Section R612.3, R202	Proponent Joseph Hetzel	Summary Inclusion of garage door labeling requirements.	Pending Review		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural


Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236					
Mod # 5670	Chapter 6	Section R612.3.1	Proponent Dwight Wilkes	Summary To reinstate the exterior windows and doors structural performance, testing, standards, label requirements and comparative analysis with Proposed changes to the 2012 IRC as submitted under S173-12 and Public Comment to S172.			Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Glenn
NAR - at the request of proponent – duplicative.							
Mod # 5334	Chapter 6	Section R612.4	Proponent Joseph Hetzel	Summary Inclusion of garage door test requirements.			Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Strawn
Mod # 5657	Chapter 6	Section R612.6	Proponent Janet Gerard	Summary Provides clarification of the term product approval			Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N	Second: Strawn
NAR – at the request of the proponent. Duplication							
Mod # 5722	Chapter 6	Section R612.8.4.1	Proponent Joseph Belcher	Summary Retains provisions for interchangeability of door components and adopted ANSI Standard for side-hinged exterior steel doors.			Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn
Mod # 5723	Chapter 6	Section R614	Proponent Joseph Belcher	Summary Adds labeling and installation provisions for impact-resistant coverings.			Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N	Second: Glenn

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review


TAC: Structural **Total Mods for this TAC:** 236

7-Wall Covering

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5709	7	703.3.3, 703.3.4	T Stafford	This proposal references the WFCM for attachment of wood, hardboard, and wood structural panel siding.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N Second: Lavrich
5750	7	703.8	Jim Heise	This mod adds the standards from R612.12.1 that are referenced in the 2010 FBC. This is also to maintain the FMA/AAMA 100, FMA/AAMA 200, FMA/WDMA 250 in the 2013 FBC as previously in the 2010 FBC	
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Motion to accept as amended with G2 comments Macomber standing on proponents rationale. Parrino					TAC Vote: 10Y-0N Second: Glenn
5629	7	R701.1	Michael Goolsby	Section formatting	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote: Second:
5704	7	R703.1.3	T Stafford	Clarifies the applicable loads on soffits.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N Second: Carroll

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC:		236	
Mod # 5947	Chapter 7	Section R703.11.2	Proponent T Stafford	Summary Clarifies the application limits of vinyl siding over foam plastic sheathing.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Macomber
Mod # 5705	Chapter 7	Section R703.4	Proponent T Stafford	Summary Clarifies the limits of the prescriptive fastening table for wall coverings.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Carroll
Mod # 5710	Chapter 7	Section R703.5.3	Proponent T Stafford	Summary This proposal establishes limits for prescriptive attachment of wood shakes and shingles wall coverings.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Carroll
Mod # 5711	Chapter 7	Section R703.7	Proponent T Stafford	Summary This proposal establishes limits for prescriptive attachment of masonry veneers.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Glenn
Mod # 5706	Chapter 7	Section Table R703.4	Proponent T Stafford	Summary Modifies the prescriptive fastening table for wall coverings to be consistent with the 2010 FBCR. Removes table entries that permit the use of staples.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Glenn

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

8-Roof-Ceiling Construction

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5630	8	R801.1	Michael Goolsby	Section formatting		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5673	8	R802.3.1	T Stafford	Requires the use of ring shank nails for roof decking attachment. This language is currently contained in the 2010 FBCR. No new requirements are being proposed.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Lavrich
5989	8	R802	T Stafford	Deletes the prescriptive wood framing construction provisions for roof framing that do not apply to high wind areas.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
6003	8	R804	T Stafford	Deletes the prescriptive steel framing construction provisions that do not apply to high wind areas.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Macomber

21-Hydronic Piping

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4979	21	2101.6	Michael Goolsby	Section formatting	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Lavrich

NAR – requested by proponent based on previous action of the TAC.

26-General Plumbing Requirements

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4984	26	2603.2	Michael Goolsby	Section formatting	

Comment AS AM NAR W I **TAC Vote:** 0Y-10N **Second:** Lavrich

NAR – requested by proponent based on previous action of the TAC

44-HVHZ

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5850	44	4403.11.2	Joseph Belcher	Modifies sunroom categories to adopt those of AAMA 2100-11	

Comment AS AM NAR W I **TAC Vote:** **Second:** Lavrich

Motion to approve the A2 by Lavrich 2nd Carroll Vote –
Withdrawn
2nd Glenn - Motion to approve the mod with the A2 comment Vote 10Y-0N


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5010	44	4403	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Kim

Glenn motion to correct spelling of "Florida". 2nd Gascon Vote 10Y-0N

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

<u>Mod #</u>	<u>Chapter</u>	<u>Section</u>	<u>Proponent</u>	<u>Summary</u>	Pending Review	
5011	44	4404	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll
5012	44	4405	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5013	44	4406	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5014	44	4407	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
5015	44	4408	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions		
<u>Comment</u>	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236			
Mod # 5016	Chapter 44	Section 4409	Proponent Michael Goolsby	Summary Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod # 5017	Chapter 44	Section 4410	Proponent Michael Goolsby	Summary Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod # 5018	Chapter 44	Section 4411	Proponent Michael Goolsby	Summary Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod # 5617	Chapter 44	Section R4408	Proponent Bonnie Manley	Summary This proposal, submitted on behalf of the steel industry, recommends the deletion of Section R4408 in favor of a direct reference to the HVHZ provisions in FBC Chapter 22.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Kim
NAR – duplicative.					

45-Referenced Standards

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural		Total Mods for this TAC: 236				
Mod # 6019	Chapter 45	Section ASTM	Proponent Joseph Belcher	Summary Updates standards.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod # 6018	Chapter 45	Section Chapte 45	Proponent Joseph Belcher	Summary Retains the prescriptive guide for small one story residential structures published by the Masonry Association of Florida.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Parrino
Mod # 5840	Chapter 45	Section Chapter 44 AAF	Proponent Joseph Belcher	Summary Retains information for adoption of AAF Guide.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Carroll
Mod # 5895	Chapter 45	Section Chapter 45	Proponent Joseph Belcher	Summary Updates AAMA/NPEA/NSA 2100—11	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Kim
Mod # 5891	Chapter 45	Section FMA	Proponent Janet Gerard	Summary Adds standard practiced for installation flashing and sealing of windows and doors installed in wood frame and masonry construction where extreme wind/water conditions exist	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Strawn

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5659	45	Standards	Dwight Wilkes	To recognize the standard for aluminum design as an alternative provision and provide the current edition AAMA 2100-10 . American Architectural Manufacturers Association (AAMA) National Patio Enclosure Association (NPEA) & National Sunroom Association (NSA) 2100 – Specification for Sunrooms.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-10N Second: Lavrich
NAR – requested by proponent to correct and correlate with previous mod.						

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5664	45	Standards	Dwight Wilkes	To recognize the standard editions for AAMA 506-06 or 08 or 11 Voluntary Specifications for Impact and Cycle Testing of Fenestration Products.		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Glenn
2 nd to approve A1 instead of original mod. Glenn						

SubCode: Building

16-Structural Design

Mod #	Chapter	Section	Proponent	Summary	Withdrawn	
5122	16	1609.1.2 Protection of Openings	Suzanne Davis	Revised to add items 3 and 4 and to be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent						

19-Concrete

Mod #	Chapter	Section	Proponent	Summary	Withdrawn	
5216	19	1913	Suzanne Davis	Sections 1913.3.1 and 1913.3.2. To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

21-Masonry

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Structural

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Structural **Total Mods for this TAC:** 236

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5217	21	2115	Suzanne Davis	Sections 2115.1-2115.1.2 To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I</p> <p style="text-align: right;">TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					

22-Steel

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5218	22	2212	Suzanne Davis	Sections 2212.1 and 2212.2. To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I</p> <p style="text-align: right;">TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					

23-Wood

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5219	23	2304	Suzanne Davis	Sections 2304.3.4.1, 2304.3.4.2, 2304.3.4.3. To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I</p> <p style="text-align: right;">TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					

Search Criteria

Modification #:	ALL	Code Version:	2013
Code Change Cycle:	ALL	Sub Code:	ALL
Chapter & Topic:	ALL	Section:	ALL
Date Submitted From:	ALL	Date Submitted To:	ALL
TAC:	S	TAC Recommendation:	ALL
Commission Action:	ALL	Proponent Last Name:	ALL
Proponent First Name:	ALL	Text of Modification:	ALL
Related Modifications:	ALL	Affects HVHZ:	ALL

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)