



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

Code Change Cycle: 2013 Triennial Original Modification 7/1/2012 - 8/2/2012

TAC: Swimming Pool

Total Mods for this TAC: 38

SubCode: Building

4-Special Detailed Requirements Based on Use and

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5808	4	454.1.2.1 Pool Structure	Alex Fletcher	Remove the requirement that the contractor provide written certification that the adhesive have a tested shear strength of at least 250 psi.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 11Y-0N					Second: Greiner
5810	4	454.1.2.2.3.1 Floor slope shall be uniform	Alex Fletcher	Reduce the minimum slope from one unit vertical in 40 units horizontal to one unit vertical in 60 units horizontal.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 11Y-0N					Second: Allen
5812	4	454.1.3.1.6	Alex Fletcher	Increase the amount of deck along the pool perimeter that can be obstructed from ten to twenty percent.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – to provide the proponent an opportunity to submit some technical changes.					
TAC Vote: 0Y-11N					Second: Greiner
5815	4	454.1.3.1.9	Alex Fletcher	Eliminate the need for redundant gates at doored access points from public rooms such as lobbies or club houses.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
NAR – latch height requirements.					
TAC Vote: 0Y-11N					Second: Allen

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5819	4	454.1.3.2 Bridges and overhead obstructions	Alex Fletcher	Change the minimum height of a bridge or obstruction from 8 feet to 7 feet.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 7Y-4N Second: Dumbaugh
NAR – No Florida specific need.						
5816	4	454.1.4.2.3 Underwater lighting	Alex Fletcher	Remove the abiguity of trying to convince each different department that the pool illumination of alternative lighting systems is equal to the requirements.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Greiner
NAR – provide opportunity for proponent to make technical revisions.						
5817	4	454.1.6.2 Rinse Shower	Alex Fletcher	Eliminate the requirement for how far a rinse shower must be from the pool.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Allen
NAR – for proponent to provide technical corrections.						
5821	4	454.1.6.5.14 Heaters	Alex Fletcher	Removes the ambiguity of having each different jurisdiction approve standards that are already nationally recognized.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Allen
NAR – in favor of Mod 5744.						
5823	4	454.1.6.5.16.2 Hypophalogenetic on and electrolytic	Alex Fletcher	States that supplemental use of Electrlytic Chlorine Generators shall not be considered modifications.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Allen
NAR – for proponent to provide technical corrections.						

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5828	4	454.1.6.5.16.6	Alex Fletcher	Eliminates the need to supply a certificate of performance to each jurisdiction and allows for equipment to comply with later editions of the USEPA Ultraviolet Disinfection Guidance Manual.	

Comment AS AM NAR W I **TAC Vote:** 0Y-11N **Second:** Allen

NAR – due to issues with reference dates and preference to mod 5744. Needs clarification of reference ‘to the Department’.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5818	4	454.1.6.5.3.1 Perimeter overflow gutters	Alex Fletcher	Reduce the abiguity of having each different jurisdiction approve the handhold design. It is too subjective.	

Comment AS AM NAR W I **TAC Vote:** 0Y-11N **Second:** O’Connor

NAR – in preference to mod 5744 and clarification of reference ‘to the Department’.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5846	4	454.1.7.2 Depths	Alex Fletcher	Adds the word depth	

Comment AS AM NAR W I **TAC Vote:** 11Y-0N **Second:** Allen

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5852	4	454.1.9.2.1.3.1	Alex Fletcher	Reduce the ambiguity of trying to justify to each jurisdiction that riders will be adequatly slowed before reaching the receiving pool.	

Comment AS AM NAR W I **TAC Vote:** 0Y-11N **Second:** Greiner


NAR – in preference of mod 5744.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5856	4	454.1.9.3.1	Alex Fletcher	Reduce unnecessary wording.	

Comment AS AM NAR W I **TAC Vote:** 11Y-0N **Second:** Dumbar

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5859	4	454.1.9.5.4	Alex Fletcher	Eliminate "to the department's satisfaction"		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Greiner
NAR – with preference to mod 5744.						
5861	4	454.1.9.8.1	Alex Fletcher	Change the collector tank size from 2 to 3 minutes of retention of the combined flow to match 64E-9		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Allen
NAR – in preference to mod 5744.						
5863	4	454.1.9.8.2	Alex Fletcher	Removes the requirement for an automatic skimmer in a collector tank for an Interactive Water Feature		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 11Y-0N Second: O'Connor
5866	4	454.1.9.8.3	Alex Fletcher	Returns the treated water to the pressure side of the recirculation system.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 11Y-0N Second: Dumbaugh
5867	4	454.1.9.8.6.1	Alex Fletcher	Returns treated water to the collector tank for longer contact time.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-1N Second: Allen

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review


TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5744	4	454.1	Bob Vincent	Proposed revisions will make the two FL public pool codes identical (FBC454.1 & Ch. 64E-9, FAC). These exist in rule 64E-9, but not currently in 454.1. So a public pool permitted-constructed legally under FBC could be denied an operating permit by FDOH		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Allen
Staff to correct grammatical errors in 454.1.6.5.16.4.4 NAR – to clean up reference to specific standards and language issues as discussed by TAC.						
5847	4	454.1	Bob Vincent	Alerts pool permit applicants that a DOH operation permit is also required to open a public pool. Requires the jurisdictional Building Official to alert the DOH County Health Department of permit issuance and clearance of pools and bathing places.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 3Y-8N Second: O'Connor
NAR – issues regarding enforceability and Florida specific need.						
5317	4	454.2	Joe Bigelow	To implement Florida statutes 515 and to carry forward the Commission's work group on this subject.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 5Y-6N Second: Allen
NAR – in support of mod 5831 and others proposed by BOAF.						
5831	4	454	BOAF CDC	Revise Section 454 FBCB to reference International Swimming Pool and Spa Code (ISPSC) for pool & spa construction		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Greiner
NAR – for proponent to address Florida specific needs.						

35-Referenced Standards

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5872	35	APSP	Jennifer Hatfield	Provides latest revisions to pool and spa standards.	

Comment AS AM NAR W I

TAC Vote: 0Y-11N **Second:** Allen

NAR – there are references to past dated standards that need to be addressed.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5839	35	Reference Standard	BOAF CDC	Add reference standard in ch 35 FBCB International Swimming Pool and Spa Code (ISPSC)	

Comment AS AM NAR W I

TAC Vote: 0Y-11N **Second:** Allen

NAR – to allow for consistency with TAC actions.

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5227	35	Referenced Standards	Suzanne Davis	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	

Comment AS AM NAR W I

TAC Vote: 0Y-11N **Second:** Allen

NAR – to allow for consistency with other TAC actions.

SubCode: Energy Conservation

4-[RE] - Residential Energy Efficiency

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5045	4	R403.9	Ann Stanton	Move swimming pool criteria from 2010 code forward into the 2013 code.	


Comment AS AM NAR W I

TAC Vote: 0Y-11N **Second:** Allen

NAR – to allow time for the standards to complete development.

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5814	4	R403.9	Representing FL Swimming Pool Assoc	Moves swimming pool and spa criteria from 2010 code, with exception of APSP-15 reference, forward into the 2013 code.	

Comment AS AM NAR W I

TAC Vote: 0Y-11N

Second: Allen

NAR – to allow time for the standards to complete development.

5-IRE1 - Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Pending Review
6004	5	R-All	Ann Stanton	Update standards list to reflect Florida specific references.	

Comment AS AM NAR W I

TAC Vote: 0Y-11Y

Second: Allen

NAR – to allow all referenced standards list to be completed prior to adoption.

SubCode: Residential

42-Swimming Pools

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5841	42	4201 Swimming Pools	BOAF CDC	The ICC codes are the base code for Florida, there is now an International Swimming Pool and Spa Code (ISPSC) and that should be the base code for Florida.	

Comment AS AM NAR W I

TAC Vote: 1Y-10N

Second: Allen

NAR – to allow for time to complete a Florida supplement if the TAC chooses to move that direction.

45-Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5874	45	APSP	Jennifer Hatfield	Provides latest editions of pool and spa standards.	

Comment AS AM NAR W I

TAC Vote: 0Y-11N

Second: Clarkson

NAR – depending on other actions of the TAC.

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5444	45	CHAPTER 45 – REFERENCED STANDARDS	Ken Cureton	Modify CHAPTER 45		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Allen
NAR – deferring until action on other mods by the TAC.						
5443	45	CHAPTER 45 - SWIMMING POOLS	Ken Cureton	Add CHAPTER 45 - SWIMMING POOLS , SECTIONS R4501.1 through R4501.23		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: Dumbaugh
NAR – deferring until action on other mods by the TAC.						
<small>**Note - This Chapter is being added which replaces the existing Chapter 45 and modifies subsequent Chapter numbers**</small>						
5842	45	Referenced Standards	BOAF CDC	The ICC codes are the base code for Florida, there is now an International Swimming Pool and Spa Code (ISPSC) and that should be the base code for Florida.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-11N Second: O'Connor
NAR – deferring until action on other mods by the TAC.						

SubCode: Building

4-Special Detailed Requirements Based on Use and

Mod #	Chapter	Section	Proponent	Summary	Withdrawn	
5579	4	454 Swimming Pools and Bathing Places	Thomas Allen	utilize the International Swimming Pool and Spa Code (ISPSC) for all swimming Pool and Spa construction.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						

35-Referenced Standards

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Swimming Pool

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Swimming Pool **Total Mods for this TAC:** 38

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5580	35	ICC Referenced Standards	Thomas Allen	utilize the International Swimming Pool and Spa Code (ISPSC) for all swimming Pool and Spa construction.	Withdrawn
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					

SubCode: Residential

42-Swimming Pools

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5581	42	4201 Scope	Thomas Allen	utilize the International Swimming Pool and Spa Code (ISPSC) for all swimming Pool and Spa construction.	Withdrawn
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					

45-Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5583	45	ICC Referenced Standards	Thomas Allen	utilize the International Swimming Pool and Spa Code (ISPSC) for all swimming Pool and Spa construction.	Withdrawn
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Withdrawn by proponent.</p>					

Search Criteria

Modification #:	ALL	Code Version:	2013
Code Change Cycle:	ALL	Sub Code:	ALL
Chapter & Topic:	ALL	Section:	ALL
Date Submitted From:	ALL	Date Submitted To:	ALL
TAC:	SW	TAC Recommendation:	ALL
Commission Action:	ALL	Proponent Last Name:	ALL
Proponent First Name:	ALL	Text of Modification:	ALL
Related Modifications:	ALL	Affects HVHZ:	ALL

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)