

# Memo

**To:** Mo Madani, DBPR  
**From:** Joe Belcher, JDBCS  
**Date:** January 25, 2023  
**Re:** Alternate Language Mods S10388 and S10120

---

Mr. Madani,

Please accept the following as alternate language to the Mods.

## **S10388-R1**

### **Accessory Structure – No Change.**

**202 Sun Control Structure.** An independently supported accessory structure consisting of columns or posts supporting an open roof of girders, beams, or cross rafters with or without fixed or operational louvers serving to direct sunlight. ~~Sun Control Structures attached to and depending on a building for support are considered the same occupancy class as the supporting building.~~

**RATIONALE:** Structural TAC members requested the changes in the Florida Building Code-Building and Residential. I neglected to make the changes in the Florida Building Code-Building. The change to the Florida Building Code-Residential was approved. Approval of this change will bring the two volumes into agreement. The alternate language proposed is to make the correction.

## **S10120-R1**

**1703.6.2.1 Concrete Testing Reports.** Where this code, a referenced standard, a building official or inspection agency requires testing of concrete on a project, test reports shall be provided to the building official or inspection agency, the registered design professional of record, and the material supplier concurrent ~~with~~ when reporting results to the client.

**RATIONALE:** The change is to correct a grammatical error.