



**FLORIDA SOLAR ENERGY CENTER**

*Creating Energy Independence Since 1975*

# **Developing Exhaust Air Energy Recovery Credits for the Florida Energy Code**

Interim Report

Bereket Nigusse / Muthusamy Swami



# Contract Overview

- Start date: Nov 3, 2014
- End date: June 1, 2015
- Deliverables:
  - Interim Report: delivered
  - Final Report
- Status: in progress



# Task Summary

- Identify Major Florida Cities
- Identify Prototype Buildings
- Computer Simulations
- Update ERV Credits
- Write Final Reports



# Climate Zones and Cities

- Identified six cities in climate zone 1A and 2A
- Miami for Climate Zone 1A and Five Cities for climate zone 2A (Tampa, Orlando, Jacksonville, Gainesville, and Tallahassee)
- Simulations to determine annual energy use for the climate zone 2A cities for each of the nine prototype buildings identified
- Jacksonville and Gainesville has annual energy use within 1.0%.
- Decided to keep the six cities for this study



# Prototype Buildings

## Identified Commercial Buildings:

- Small Size Office
- Medium Size Office
- Large Office
- Standalone Retail
- Primary School
- Secondary School
- Large Hospital
- Small Size Hotel
- Large Size Hotel



# Computer Simulations


- Modified prototype buildings
- Created HVAC systems with and without ERV
- Performed sizing calculations
- Obtained effectiveness and pressure drop data (AHRI certified database)
- Created automated input file processor tool
- Simulations for large office building
- Analyzed results & reviewed assumptions



# Computer Simulations

## ERV Input Assumptions:

- Pressure Drop Across ERV Device
- Heating and Cooling Effectiveness
- Power Input for Control and Drive Motor



# Computer Simulations

Fan Pressure Adjustment Due to ERV Device:

- ☐ 2014 Florida Energy Code

- Section C403.2.10 allows fan pressure adjustment for ERV in the reference building

- ☐ Two sets of simulations were conducted


- With and without fan pressure drop adjustment to the reference buildings
- The reference building fan pressure difference is adjustment per the standard





# Preliminary Results

Total energy use and energy savings intensities of the large office building without fan pressure adjustment.




The *reference building total energy use* is the sum of *total energy use with ERV* and *total energy savings* of the building.



# Preliminary Results

Total energy use and energy savings intensity of the large office building with fan pressure adjustment.



The *reference building total energy use* is the sum of *total energy use with ERV* and *total energy savings* of the building.



# Preliminary Results

HVAC energy intensity and percent savings for the large office building.

	Units	Miami	Tampa	Orlando	Gainesville	Jacksonville	Tallahassee
Without Fan Pressure Adjustment	kBtu/ft <sup>2</sup> /yr	1.7	1.5	1.3	1.0	1.0	0.9
	%	<b>10.1</b>	<b>10.1</b>	<b>9.5</b>	<b>7.9</b>	<b>7.6</b>	<b>6.9</b>
With Fan Pressure Adjustment	kBtu/ft <sup>2</sup> /yr	2.4	2.1	1.9	1.6	1.5	1.4
	%	<b>13.6</b>	<b>13.8</b>	<b>13.3</b>	<b>11.7</b>	<b>11.3</b>	<b>10.7</b>

HVAC energy percent savings calculation

$$HVACEnergySavings = 100 \frac{HVACEnergyUse_{withoutERV} - HVACEnergyUse_{withERV}}{HVACEnergyUse_{withoutERV}}$$

- Percent HVAC energy savings will be used in the Florida code.



# ERV Credits

- ERV Credits Definition: annual cooling and heating energy savings in percent.
- Annual energy savings due to ERV device installation is estimated as the ERV credit times the annual cooling and heating energy consumption of the reference building.
- The reference building annual cooling and heating energy use is the electric and gas energy consumed to provide cooling and heating including the fan electric energy use.
- $HVACEnergySavings = ERVCredit \times HVACEnergyUse_{ReferenceBuildingWithoutERV}$



Thank you  
Questions?

