

**Petition for Declaratory Statement
Before the Florida Building Commission
December 29, 2015**

Company: Stan Weaver & Company
Address: 4607 North Cortez Avenue
Tampa, FL 33614
Name: David A John, P.E.
Title: Sales Engineer
Telephone: 813 879-0383
Facsimile: 813 879-2932
Email: djohn@stanweaver.com

DS 2015-154

Statute(s), Agency Order(s) and/or Code Section(s) on which this Declaratory Statement is sought:

C403.2.6 Energy recovery ventilation systems. Where the supply airflow rate of a fan system exceeds the values specified in Table C403.2.6, the system shall include an energy recovery system. The energy recovery system shall have the capability to provide a change in the enthalpy of the outdoor air supply of not less than 50 percent of the difference between the outdoor air and return air enthalpies, at design conditions. Where an air economizer is required, the energy recovery system shall include a bypass or controls which permit operation of the economizer as required by Section C403.4.

Exception: An energy recovery ventilation system shall not be required in any of the following conditions:

7. Systems requiring dehumidification that employ energy recovery in series with the cooling coil.

The intent of this petition is to clarify that a wrap-around heat pipe meets the exception C403.2.6.7.

Background

Stan Weaver & Company is a manufacturer's representative of air distribution products for central Florida. One of the manufacturers they represent is Heat Pipe Technology (HPT) who manufactures heat pipes that are used in air handler units as an energy savings device.

Having heat pipe included as an exception in C403.2.6 Energy recovery ventilation systems is a major point of emphasis with Florida engineers and owners. It allows engineers to design HVAC systems, include a heat pipe, and not have to provide an additional energy recovery system. It saves the building owner the expense of two heat recovery systems. Heat pipes are a proven technology and have been successfully operating in projects around the world for many years.

History of HPT Heat Pipe Technology


HPT was founded in 1983 with a grant from the Department of Energy for a project to begin research on new uses for heat pipe technology. Heat pipes are passive-heat-transfer devices that were previously used in various applications ranging from orbiting satellites to the Alaskan Pipeline ground spikes. By applying the principle of heat pipes to air conditioning systems, efficiency was greatly enhanced in both dehumidification performance and energy utilization, with moisture removal increased by 30 to 50%.

Additional research and development followed to determine how to lower fabrication costs. This task was performed by HPT under a three-year, \$500,000 contract with NASA's Kennedy Space Center. The outcome of that effort was a new generation of heat pipe technology, costing one third the price of the existing aerospace heat pipes, while still offering the same level of performance.

This revolution shattered the price barrier that restricted the widespread commercial implementation of heat pipes, and it yielded a rapid return on investment for building owners, often in as little as a year. Projects soon proved the technology could be applied on virtually any scale, while being commercially viable and practical to implement.

Wrap-Around Heat Pipe – Dehumidification Device

Heat pipes can be used in series with a cooling coil as a means of dehumidifying the outside air before it enters the cooling coil. The heat is then “wrapped around” the cooling coil and transferred downstream to re-heat the air as shown in the diagrams below. A heat pipe is a closed circuit device without the requirement of any power source. Thus the heat pipe can transfer energy with the only energy loss being the relatively small pressure drop across the heat pipe coil and corresponding fan energy requirement.



An example of the energy savings of a wrap-around heat pipe is shown on the below psychrometric chart. The enthalpy savings (Btu per Pound of Dry Air) is represented below and shown as both Precool and Reheat.

Total energy savings from pre-cooling and re-heat can be expressed as:


$$h_t = 4.5 q dh$$

where

h_t = total energy savings (Btu/hr)

q = air volume flow (cfm, cubic feet per minute)

dh = enthalpy difference from Precool/re-heat (btu/lb dry air)



A selection and payback analysis for a current design under consideration

A school in central Florida is being evaluated requiring:

- 100% OA unit with constant 20,000 CFM
- 52 F off the cooling coil
- no more than 65 F supplied after reheat
- supplemental reheat is via hot water

Assumptions:

- Chiller has efficiency of 20 EER (or 0.600 kW/ton)
- utility rate is \$0.10/kWh
- hot water costs \$1/therm (therm = 100,000 Btu's)
- AHU fan is 70% efficient and motor is 90% efficient
- Temperatures and hours based on Tampa bin data for one year
- AHU operates 24/7/365

At the first/uppermost bin (where OA is between 90 F and 95 F)...

Cooling Savings = Tons removed X Chiller's kW/ton X Tampa's cooling hours X Utility Rate
= 22 tons x 0.600 kW/ton x 157 Hours x \$0.10/kWh = \$209

Heating Savings = Free Reheat X Utility Rate ... Free Reheat = 265,746 BTUH = 2.66 Therms/hour
= 2.66 Therms/hour X \$1/Therm X 157 Hours = \$417

Fan Penalty = (Airflow X Total Static Pressure X Utility Rate X Hours) / (Constant X Fan & Motor Efficiencies)
= (20,000 CFM X 0.37" X \$0.10/kWh X 157 hours) / (8,522 X 0.7 X 0.9) = \$22

NET Savings (for 90F-95F bin) = \$209 + \$417 - \$22 = \$604

Then calculate for each bin and sum to get NET Annual Savings = **\$16,965***

* See attached Bin Analysis for breakdown.

If this standard 2-row DHP is budgeted for \$25,000 and annual savings are \$16,965...

Payback is less than a year and a half

Question: If an air handling unit is provided with a wrap-around heat pipe (for dehumidification), is it acceptable to not provide an Energy Recovery Ventilation System per paragraph C403.2.6.7?

Summary:

Petitioner respectfully believes the answer to the question outlined above is yes, if a wrap-around heat pipe coil is used, it is acceptable to not provide an Energy Recovery Ventilation System per paragraph C403.2. A wrap-around heat pipe is commonly viewed as a dehumidification device that employs energy recovery in series with the cooling coil. Many Florida engineers are already implementing wrap-around heat pipes as an exception in compliance with C403.2.6.7. We are seeking clarification on this matter.

Wrap-around heat pipes have been successfully applied as an energy savings dehumidification device for many years. Heat pipes are passive-heat-transfer devices requiring minimum maintenance and service. The typical payback to the building operator is generally 1 to 3 years. If heat pipe is supplied on a project, the building operator should not be penalized and have to provide a second energy recovery device.

A handwritten signature in black ink, appearing to read "David A. John", followed by a horizontal line.

David A John, P.E.
December 29, 2015



Project Name: DHP Payback for School
 Prepared For:
 Prepared By: Drew Elsberry (hpt-drew)
 Heat Pipe Technology
 Date: 12/28/2015 2:18 PM
 HPT Project: 47593


Qty:	Model:	Tag:	AHU Tag:	Order Code:
1	DHP	DHP	AHU	DU-AMG-20212A-07500-08500-1200X-XXX

Air Properties

Air Type: Standard

Elevation: 0ft

	Outside Air	Returned Air	Mixed Air (Standard)	Precool Leaving	Reheat Entering	Reheat Leaving
CFM	20,000		20,000			
DBT (°F)	95.00		95.00	82.05	52.00	65.16
WBT (°F)	77.99		77.99	74.63	52.00	57.33
RH(%)	47.3		47.3	71.2	100.0	62.4



Coil Performance

Pressure Drop (in. H2O)	0.19	0.18	
Face Velocity (SFPM)	451.80	451.80	
Temperature Gain/Loss(°F)	13.00	13.20	
Sensible Effectiveness	30.13	30.60	
Heat Transferred (BTU/h)	288,539	1,507,106	288,539
Condensation (lbs/hr)	0.0	772.9	

Coil Design

Fin Height (in.)	75.00	75.00
Fin Length (in.)	85.00	85.00
Face Area (SF)	44.27	44.27
No. of Rows	2	2
Tube OD (in.)	1/2	1/2
Fins per inch	12	12
Fin Type	Standard	Standard
Fin Material	Aluminum	Aluminum
Refrigerant:	R410a	



Project Name: DHP Payback for School
 Prepared For:
 Prepared By: Drew Elsberry (hpt-drew)
 Heat Pipe Technology
 Date: 12/28/2015 2:18 PM
 HPT Project: 47593

Qty:	Model:	Tag:	AHU Tag:	Order Code:
1	DHP	DHP	AHU	DU-AMG-20212A-07500-08500-1200X-XXX

DHP Bin Analysis

	Precool	Reheat	Heat pipe installed as retrofit	
Fin Height (in.)	75.00	75.00	Cooling	Electric
Fin Length (in.)	85.00	85.00	Heating	Hot Water
Face Area (SQFT)	44.27	44.27	Cooling EER	20
Face Velocity (SFPM)	451.8	451.8	Electric Rate	\$0.1/kwh
Max Pressure Drop (in. H2O)	0.19	0.18	Hot Water Rate	\$1.0/Therm
No. of Rows	2	2	Burner Efficiency	75%
Fiins per Inch	12	12	Motor Efficiency	90%
Fin Material	Aluminum	Aluminum	Fan Efficiency	70%
Fin Type	Standard	Standard	Refrigerant	R410a

TAMPA INTERNATIONAL AP, FL@M-F: 0-24 Sat: 0-24 Sun: 0-24

@Months: All.

RER: 201.68

Rate of Return: NA

Outside Air			Return Air		Mixed Air Entering			Precool Heat Pipe		
CFM	°F DB	°F WB	CFM	°F DB/ °F WB	Total CFM	°F DB/ °F WB	%RH	Rate BTU/h	Cond. lbs/hr	Leaving °F DB/ °F WB
20000	91.6	77.8	0	0.0 / 0.0	20000	91.6 / 77.8	54.4	265746	0	79.7 / 74.7
20000	87.8	76.2	0	0.0 / 0.0	20000	87.8 / 76.2	59.1	240495	0	77.0 / 73.3
20000	82.3	73.9	0	0.0 / 0.0	20000	82.3 / 73.9	68.0	202911	0	73.1 / 71.4
20000	76.9	72.3	0	0.0 / 0.0	20000	76.9 / 72.3	80.7	171176	19.3	70.1 / 70.1
20000	72.6	68.3	0	0.0 / 0.0	20000	72.6 / 68.3	80.5	138005	0	66.4 / 66.3
20000	68.1	63.8	0	0.0 / 0.0	20000	68.1 / 63.8	79.8	107464	0	63.2 / 62.2
20000	62.8	58.5	0	0.0 / 0.0	20000	62.8 / 58.5	77.6	72310	0	59.5 / 57.2
20000	57.2	53.3	0	0.0 / 0.0	20000	57.2 / 53.3	78.0	34709	0	55.6 / 52.7
20000	52.3	48.2	0	0.0 / 0.0	20000	52.3 / 48.2	74.9	1931	0	52.2 / 48.2
20000	47.5	43.7	0	0.0 / 0.0	20000	47.5 / 43.7	74.2	0	0	0.0 / 0.0
20000	43.2	38.6	0	0.0 / 0.0	20000	43.2 / 38.6	66.2	0	0	0.0 / 0.0
20000	38.3	34.2	0	0.0 / 0.0	20000	38.3 / 34.2	66.2	0	0	0.0 / 0.0
20000	32.6	27.8	0	0.0 / 0.0	20000	32.6 / 27.8	53.0	0	0	0.0 / 0.0
20000	28.6	24.0	0	0.0 / 0.0	20000	28.6 / 24.0	48.6	0	0	0.0 / 0.0

Cooling Coil			Reheat Heat Pipe			Run Time h/year	Savings		Fan Cost \$/year	Net Savings \$/year
Rate BTU/h	Cond. lbs/hr	Leaving °F DB/ °F WB	Rate BTU/h	Leaving °F DB/ °F WB % RH			Precool \$/year	Reheat \$/year		
1514615	828	52.0 / 52.0	265746	64.1 / 56.9	64.7	157	\$209	\$417	\$22	604
1396036	773	52.0 / 52.0	240495	63.0 / 56.5	67.4	778	\$936	\$1871	\$108	2699
1243922	714	52.0 / 52.0	202911	61.3 / 55.8	71.6	1523	\$1545	\$3090	\$210	4426
1145693	686	52.0 / 52.0	171176	59.8 / 55.2	75.3	1780	\$1523	\$3047	\$252	4318
865954	505	52.0 / 52.0	138005	58.3 / 54.6	79.5	1139	\$786	\$1572	\$155	2203
587116	314	52.0 / 52.0	107464	56.9 / 54.1	83.6	1190	\$639	\$1279	\$161	1757
285157	110	52.0 / 52.0	72310	55.3 / 53.4	88.6	893	\$323	\$646	\$120	848



Project Name: DHP Payback for School
 Prepared For:
 Prepared By: Drew Elsberry (hpt-drew)
 Heat Pipe Technology
 Date: 12/28/2015 2:18 PM
 HPT Project: 47593

79229	0	52.0 / 51.1	34709	53.6 / 51.8	89.0	523	\$91	\$182	\$70	202
91030	80	52.0 / 46.3	1931	52.1 / 46.3	64.8	387	\$4	\$7	\$51	(40)
0	0	52.0 / 52.0	0	0.0 / 0.0	0.0	167	\$0	\$0	\$22	(22)
0	0	52.0 / 52.0	0	0.0 / 0.0	0.0	139	\$0	\$0	\$18	(18)
0	0	52.0 / 52.0	0	0.0 / 0.0	0.0	69	\$0	\$0	\$9	(9)
0	0	52.0 / 52.0	0	0.0 / 0.0	0.0	12	\$0	\$0	\$2	(2)
0	0	52.0 / 52.0	0	0.0 / 0.0	0.0	3	\$0	\$0	\$0	0
Totals:						8760	\$6055	\$12111	\$1201	\$16965



Qty:	Model:	Tag:	AHU Tag:	Order Code:
1	DHP	DHP	AHU	DU-AMG-20212A-07500-08500-1200X-XXX

Psychrometric Analysis

Airflow: 20000 CFM
 Outside Air: 95.0/78.0 °F DB/ °F WB
 Precool Entering: 95.0/78.0 °F DB/ °F WB
 Precool Leaving: 82.1/74.6 °F DB/ °F WB
 Reheat Entering: 52.0/52.0 °F DB/ °F WB
 Reheat Leaving: 65.16/57.33 °F DB/ °F WB

