

Madani, Mo

From: Madani, Mo
Sent: Thursday, February 15, 2018 6:33 AM
To: Madani, Mo
Cc: Williams, Kendrick
Subject: Fwd: BCIS Login
Attachments: image001.png; image002.jpg; image003.jpg; image004.jpg; image005.jpg; image006.jpg; image007.png; image008.png; image009.png; image010.png

Sent from my iPad

Begin forwarded message:

From: "Madani, Mo" <Mo.Madani@myfloridalicense.com>
Date: February 14, 2018 at 7:57:55 PM EST
To: "Williams, Kendrick" <Kendrick.Williams@myfloridalicense.com>
Cc: "Madani, Mo" <Mo.Madani@myfloridalicense.com>
Subject: FW: BCIS Login

I will get with you on this.

Thanks

From: Ford, Jim [mailto:jford@myseminole.com]
Sent: Wednesday, February 14, 2018 5:20 PM
To: Bigelow, Joe
Cc: Madani, Mo
Subject: RE: BCIS Login

Joe,

I created a new log-in and have accessed petition # 153. Unfortunately the system will not allow me to enter any comments into the "Local Building Official response" field. In the interest of time, my response is:

I essentially agree with the comments from the petitioner with the exception of the comment "before a minor amendment regarding the manufacturer" The original permit was issued based on a valid product approval #7271.2 for a Union Corrugating Company 5V crimp. It was subsequently discovered that the product installed was not a Union Corrugating Metal but a Sheffield Metal. The only Florida approval for Sheffield Meta, #18316.1, is for 1-1/2" standing seam panel. In my opinion, this is not a minor amendment.

I denied the request for local product approval based on the fact that the EOR did not provide a installation procedure, which provides no direction for the jurisdiction to follow for an inspection. However, I would agree that an inspection affidavit, as provided by FBC 105.14, from the EOR, stipulating that the work has been completed in conformity with the Code, would be acceptable.

Thank you,

Jim Ford, CBO