

**REPORT OF THE THIRD-PARTY INDEPENDENT
EVALUATION PANEL ON THE EARLY STREAMER
EMISSION LIGHTNING PROTECTION TECHNOLOGY**

BY

John L. Bryan

Richard G. Biermann

Glenn A. Erickson

**CHARLES S. MORGAN LIBRARY
NATIONAL FIRE PROTECTION ASSOCIATION
1 BATTERY MARCH PARK
QUINCY, MA 02269-9101**

**Submitted to the National Fire Protection Association Standards Council on
September 1, 1999**

RARE
QC966
.B79
1999

EXHIBIT E


9650

OBTAIN FROM MARY MAYHARD, #001

Copyright©1999
NATIONAL FIRE PROTECTION ASSOCIATION, INC.

PREFACE

This report is the result of the collaborative and cooperative efforts of the three independent evaluators in reaching a complete and full consensus on the content of the report and the recommendations to the National Fire Protection Association Standards Council. Each evaluator certifies as to his full and complete agreement with the report as prepared and submitted to the National fire Protection Association Standards Council on September 1, 1999.

Name 
Date 8-14-99

Name Richard H. Biermann
Date August 19, 1999

Name Glenn E. Erickson
Date AUGUST 23, 1999

Table of Contents

| Topic | Page |
|--|------|
| I. INTRODUCTION | 4 |
| A. Purpose of Panel | 4 |
| B. Panel Formation | 5 |
| C. Information Solicitation | 6 |
| D. Number and Types of Materials Received | 7 |
| II. PANEL EVALUATION | 8 |
| A. Scientific and Technical Basis of ESE | 9 |
| 1. Consideration of Laboratory Tests | 10 |
| 2. Consideration of Field Tests | 15 |
| B. Adequacy of Theoretical Basis and Lab Tests | 19 |
| 1. Consideration of Scientific Theoretical Basis | 20 |
| 2. Consideration of Systems Performance. | 23 |
| III. RECOMMENDATIONS TO STANDARDS COUNCIL | 25 |
| A. Scientific and Technical Basis of ESE | 26 |
| B. Adequacy of Theoretical Basis and Lab Tests | 26 |
| C. NFPA Lightning Protection Documents | 27 |
| D. NFPA Initiatives | 29 |
| IV. A SELECTED BIBLIOGRAPHY. | 30 |

I. INTRODUCTION

A. Purpose of Panel

The third-party independent evaluation panel was created by the legal Agreement of Settlement and Release between the National fire Protection Association and the National Lightning Protection Corp., Heary Bros. Lightning Protection Co., Inc. and Lightning Preventor of America, Inc. (297) The agreement was accepted by the National fire Protection Association Standards Council on October 8, 1998 (296) as follows:

At its meeting on October 8, 1998, the Standards Council considered the request of Linda Joseph, representing Heary Bros. Lightning Protection Co., Inc., Lightning Preventor of America, Inc. and National Lightning Protection Corp. The request asks the Council to reopen the proceedings for issuance of a standard for Early Streamer Emission ("ESE") lightning Protection Systems, and to conduct a *de novo* review, re-weighting and considering all evidence, including evidence not previously available, anew. (For the history of previous proceedings, see especially, the Standards Council decision of July 18, 1995, Agenda item 94-5, D#95-25, and the Standards Council decision of January 12, 1994, Agenda item 94-5, D#94-11). Specifically the request seeks to have the Standards Council reopen the proceedings and reconsider the issuance of a standard for ESE lightning Protection systems along the lines set forth in a proposed settlement agreement which would resolve litigation by the requesting parties against NFPA ("Settlement Agreement"). A Copy of the Settlement Agreement has been made a part of the record.

After a hearing and consideration of the entire record before it, the Standards Council has concluded that reopening the proceedings pursuant to the request and in accordance with the Settlement Agreement is appropriate, will allow the Council to give full consideration to any existing and new information that is available, and is fully consistent with the regulations and procedures of the

NFPA and the Standards Council. The Council therefore, has voted to grant the request. Specifically, the Council, by this decision, undertakes to reopen the proceedings for consideration of issuance of a standard for ESE Lightning Protection Systems in full accordance with the terms of the Settlement Agreement.¹

The instructions to the third-party independent evaluation panel as contained in the Settlement Agreement were specific and are presented as follows:

f. As proposed by the Plaintiffs, the independent third-party shall consist of a panel headed by Dr. John Bryan, with one or two scientists or similarly-qualified technical persons chosen by Dr. Bryan. No person at the National Institutes of Standards and Technology ("NIST") who prepared or assisted in any way in the report on ESE technology previously issued by NIST, or any person who submitted comments in connection with the NIST report, shall be a member of this panel. If, for any reason, a member of this panel is unable to participate in the third-party evaluation, the evaluation shall be completed by the remaining member(s) of the panel or a substitute panel member may be chosen by Dr. Bryan. This panel, in issuing its report, shall address the following issues, and any other issues it deems relevant: (1) whether the ESE lightning protection technology is scientifically and technically sound; and (2) whether the ESE lightning protection technology is supported by adequate scientific theoretical basis and laboratory testing. The independent third party shall be instructed to specifically address in its report how it has addressed any and all issues.²

B. Panel Formation

The selection of the third-party independent panel members was

¹NFPA, Decision of The Standards Council, "NFPA 781", West Point, NY, 10-8-98, p. 1.

²NFPA, Agreement of Settlement and Release, "ESE Lightning Protection Systems", West Point, NY, 10-8-98, p 4.

completed on October 23, 1998 and the two additional panel members were Richard G. Biermann, Des Moines, IA and Glenn A. Erickson, Hastings, MN. None of the panel members were atmospheric scientists or "lightning experts", and did not claim to have expertise in the lightning protection study area.

The panel members were selected because of their long and varied experience in building, electrical and fire code development and the consensus standards process of the National Fire Protection Association and other code development organizations. The panel members were selected by the Chair for their consensus standards committee experience with their professional and personal reputations for reliable, fair, equitable and valid consideration of the consensus code and standards process.

The National Fire Protection Association agreed to provide administrative support for the third-party independent panel through the Codes and Standards Administration Division with Leona A. Nisbet as it's Director.

C. Information Solicitation

As a portion of the Settlement and Agreement it was stipulated that material and information could be provided for consideration by the third-party independent panel from any interested party. Thus, an announcement was prepared in October, 1998 by the Chair of the third-party independent panel with Leona A. Nesbit, Director of NFPA's Codes and Standards.

This solicitation announcement was published in NFPA publications and other trade journals in November, 1998 in the following format:

**Early Streamer Emission (ESE) Lightning Protection
Technology To Be Studied**

At its October 1998 meeting, the Standards Council agreed to reopen proceedings on the issuance of a standard on Early Streamer Emission (ESE) Lightning Protection Systems. In connection with this decision, the Council authorized the creation of an independent panel which will be issuing a report concerning ESE lightning protection technology to the Council.

This panel will be chaired by Dr. John L. Bryan, Frederick, MD, who has designated Mr. Richard Biermann, Des Moines, IA and Mr. Glenn Erickson, Hastings, MN to serve with him on the panel.

The panel will address the following issues, and any other issues it deems relevant: 1) whether ESE lightning protection technology is scientifically and technically sound; and 2) whether the ESE lightning protection technology is supported by an adequate scientific theoretical basis and laboratory testing. The panel is inviting anyone with information which may be relevant to its inquiry, to submit it for the panel's consideration.

Anyone wishing to submit information to the Panel, should send it no later than 1 March 1999 to the attention of NFPA Codes and Standards Administration, NFPA, 1 Batterymarch Park, Quincy, MA USA 02269-9101 (fax: 617-770-3500).³

D. Number and Types of Materials Reviewed

From the published deadline for the receipt of information of March 1, 1999 the third-party independent panel received and reviewed a total of

³National Fire Protection Association, NFPA News, Vol. 2, Number 1, December 1998, p. 1.

377 items as itemized and listed in the Bibliography in section IV of this report. The tabulation of these materials is presented as follows:

**Summary of ESE Third-Party Evaluation Panel
Materials Reviewed**

Personal Communications-Letters (to)

| | |
|----------------------------------|-----------|
| Third-Party Ind. Panel | 75 |
| NFPA Personnel | 48 |
| Others | <u>55</u> |
| Total = | 178 |

Reports, Papers, Documents (From)

| | |
|---------------------------------|-----------|
| Public | 163 |
| NFPA Standards System | <u>36</u> |
| Total = | 199 |

Total All Materials = 377

II. PANEL EVALUATION

The third-party evaluation panel decisions were developed through a consensus discussion involving all three panel members from the individual panel member's review of the submitted documents and personal communications. All of the items submitted to the panel obviously

influenced the deliberations and decisions of the panel. However, the numbers of the documents from item IV. A Selected Bibliography, are referenced where it appeared the specific document was significantly related to the panel's decision as are the referenced quotations.

A. Scientific and Technical Basis of ESE

Before considering the specific questions posed to the third-party evaluation panel it would appear to be essential to understand the concept and philosophy of the early streamer emission lightning protection technology. Allen *et al.*, (10) have provided the following explanation of the ESE concept:

A simple passive Franklin rod, on the roof of a large building, may not give full protection against a strike to the fabric, since upward corona may be initiated at parts of the structure more favorably placed in relation to the downward leader. However, if the corona can be activated at an earlier time in the downward progress, development of the upward leader may be advanced sufficiently, by such an activated rod, to overcome the distance disadvantage and effect an attachment before corona at other sites can develop sufficiently to compete with it. Extension of this argument suggests that the corona set up at the active rod, placed centrally, for example, could replace the coronas from the separate passive rods placed in a conventional system around the roof of the building.

This principle forms the basis of the so-called "early streamer emission" devices which have been developed in recent years.⁴

⁴Allen, N.L., K.J. Cornick, D.C. Faircloth and C.M. Kouzis, "Tests of The Early Streamer Emission Principle for Protection Against Lightning", IEEE Proceedings Science Measurement Technology, Vol. 145, No. 5, 9-98, p. 200.

The specific question charged to the independent third-party evaluation panel in the Settlement Agreement was: "whether the ESE lightning protection technology is scientifically and technically sound." The panel determined this question could only be answered validly with an examination of the laboratory tests (small-scale) and the Field tests (large-scale) data provided to it in the submitted documents.

1. Consideration of Laboratory Tests

A number of "lightning protection researchers" indicated their conclusions that laboratory tests did not adequately simulate lightning in the natural state due to the difference in scale between the laboratory arcs and the natural stroke lengths with the difference between positive and negative lightning. (249) (353) Pederson (312) has indicated a general caution relative to the application of laboratory tests in the following manner:

High voltage laboratories have been extensively used to simulate lightning phenomena. However, such simulations should be performed and interpreted with great care.⁵

However, small scale tests have been proven effective in examining specific aspects of the various types of lightning system air terminals, in particular by measuring the number of laboratory arcs attracted with the timing of the attraction of the arcs. In general, the laboratory tests have indicated the ESE terminals have a recorded advantage in the attraction of

⁵Pederson, Aage, A. Bondiv-Clargerie, V. Cooray and L. Dellera, "Lightning Threat and Protection in Perspective", International Conference on Lightning Protection, ICLP, Birmingham, 9-98, p. 1.

the laboratory arc or are equivalent in the attraction of the arc to the Franklin terminal. (NFPA 780 recognized) Allen *et al.*, (10) have indicated the results of their laboratory comparison of a ESE terminal and a traditional Franklin rod in the following terms:

It is shown that the ESE devices showed a small advantage, in time to breakdown, over the Franklin rod.⁶

Chalmers *et al.*, (62) indicated in their laboratory tests of ESE devices and Franklin rods that one ESE device reached breakdown at a time significantly earlier than the Franklin rod and two ESE devices caused discharges at the same time or later than a Franklin Rod. In addition these researchers indicated that Franklin rods of different shapes resulted in varying times to breakdown.

Berger (20) concludes his laboratory studies comparing the conventional Franklin rod with a pulsating ESE terminal in the following manner:

The conventional Franklin rod has been tested and then compared to an air-terminal using an Early Streamer Emission (E.S.E.) triggering device designed to enhance the protection area of the Franklin rod. Extensive tests have shown that a high voltage pulse E.S.E. air-terminal is more effective than the conventional Franklin rod used in the standards.⁷

⁶Allen, N.L., K.J. Cornick, D.C. Faircloth and C.M. Kouzis, "Tests of The Early Streamer Emission Principle for Protection Against Lightning", IEEE Proceedings Science Measurement Technology, Vol. 145, No. 5, 9-98, p. 200.

⁷Berger, Gerard, "Testing to Show a Time Advantage in Production of a Lightning Up Leader", CRNS Laboratoire De Physique Des Discharges, p. 1.

A series of laboratory evaluations were conducted on three various ionizing ESE air terminals by the ETL testing organization in 1995, comparing the initiation time of the device in comparison with a standard Franklin air terminal. (89) (91) (93) The examination was under laboratory conditions with the initiation time of the devices measured in nanoseconds, with 100 strikes to the devices. The three ESE devices all were reported to have lower initiation times than the Franklin rod, varying from a difference of 13.74 nanoseconds to 47.58 nanoseconds with the mean difference being 25.18 nanoseconds. In addition, ETL conducted a similar comparison evaluation between a standard sharp-pointed Franklin rod and a rounded Franklin rod and found a difference in the initiation time of 0.44 nanosecond. (95)

The Department of Electrical Engineering and Electronics at the University of Manchester Institute of Science and Technology (76) conducted Laboratory evaluation studies between three ESE devices and a standard Franklin rod. With one ESE device the Franklin rod was struck 27 times and the ESE device was struck 22 times. With the second ESE device the Franklin rod was struck 72 times and the ESE device was struck 42 times. The evaluation between the third ESE device and the Franklin rod resulted in each of the devices being struck 101 times, with eight discharges striking neither device. During this entire evaluation program in the laboratory a total of 420 electrical discharges were generated, with

200 of these discharges striking the Franklin rod for 47.6 per cent, 165 discharges striking the ESE device for 39.3 per cent, and 55 discharges did not strike either device for 13.1 percent of the discharges. The conclusion of this study were stated as follows:

The results produced from this test show a complete random nature of discharges to the Franklin and ESE terminals under identical electrical and geometrical conditions. They did not substantiate claims of enhanced properties from the ESE terminals.⁸

The disparity of results from the conducted laboratory evaluations of lightning protection air terminals may arise from a number of intervening variables involving the location of the devices, the interference of each device to the performance of the other device, the intensity of the laboratory discharge and the gap provided in the laboratory for the electrical discharge. Montadon (236) has reminded us of a fact related to any air terminal as follows:

It is well known that a Franklin rod cannot provide a 100 % protection against lightning discharges to its surroundings. Therefore it is a challenge to study on one hand side the protection efficiency of such a rod and on the other side to try to enhance the efficiency by all kinds of additional devices.⁹

Van Brunt *et al.*, (369) in the NIST report have elaborated on the view by Montandon relative to the effectiveness of lightning protection

⁸Department of Electrical Engineering and Electronics, "Report on The Results of Tests of ESE & Franklin Terminals", The University of Manchester, Institute of Science and Technology, Test Report No. 43427, p. 6.

⁹236. Montandon, Eric, Consultant-Switzerland, "Personal Communication & Papers", 2-16-99, p. 1.

air terminals in the following manner:

There is no reason to believe that an air terminal is 100% efficient in attracting lightning, regardless of what kind of ESE device it uses, if any. Considering the wide range of possible atmospheric conditions and types of lightning behavior that have been recorded, it is not surprising that air terminals of all types will sometimes fail. Tall structures are reported to be struck occasionally by lightning at points far below the top, i.e., outside of the "protection zone". Any claims of 100% efficiency in the performance of a lightning attractor should be viewed with skepticism.¹⁰

Grumley and Berger (140) have indicated that they believe the efficiency of an air terminal is related to both the design of the air terminal and the height penetration of the electrical intensification in the following manner:

Importantly, the electrical field intensification of an air terminal is related to the height penetration into the electrical field and its radius of curvature. This suggests that there is no universal air terminal.¹¹

Heary, *et al.* (154) (162) have reported on laboratory tests under varying atmospheric conditions with the use of exterior and interior test arrangements. Their conclusions indicated that atmospheric lightning thunderstorm conditions are necessary for air terminal testing and a superiority of the ionizing terminal over the standard air terminal.

¹⁰Van Brunt, Richard J., Thomas L. Nelson, Samar L. Firebaugh, Early Streamer Emission Air Terminals Lightning Protection Systems: Literature Review and Technical Analysis, Quincy, MA, National Fire protection Research Foundation, 1-31-95, p. 25.

¹¹Gumley, J. R., G. Berger, A Review of The Lightning Attachment Process and Requirements to Achieve Improved Modeling, Erico Lightning Technologies, Hobart, Australia, p. 3.

2. Consideration of Field Tests

It would appear from the literature that field tests of the performance of lightning protection system air terminals are as controversial as are the laboratory tests of air terminals. Field tests are subject to the occurrence of natural atmospheric conditions conducive to the initiation of lightning strikes. Thus, rockets trailing wire leaders to induced charges have been utilized in some field experiments.

Moore (249) has discussed the difference in the environmental situation between the generator created electrical arc in the laboratory and the natural lightning, and thus, the necessity for external field tests for the evaluation of air terminals as follows:

Such a laboratory test does not simulate how a given rod would respond to natural lightning because there is insufficient time in the laboratory tests for the ions created by the strong fields to move above the tip of a rod as they would during a natural strike. Streamers can be provoked from all manner of proposed air terminals in the laboratory with no indication as to how they would serve as lightning protectors; any differences in their behavior appear to be caused by their shapes, not by their protective capabilities.¹²

Eybert Berard *et al.*, (97) have reported on field tests conducted in St. Privar d'Allier France in 1996 and at Camp Blanding Florida in 1993 to 1995 utilizing the rocket triggering system to an altitude of 500 to 800

¹²Moore, Charles B., New Mexico Tech., "Personal Communication, Papers & Photos", 2-16-99, p. 2.

meters. These experiments appeared to be rather limited due to the atmospheric conditions. However, they did indicate the voltage the ESE device received with out a loss of operational capability, and the reported domination of the ESE device over a simple rod.

Gumley *et al.*, (142) have reported on an experimental test site operational during the 1997-98 storm season in northern Australia. A total of 500 triggering events were recorded with the largest event recording an electrical field at ground of 100 kV/m. From an analysis of the large event they concluded that their air terminal arrangement produced field intensification that may be too high for optimum leader development

Rison, and Moore *et al.*, (244) (245) (337) have conducted studies with air terminals exposed to natural thunderstorms at the Langmuir Laboratory for Atmospheric Research of the New Mexico Institute of Mining and Technology. These evaluations have concentrated on comparing the performance of both blunt and sharp-pointed Franklin rods in addition to comparing the performance of ESE air terminals and Franklin rods (248) (336) in the natural environment of an exposure near the summit of 3,287 m high South Baldy Peak. These studies comparing the sharp-pointed and the blunt Franklin rods indicated the blunt rods were more effective. Over a four-year period nine blunt rods were involved with cloud to ground discharges while none of the adjacent sharp-pointed rods appeared to have been struck.

Rison (336) reported in 1991 on studies conducted at the Langmuir Laboratory from July 15 to August 23, 1991 to evaluate whether a radioactive ESE air terminal provided protection within a 100 meter radius as reported by the Manufacturer. The ESE device was installed on a twenty foot mast 4 meters below South Baldy Peak. Video cameras were used to record the occurrence of lightning strikes. There were two recorded lightning strikes within the 100 meter radius area during the approximate five week study, one 85 meters from the ESE device and one approximately 78 meters from the device. However, the following statement should be noted from the report:

Near the end of the test period, it was noticed that the radioactive Preventor had been damaged --the weld had broken between the spherical ball on the Preventor and the nut to which it attached. It is not certain when or how this happened. There was no evidence of tampering or vandalism. Examination of the tip of the Preventor under a microscope showed evidence of melting, such as would occur if lightning were to have struck it. Most likely, the Preventor was struck by lightning at a time when the camcorders were not turned on (when the peak was in a cloud, or a storm occurred in the early morning hours), and the lightning broke the weld.¹³

Thus, it might appear that the ESE device was active in a lightning strike not recorded by the video cameras utilized during the study, since there were periods during the study when the cameras were inactive.

¹³Rison, William, A Study of Lightning Strikes in The Vicinity of a Radioactive Preventor, Langmuir Laboratory, New Mexico Tech., Socorro, NM, 11-8-91, p. 4.

Moore *et al.* (248) reported in 1998 a summary of all the field tests of the radioactive "Preventor" ESE device during the summers of 1990, 1991, 1993, 1994, 1995, 1996, and 1997. Moore's analysis is as follows:

In the six summers during which the "preventor" was exposed to thunderstorms overhead, lightning struck six different sites within 100 meters of the device yet the "preventor" itself was never struck.

Digitized measurements with quarter-microsecond time resolution, of the currents that flowed from the "Preventor" during two nearby lightning strikes in September 1997 showed no indication that the "Preventor" emitted any effective "early streamers". In fact, during one of these discharges, lightning struck a blunt rod located 20 meters distant yet no streamers were emitted from the "Preventor" to connect with this close strike.¹⁴

It should be noted these seven-year tests involved a single ESE device of a radioactive type. It should also be noted that Moore's (243) field studies under natural lightning conditions have questioned the validity of the effectiveness of the sharp-pointed Franklin air terminal as follows:

The failure of radioactive-ionizing and of sharply pointed air terminals to participate in lightning discharges by being pre-eminent connectors of lightning to earth is no surprise to scientists studying thunderstorms and lightning. For the past 40 years, I have been measuring the electric currents flowing into the air from both radioactive electrodes and from sharply pointed ones under the influence of the strong electric fields beneath thunderstorms but not one of my well-exposed electrodes has ever been struck by lightning.¹⁵

¹⁴Moore, C. B., William Rison, and G. D. Aulich, An Assessment of The Radioactive "Preventor" as an Early Streamer Emitting Lightning Protector, New Mexico Tech., Langmuir Laboratory for Atmospheric Research, Socorro, NM, 12-29-98, pp. 24-25.

¹⁵243. Moore, Charles B., New Mexico Tech., "Personal Communication to Subcommittee of NFPA Board of Directors", 9-4-95, p. 1.

The NIST study by Van Brunt *et al.* (369) has summarized the contributions of both the laboratory and the field tests to the continuing debate as to the effectiveness of the ESE air terminals in the following manner:

Although much has been learned about the operation of ESE terminals compared to conventional terminals from laboratory-scale tests which suggest that ESE devices do indeed enhance streamer emission, these results have not, and probably cannot, be used to make quantitative determinations of the relative efficiencies of these terminals for atmospheric conditions under a thunderstorm. At the present time, the results from a limited number of field tests with natural lightning are inconclusive with respect to providing estimates of relative efficiencies. It is not clear that enough data can ever be acquired from such tests to draw quantitative conclusions about attraction efficiency. Tests in the natural environment appear to be most useful in identifying and documenting conditions under which air terminals fail.¹⁶

B. Adequacy of Theoretical Basis and Lab Tests

The third-party independent evaluation panel was charged in the Settlement Agreement with evaluating the following question: "whether the ESE lightning protection technology is supported by adequate scientific theoretical basis and laboratory testing." The evaluation of this question necessitated an examination of the submitted documents. The role of laboratory testing has been examined in answering the previous question relative to the basis of ESE technology.

¹⁶Van Brunt, Richard J., Thomas L. Nelson, Samar L. Firebaugh, Early Streamer Emission Air Terminals Lightning Protection Systems: Literature Review and Technical Analysis, Quincy, MA, National Fire protection Research Foundation, 1-31-95, P. 26.

1. Consideration of Scientific Theoretical Basis

The scientific and theoretical basis for the ESE lightning protection technology appears to be based on the laboratory performance of the air terminals shown to be superior or at least equivalent to the Franklin rod.

Berger (31) has indicated that it is possible to predict the threshold field E_i for the activation of the ESE air terminal from the laboratory experiments in the following manner:

This concept leads to predict the threshold field E_i (initiation field) generated by the negative lightning downward leader for which the positive upward leader starts its continuous propagation from the tip of a lightning rod conductor the height h of which being known.¹⁷

As was indicated in the previous section of this report there appears to be no correlation between the performance of the ESE or Franklin air terminals in the high voltage laboratory situations and the field test results under natural lightning storm conditions. Almost all of the laboratory comparative tests have been between the radioactive ESE air terminals and the conventional Franklin air terminal. The material submitted to the independent third-party evaluation panel contains little data on tests of the sparking type of ESE devices. As Moore (242) (243) (249) has indicated the seven year field tests did not result in the activation of a radioactive ESE device and in 40 years the activation of a Franklin rod.

¹⁷Berger, Gerard, Expert Testimony, U.S. District Court, District of Arizona, 11-16-98, p. 1.

Van Brunt *et al.* (369) in the NIST report has indicated there appears to be some physical basis for the ESE air terminals from the laboratory tests, but the efficiency of this basis has not been determined in the natural lightning situation. This information was presented as follows:

A reasonable physical basis for the operation of an ESE device appears to exist in the sense that there is good evidence from laboratory investigations that the probability of initiating a streamer discharge from an electrode can be increased significantly by irradiation or electrical triggering. However, the precise amount by which this enhancement in streamer initiation improves the lightning attraction efficiency of an air terminal remains questionable. There is reason to doubt that it significantly extends the maximum range of protection.¹⁸

In contrast, Moore (249) reports the following experimental experience relative to the ESE lightning protection technology:

On the other hand, a September 1998, high-speed, digitized measurement of the current flowing from the tip of a standard, UL-approved, sharp-tipped Franklin rod during a strike to Earth 155-meters distance showed that it emitted three early streamers starting at about 260 microseconds before the strike. This sequence is shown in Figures 2 and 3. These streamers carried the largest currents we have yet measured and they were early enough to meet the early streamer criteria. None of these early streamers connected with the approaching lightning, however; after emission and early propagation, they all extinguished without contact with the negative, stepped leader, probably because the electric fields at their tips were not strong enough for continued propagation.

This of course, is why the so-called "early streamer" hypothesis fails. The factor that determines the continued propagation of an upward-going streamer is the strength of the electric field ahead of the leader

¹⁸Van Brunt, Richard J., Thomas L. Nelson, Samar L. Firebaugh, Early Streamer Emission Air Terminals Lightning Protection Systems: Literature Review and Technical Analysis, Quincy, MA, National Fire protection Research Foundation, 1-31-95, p. 25.

tip, not increased ionization back at the air terminal, the feature claimed for the ESE devices.¹⁹

Mackerras, *et al.*, (219) have reviewed the performance of ESE air terminals in the laboratory experiments and the field studies, as well as the studies of the performance of the ESE lightning protection systems. They essentially agree with Moore (249) and have concluded the propagation of a leader from the tip of the air terminal is not influenced by the characteristics of the air terminal as follows:

Once a streamer or leader discharge has propagated into the space remote from the air terminal, its further progress depends upon the supply of energy from the electric field in the space near the tip of the discharge and upon the dielectric properties of the air undergoing breakdown. As neither of these factors can be influenced by the air terminal, it is concluded that it is not possible to gain a significant improvement in lightning interception performance by causing the early emission of a streamer from an air terminal.²⁰

Mackerras *et al.*, (219) have also indicated they believe there is no physical basis for the claims of enhanced lightning protection from ESE air terminals based on the earlier time of the emission of an upward leader. They indicate that the ESE air terminal is subject to the identical physical laws as any air terminal concerning streamer to leader transition.

¹⁹Moore, Charles B., New Mexico Tech., "Personal Communication, Papers & Photos", 2-16-99, p. 4.

²⁰Mackerras, D., M. Darveniza and A.C. Liew, "Review of Claimed Enhanced Lightning Protection of Buildings by Early Stream Emission Air Terminals", IEE Proceedings - Science Measurement Technology, Vol. 144, No.1, 1-97, p. 1.

2. Consideration of System Performance

It would appear the ultimate evaluation of any complete lightning protection system would be the performance of the systems as installed on buildings. The submitted materials included one reference to the failure of a conventional system with Franklin rods (328) and there was one newspaper account of a Franklin rod system failure resulting in personnel injuries. (252) There were several studies of failures of ESE lightning protection systems. (146) (220).

The failure of the Franklin rod system resulting in the eleven personnel injuries occurred at the Robert F. Kennedy stadium in Washington, D.C. on June 13, 1998. (252) Richardson reported on the failure of a Franklin rod air terminal located approximately four feet from an externally mounted camera on the building which was damaged by a lightning strike. (328)

Makerras *et al.*, (220) have reported on four cases of lightning striking buildings in Singapore from the late 1960's until the 1980's. Hartono and Robiah (146) have reported on ten cases of failures on buildings protected with ESE lightning protection systems. This study utilized photographs of the building conditions both before and after the reported lightning strikes on the damaged areas of the buildings. It was found from this photographic study the damage appeared to be dependent on the number of strokes received, the strength of the lightning stroke and

the shape of the structure at the point of the stroke. Although not specified in the study Hartono and Robiah have indicated lightning strike damage was found on buildings protected with Franklin air terminals as indicated in the following statement:

Studies conducted on the buildings equipped with the standard lightning air terminals (Franklin rod type) also exhibited similar lightning damage locations on or near the rooftop. Based on this comparison, we conclude that no advantage can be obtained by using the ESE device in protecting the building against direct lightning strikes.²¹

It should be noted that all of the incidents of system failure submitted to the panel lacked the necessary detailed documentation to enable a valid analysis as to the effectiveness of the system. Even the most detailed photo study lacked the necessary documentation consisting of the following: The manufacture and model of the air terminal. The date the installation was completed, thus establishing the age of the system when the lightning strike occurred. The maintenance and condition of the system when the strike occurred, including the condition of the down conductors and the grounding system. It would appear that detailed documentation of lightning protection system operations or failures is a needed component for the evaluation of the effectiveness of lightning protection systems of all types on various buildings of differing heights and configurations.

²¹Hartono, Zainal Abidin and Ibrahim Robiah, A Long Term Study on The Performance of Early Streamer Emission Air Terminals in a highly Isokeraunic Region. 2-19-99, p. 2.

Van Brunt *et al.*, (369) has referenced this problem of adequate data on lightning protection system performance in the following manner:

There are reports of incidents where ESE devices failed to provide the protection specified by the manufacturer [156,158,165,215]. Statistics on the failure of conventional systems have also been documented [109]. When examining reports of "failures", one can always raise questions about their cause, e.g., whether they are primarily a consequence of exaggerated claims made by the manufacturer or a consequence of misuse (faulty installation) of the device. Reports of isolated failures raise legitimate concerns, but are seldom accompanied by enough supporting data about the event to enable a determination of why the failure occurred. Generally it is difficult to draw significant conclusions from single events that can be used to improve system design or evaluate system performance.²²

Thus, given the present situation of lightning protection system performance not being a priority of the proponents of the systems, the manufacturers, the insurance companies or public officials it would appear little valid information or data relative to a validation of the theoretical basis of the systems will be obtained.

III. RECOMMENDATIONS TO STANDARDS COUNCIL

Based on a thorough and complete evaluation of the 377 items submitted to the third-party independent panel the members of the panel have agreed in a complete consensus on the following recommendations to the National Fire Protection Association Standards Council. It should be

²²Van Brunt, Richard J., Thomas L. Nelson, Samar L. Firebaugh, Early Streamer Emission Air Terminals Lightning Protection Systems: Literature Review and Technical Analysis, Quincy, MA, National Fire protection Research Foundation, 1-31-95, p. 25.

recognized the Standards Council is the official designated authority on any action to be taken relative to the NFPA lightning protection documents.

A. Scientific and Technical Basis of ESE

The initial question posed to the third-party independent evaluation panel was stated as: "whether the ESE lightning protection technology is scientifically and technically sound." The panel's review of the submitted materials resulted in the following determinations:

1. The ESE air terminals appear to be technically sound since they are generally equivalent to the conventional Franklin air terminal in laboratory experiments.
2. However, neither the ESE air terminals nor the conventional Franklin rod appear to be scientifically or technically sound when evaluated in field tests under natural lightning conditions.
3. The ESE lightning protection technology as currently developed in the installation of complete systems does not appear to be scientifically and technically sound in relation to the claimed areas of protection or the essentials of the grounding system.

B. Adequacy of Theoretical Basis and Lab Tests

The second specific question posed to the third-party independent review panel was stated as: "whether the ESE lightning protection technology is supported by adequate scientific theoretical basis and

laboratory testing.” The panel’s review of the submitted materials resulted in the following determinations:

1. There does appear to be an adequate theoretical basis for the early streamer emission lightning protection air terminal concept and design from a physical viewpoint.

2. There does not appear to be an adequate theoretical basis for the claimed enhanced areas of protection with limited down conductors and grounding system.

3. The high voltage laboratory tests of the ESE air terminals appear to be adequate in scope and quantity, but they are limited in that they are not equivalent to an evaluation of the complete ESE lightning protection system under natural thunderstorm conditions.

C. NFPA Lightning Protection Documents

The third-party independent evaluation panel was also directed in the Settlement Agreement as follows: “This panel, in issuing its report, shall address the following issues, and any other issues it deems relevant:” The panel considered the issues of the existing NFPA 780 document titled: Standard for The Installation of Lightning Protection Systems 1997 edition. (294) and the proposed NFPA 781 document titled: Standard for Lightning Protection Systems Using Early Streamer Emission Air Terminals. (277) The panel considered the need for each document and each committee’s membership and balance in accordance with NFPA

procedures. The panel's review of the submitted materials resulted in the following determinations:

1. The current NFPA 780 Committee should be discharged and the Committee should be completely restructured. The committee needs new and additional memberships in the membership categories of enforcer, consumer, user, insurance, labor, special expert and research/testing..

2. The Council should solicit memberships from prominent users such as: FAA, DOE, DOD, NASA, IBM, Reedy Creek Improvement District, phone, radio, television organizations and electric power utilities.

3. The NFPA 780 document should be reformulated as a Guide or Recommended Practice. It appears to the panel the NFPA 780 document does not meet the NFPA criteria for a standard since the recommended lightning protection system has never been scientifically or technically validated and the Franklin rod air terminals have not been validated in field tests under thunderstorm conditions. The NFPA criteria for a standard as stated in the NFPA 99 Directory (298) is as follows:

Standard --A document, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions shall be located in an appendix, footnote, or fineprintnote and are not to be consider as part of the requirements of a standard.²³

²³NFPA, National Fire Protection Association 1999 Directory, Quincy, MA, 11-98, p. 52.

It appeared to the panel the NFPA 780 document is currently not suitable for mandatory reference by another standard or code or for adoption into law. The current NFPA 780 document appears to have been recognized by historical precedent rather than by experimental and scientific validation.

4. The current provision in the NFPA 780 document scope as follows: "except those concepts utilizing early streamer emission air terminals." Should be removed. The restructured 780 Committee should include representatives from the total lightning protection community.

D. NFPA Initiatives

The panel in reviewing the submitted material from the NFPA standards system for the years 1986 to 1998 (263 - 297) have developed the following determinations:

1. The NFPA Fire Investigations group should form a task force with an NFPA electrical engineer to conduct detailed documented investigations of lightning strike incidents to provide the needed field experience relative to the performance of lightning protection systems. These investigations should include such needed data as: Manufacturer and installer of the system. Date of installation of the system. Lightning damage to the system. The maintenance and condition of the system, including down conductors, grounding methods and system performance.

2. The NFPA Fire Analysis and Research group should develop a system for collecting the needed notification and statistical data on lightning strike incidents resulting in personal injuries or significant property damage for the investigation task force. Such a system could include the resources of the NFPA International Fire Marshals Association, the Insurance company members of NFPA and Underwriters Laboratories.

3. The Standards Council should monitor the activities of the restructured NFPA 780 committee for a guide or recommended practice document, with semi-annual written reports from the committee staff liaison.

IV. A SELECTED BIBLIOGRAPHY OF MATERIALS SUBMITTED TO THE EVALUATION PANEL

1. Ace Lightning Protection Company, Submittal Data, State Correctional Facility, Pine Grove, Indiana County, 9-9-98.
2. Ackerman, Charles H., East Coast Lightning Equipment Inc., "Personal Communication to Richard P. Bielen", NFPA, 5-16-94.
3. Ackerman, Charles H., East Coast Lightning Equipment Inc., Deposition, U.S. District Court, District of Arizona, pp. 70-77, 124-133, 136-137, 140, 144-146, 205-218, Exhibits 4, 10, 11, 18, 19, 20, 21, 12-3-98: pp. 266-381, 383, 2-2-99.
4. Ackerman, Charles H., East Coast Lightning Equipment Inc., "Personal Communication & Papers", 2-26-99.
5. Ackerman, Charles H., East coast Lightning Equipment Inc., "Personal Communication", 2-26-99.
6. Alessandro, F.D., Erico Lightning Technologies, A Statistical Analysis of Strike Date From Real Installations Which Demonstrates Effective Protection of Structures Against Lightning, Hobart, Australia.

7. Alessandra, F.D. and G. Berger, Erico Lightning Technologies, Laboratory Studies of Corona Current Emissions From Blunt, Sharp and Multipointed Air Terminals, Hobart, Australia.
8. Aleksandrov, G.N., "Increase of Lightning Rod Efficiency", 1st. International Workshop on Physics of Lightning, France, 6-21-25-93.
9. Allen, N.L., "Investigation of The Principles of Early Streamer Emission Devices", ICLP-98, Birmingham, 1998, pp. 406-411.
10. Allen, N.L., K.J. Cornick, D.C. Faircloth and C.M. Kouzis, "Tests of The Early Streamer Emission Principle for Protection Against Lightning", IEEE Proceedings Science Measurement Technology, Vol. 145, No. 5, 9-98, pp. 200-206.
11. Allen, N.L., University of Manchester, "personal Communication & Papers", 1-18-99.
12. Bakker, T., "781 Ballot to Andrew J. O'Connor", Chair 781, 12-15-93.
13. Barnard, James G., NorthEast Lightning Protection systems Inc., "Personal Communication", 1-28-99.
14. Belandis, J.P., A. Eybert-Berard, Indelec, "In Situ Testing of The Prevelectron Early Streamer Emission Lightning Conductor (E.S.E.L.C.) Manufactured by Indelec, 1994 Triggered Lightning Campaign, Camp Blanding Florida, 11-94.
15. Belgium National Institute, Thomas Lightning Protection, Brussels, Belgium.
16. Berger, G., B. Sonouci, M. Abdel Salam, M.T. El Mohandes, "Onset Criterion of Upward Streamers From A Franklin Rod," Electrical society of America, Palo Alto, CA, 6-22-24-88.
17. Berger, G., B. Sonouci, A. Goldman, M. Goldman, "A Physical Approach for Lightning Protection", 9th. International Conference on Gas Discharges and Their Applications, Venezia, 9-19-23-88.
18. Berger, G., A. Goldman, B. Sonouci, M. Goldman, "Some Basic Ideas to Improve Lightning Interception, ICLP 1988.
19. Berger, Gerard, "Determination of The Initiation Advance of The Pulsar 20KV", Laboratoire De Physique Des Discharges, Research Report No. HPF/0195/072, 4-9-11-92.
20. Berger, Gerard, "Testing to Show a Time Advantage in Production of a Lightning Up Leader", CRNS Laboratoire De Physique Des Discharges.
21. Berger, Gerard, "Applications of The Electrogeometric Model to Franklin and ESE Lightning Rods", Lightning Protection Workshop, Hobart, Australia, 11-12-13-92.
22. Berger, Gerard, "Laboratory Simulation of The Connecting Discharge From A Lightning Rod Conductor-Application to Lightning Protection", 2nd. Middle East Power System conference, Egypt, 1992.

23. Berger, Gerard and James Charrier, "A Simple Model Explaining The Positive Glow Corona in Atmospheric Air", Laboratoire De Physique Eperimentale.
24. Berger, Gerard, "The Application of Upward Leader Initiation Time Advantage into an Electrogeometric Model", CRNS.
25. Berger, Gerard, "Investigations on The Lightning Upward Leader Inception Field in High Voltage Laboratory", Jordan International Power System Conference, Amman, 10-4-6-93.
26. Berger, Gerard M., "The Design of A New Approach for Lightning Protection", NFPA Fall Meeting, Phoenix, 11-14-17-93.
27. Berger, Gerard, "Personal Communication & 781 Ballot to Andrew J. O'Connor", Chair 781, 12-14-93.
28. Berger, Gerard, "Personal Communication to Arthur E. Cote, NFPA", 12-14-93.
29. Berger, Gerard, "The Early Streamer Emission Lightning Rod Conductor", Laboratoire De Physique Des Discharges.
30. Berger, Gerard, "Inception Electric Field of The Lightning Upward Leader Initiated From a Franklin Rod in Laboratory", 11th. Annual Conference on Gas Discharges and Their Applications, Chuo University, Tokyo, 9-11-15-95.
31. Berger, Gerard, Expert Testimony, U.S. District Court, District of Arizona, pp. 1-44, 11-16-98.
32. Berry, Dennis J., NFPA, "Personal Communication to Elizabeth Gilson", Wiggin & Dana, 2-23-94.
33. Berry, Dennis J., NFPA, "Personal communication to A. E. Cote", NFPA, 3-15-94.
34. Blitstein, Salomon and Eduardo Mariani, "Personal Communication to Leona Nesbit", NFPA, 12-27-93.
35. Blitstein, Salomon, "Personal Communication", 2-17-99.
36. Bittner, Burt, J., Sr., Interstellar Ltd., "781 Ballot to Andrew J. O'Connor", Chair 781, 12-15-93.
37. Bittner, Burt, J., Sr., Interstellar Ltd., "Personal Communication to Leona Nesbit", NFPA, 12-21-93.
38. Blanda, Robert S., Dolphin Hotel Associates, "Personal Communication to Jack Bettick", Alexander & Alexander, 8-17-92.
39. Blanda, Robert S., Dolphin Hotel Associates, "Personal Communication to Jack Bettick", Alexander & Alexander, 9-14-92.
40. Bonamy, Andre, Electricite De France, Les Laboratoires De Genie Electrique, "Personal Communication", 2-18-99.

41. Bouquegneau, C., C. Gregoire, J. Trecat, "Tests on Ionizing Rods", Technical Note for The Belgian Electrotechnical Committee CEB, 2-85.
42. Bouquegneau, C., Ir Christian, Faculte Polytechnique de Mons, Belgium, "Personal Communication", 2-15-99.
43. Bouquegneau, C., "The Value of Radioactive Lightning Conductors", Revue Belgedufeu.
44. Brohm, Richard T., "Personal Communication", 1-25-99.
45. Brown, Henry S., Florida Department of Transportation, "Personal Communication & Drawings", 12-29-98.
46. Burris, Sara, "Lightning Preventor Brings Safety into The 21st. Century", Today, Vol. 4, No. 62, 8-1-97, p. 1.
47. Burrows, B. J. C., Culham Laboratory, "Personal Communication to P. Ludlow", W. J. Furse & Co. Ltd., 12-15-83.
48. Burrows, Brian, "Personal Communication", 2-11-99.
49. Caloggero, John M., NFPA, "Personal Communication to Mark Earley", NFPA, 1-20-93.
50. Caloggero, John M., NFPA, "Personal Communication to Art Cote", NFPA, 12-20-93.
51. Caloggero, John M., NFPA, "Personal Communication to Art Cote", NFPA, 12-21-93.
52. Carpenter, Roy B., Jr., Lightning Eliminators and Consultants Inc., A Hybrid Lightning Strike Protection system That Satisfies The Standards and Reduces The overall Risk. Boulder.
53. Carpenter, Roy B., Jr., and Mark M. Drabkin, Lightning Eliminators and Consultants Inc., Lightning Strike Protection, Boulder.
54. Carpenter, Roy B., Jr., Lightning Eliminators and Consultants Inc., Improved Strike Collection With The Ion Plasma Generator (IPG).
55. Carpenter, Roy B., Jr., Lightning Eliminators and Consultants Inc., "Personal Communication & Papers", 2-4-99.
56. Carpenter, Roy B., Jr., Lightning Eliminators and Consultants Inc., "Personal Communication & Papers", 3-3-99.
57. CEI/IEC, International Standard, Protection of Structures Against Lightning-Part 1-2 General Principles-Guide B-Design, Installation, Maintenance and Inspection of Lightning Protection systems. CEI/IEC, 61024-1-2, 1998.
58. Chaberski, Aleksander Z., Lightning Consultant, "Personal Communication to NFPA Standards Council", 6-9-86.

59. Chaberski, Aleksander Z., Lightning consultant, "Personal communication to Tishman Hotel corp.", 9-29-92.
60. Chaberski, Aleksander Z., Lightning Consultant, "Personal Communication to Arthur E. Cote", NFPA, 12-16-93.
61. Chaberski, Aleksander Z., Lightning consultant, "Affidavit, Document No. 8413, Buffalo, NY, 2-26-99.
62. Chalmers, I.D., J. C. Evans, W. H. Siew, N. L. Allen, D.A. Greaves, I. cotton, "Laboratory Testing of Early Streamer Emission Air Terminals", University of Strathclyde, UMIST, pp. 412-417.
63. Chalmers, I. D., University of Strathclyde, "Personal Communication", 2-12-99.
64. Clarke, Sylvia M., SUNY College at Fredonia, "Personal Communication to Mr. Heary", Heary Bros. Lightning Protection Co. Inc., 2-16-99.
65. CNRS/Helita, patents, Pulsar the Atmospheric Pulse Voltage Lightning Conductor.
66. CNRS/Helita, patents, Corona II The Electrical Ionizing Lightning Conductor.
67. Cohen, Richard L., Panamax Power Protection Products, "Personal Communication & Paper", 1-8-99.
68. Conrad, Larry A., Lightning Master Corporation, "Personal Communication to NFPA Standards Council", 12-4-93.
69. Cotton, Larry, San Juan Construction, "Personal Communication Petition", 1-13-99.
70. County Commissioners, Purchasing Division, Broward County, Florida, "Special Instructions to Quoters, Furnish & Install Lightning Protection System. Attachment "A" Quotation Request No. H1812-99", 2-8-99.
71. Danni, F. Robert, Western Region Board of Review, NY Department of State, Decision in the Petition of Marine Midland Arena for a Variance to The New York State Uniform Fire Prevention & Building Code, 8-29-97.
72. Danvers, Martin, British Standards Institute, "Personal Communication", 2-19-99.
73. Deller, L., E. Garbagnati, M. Bernardi, V. Cooray, Aa. Pederson, A. Bondiou, I. Gallimberti, F, Ruhling, "Lightning Exposure of Structures and Interception Efficiency of Air Terminals", CIGRE, Task Force 33.01.03, 10-97.
74. Deller, Luigi, Maurizio Scaravaggi, Marino Bernardi, CESI, "Personal Communication", 2-26-99.
75. Dennis, Eric and Christian Morin, "Comparison of Early Streamer Emission (ESE) and Simple Rod Type Lightning conductors", Electricite de France, Direction des Etudes et Recherches, Test Report No. HM22/1201/2, 1995.
76. Department of Electrical Engineering and Electronics, "Report on The Results of Tests of ESE & Franklin Terminals", The University of Manchester, Institute of Science and Technology, Test Report No. 43427.

77. Departments of The Army and The Air Force, Electrical Design Lightning and Static Electricity Protection, March 1985, p. 2-1.
78. Diaz, Henry, "781 Ballot to Andrew J. O'Connor", Chair 781, 12-7-93.
79. Diels, Jean-Claude, Ralph Bernstein, Karl E. Stahlkopf and Xin Miao Zhao, "Lightning Control With Lasers", Scientific American, August 1997, pp. 50-55.
80. Dowling, T.P., Institute of Makers of Explosives, "Personal Communication to Andrew J. O'Connor", Chair 781, 12-6-93.
81. Drabkin, Mark M, and Roy B. Carpenter, Jr., Lightning Eliminators and Consultants, An Analysis of Advanced Lightning Collection Technology, 3-3-99.
82. Duggleby, J. C., Australian Radiation Laboratory, "Personal Communication to B. Buckley", Lightning Protection International, 5-22-92.
83. Dupuy, Jean, "Negative Discharges in Air", Proceedings of The 4th. Japan-France Workshop on Lightning, Kawazawa, Japan, 11-11-14-91.
84. East Coast Lightning Equipment Inc., Vote Against Document 781, 11-93.
85. Easton, Stephen B., A C Lightning Security Inc., "Personal Communication to Donald E. Downen", Sachs Electric, 11-4-93.
86. E.F. Australasia, Pty. Ltd., E.F. Lightning Control System.
87. E.F. International S.A., Introduction to The E.F. Carr System of Lightning Protection, 1993.
88. Ensign, Brian S., ETL Testing Laboratories, Inchcape Testing Services, "Personal Communication to Ken and Bill Heary", Heary Bros. lightning Protection Co. Inc., 9-29-95.
89. ETL Testing Laboratories Inc., Listing Report, Inspection, Tests, and Evaluation of ESE Lightning Preventor Air Terminal, Model 2005, Listing Report No. 548522, 2-14-95.
90. ETL Testing Laboratories Inc., Factory Audit Manual and Procedural Guide for Complying With ETL Listing, In-Plant Labeling and Follow-Up Service Requirements, 2-14-95.
91. ETL Testing Laboratories Inc., Listing Report, Inspection, Tests, and Evaluation of ESE lightning Preventor Air Terminal, Model LPA 4004A, Listing Report No. 548905, 3-7-95.
92. ETL Testing Laboratories Inc., Factory Audit Manual and Procedural Guide for Complying With ETL Listing, In-Plant Labeling and Follow-Up Service Requirements, 2-14-95, Revised 3-7-95.
93. ETL Testing Laboratories Inc., Listing Report, Inspection, Tests, and Evaluation of ESE Air Terminal Blitzter, Model LPA 7000, Listing Report No. 548904, 3-7-95.

94. ETL Testing Laboratories Inc., Factory Audit Manual and procedural Guide for Complying With ETL Listing, In-Plant Labeling and Follow-Up Service Requirements, 2-14-95, Revised 4-24-95.
95. ETL Testing Laboratories Inc., Listing Report, Inspection, Tests, and Evaluation of ESE Lightning Preventor Air Terminals, Listing Report No. 550635, 4-21-95.
96. ETL Testing Laboratories Inc., Listing Report, Inspection, Tests, and Evaluation of ESE Lightning Terminals, Listing Report No. 552913, 6-30-95.
97. Eybert-Berard, A., A. LeFort, B. Thirion, "On-Site Tests", CEA/Indelec.
98. Eybert-Berard, A., B. Thirion, J. P. Berlandis, B. Bader, C. Gary, "In Situ Lightning Rods Test and Analysis", Triggered Lightning Campaign, Florida, Indelec, 1993.
99. 2F Franklin France, Saint-Elmo Lightning Conductor With Piezoelectric Exciter.
100. Fiske, William T., Inchcape Testing Service, "Personal Communication to Heary Bros. Lightning Protection Co. Inc.", 12-30-93.
101. Fiske, William T., Inchcape Testing Services, "Personal Communication to Kenneth Heary", Heary Bros. Lightning Protection Co. Inc., 8-11-97.
102. Fiske, William T., Deposition, U.S. District Court, District of Arizona, pp. 105-117, 11-9-98.
103. Flashtech, Pty, Ltd, "Personal Communication & Photos to Emillo Garbagnati," ENEL.
104. Flisowski, Zdobyslaw, Warsaw University of Technology, "Personal Communication", 2-24-99.
105. Floret, N., Helita, "Personal Communication to Art Cote," NFPA, 12-6-93.
106. Floret, N., Helita, "Personal Communication & 781 Ballot to Andrew J. O'Connor", Chair 781, 12-14-93.
107. Floret, N., Helita, "Personal Communication to Richard Bielen", NFPA, 3-14-94.
108. Franklin, Douglas J., Thompson Lightning Protection Inc., "Personal Communication to Bob Zafaras", 11-22-98.
109. French Standard-Lightning Protection, Protection of Structures and of Open Areas Against Lightning Using Early Streamer Emission Air Terminals, NFC 17-102, 7-95.
110. Fritts, Barbara, Inchcape Testing Services, "Personal Communication to Ken Heary", Heary Bros. Lightning Protection Co. Inc., 4-24-95.
111. Fritts, Barbara, Inchcape Testing Services, "Personal communication to Ken Heary", Heary Bros. Lightning Protection Co. Inc., 5-30-95.
112. Fritts, Barbara, Inchcape Testing Services, "Personal Communication to Ken Heary", Heary Bros. Lightning Protection Co. Inc., 6-12-95.

113. Fritts, Barbara, Inchcape Testing Services, "Personal Communication to Ken Heary", Heary Bros. Lightning Protection Co. Inc., 6-29-95.
114. Frydenlund, Marvin H., "Ineffective Devices", Chapter 17 in Lightning Protection for People and Property, New York, Van Nostrand Reinhold, 1993, pp. 217-223.
115. Gary, C., B. Hutzler, D. Cristescu, G. Dragan, R. Enache, B. Popa, "Laboratory Aspects Regarding The Upward Positive Discharge Due to Negative Lightning", CIGRE33-88, Stockholm, 8-88.
116. Gary, C., "Parameters for H.V. Testing of Various Forms of Air Terminations", Electricite de France.
117. Gary, C., S. Hurdubetiu, G. Dragan, "Downward Negative Lightning and High Voltage Overhead Line Surface Gradients", 21st. ICLP, Berlin, 9-21-25-92.
118. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to NFPA Standards Council", 9-13-93.
119. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to NFPA Standards Council", 10-5-93.
120. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication & Papers to NFPA Standards Council", 10-11-93.
121. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to Arthur E. Cote", NFPA, 12-9-93.
122. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to NFPA Standards Council", 1-12-94.
123. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to Leona Nesbit", NFPA, 2-8-94.
124. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to Dennis J. Berry", NFPA, 2-17-94.
125. Gilson, Elizabeth, Wiggin & Dana, "Personal Communication to Paul Klolb", 9-23-96.
126. Gilson, Elizabeth, Attorney at Law, "Personal Communication ", 2-24-99.
127. Graziano, Kim, Loehr Lightning Protection Co., "Personal Communication & Photos", 2-18-99.
128. Gross, Al, Orbital Sciences Corp., "Personal Communication", 2-16-99.
129. Grzybowski, S., A.L. Libby, E. B. Jenkins, C. R. Davis, "DC Dissipation Current From Elements Used for Lightning Protection on 115 KV Transmission Lines", IEEE Proceedings of The SouthEastCon 91, pp. 1250-1254.
130. Grzybowski, S., E. B. Jenkins, "Estimation of Lightning performance on Models of 115 KV Transmission Lines", 8th. International Symposium on High Voltage Engineering, Yokohama, 8-23-27-93, pp. 325-328.

131. Grzybowski, S., G. M. Molen, S. Sathishram, C. R. Davis and E. B. Daigle, "Lightning Performance Test on 115 KV Transmission Line Model With Spline Ball Ionizers", Proceedings of 1994 IEEE SouthEast Con 94, Miami, 4-10-13-94, p. 288.
132. Grzybowski, S., G. M. Molen, C. R. Davis and E. B. Daigle, "Effectiveness of Spline Ball Dissipators Used for Lightning Protection on 115 KV Transmission Lines-Model Tests", 22nd. International conference on Lightning Protection. ICLP, Budapest, 9-19-23-94.
133. Grzybowski, S., G. M. Molen, C. R. Davis and E. B. Daigle, "Effectiveness of Dissipators Used for Lightning Protection of 13 KV Distribution Lines-Model Test", 9th. International Symposium on High Voltage Engineering, Austria, 8-28-9-1-95.
134. Grzybowski, S., "Evaluation of Lightning performance of 115 KV Transmission Lines With Spline Ball Ionizers Based on Model Tests", 1995 International Aerospace and Ground Conference on Lightning and Static Electricity, Williamsburg, 9-26-28-95.
135. Grzybowski, S. and C. D. Taylor, "Effectiveness of Dissipators Used for Lightning Protection on 115 KV Transmission and 13 KV Distribution Lines-Long Gap Model Tests", 10th. International Symposium on High Voltage Engineering, pp. 479-484.
136. Grzybowski, S., A. L. Libby, J. R. Gumley, S. J. Grumley, "Comparative Testing of Ionizing and Non-Ionizing Air Terminals", 10th. International Symposium on High Voltage Engineering, Montreal, 8-25-29-97, pp. 331-334.
137. Grzybowski, S., Mississippi State University, "Personal Communication & Papers", 2-22-99.
138. Gumley, J. R., International Protection Consultants, Pty, Ltd., "Personal Communication to NFPA Standards council", 4-10-93.
139. Gumley, Rick, Erico Lightning Technologies", Personal Communication & 781 Ballot to Andrew J. O'Connor", 781 Chair, 12-15-93.
140. Gumley, J. R., G. Berger, A Review of The Lightning Attachment Process and Requirements to Achieve Improved Modeling, Erico Lightning Technologies, Hobart, Australia.
141. Gumley, J. R., F. D. Alessandro and C. J. Kossman, Development of a High Voltage Arbitrary Waveform Generator Capable of Simulating The Natural Electrical Fields Arising From Stepped Downleaders, Erico Lightning Technologies, Hobart, Australia.
142. Gumley, J. R., F. D. Alessandro, M. A. Austin, Experimental Arrangements To Study Lightning Attachments Characteristics in Northern Australia, Erico Lightning Technologies, Hobart, Australia.
143. Hann, Julius, Handbook of Climatology, New York, The MacMillan Co., 1903, pp. 286-291.

144. Harger, Jeffery B., Harger Lightning Protection Inc., "Personal Communication to Mr. & Mrs. James Fritsch", 11-4-92.
145. Haortono, Zainal Abidin, Ibrahim Robiah, "A Method of Identifying The Lightning Strike Location on A Structure", International conference on Electromagnetic Compatibility, 4-11-13-95.
146. Hartono, Zainal Abidin and Ibrahim Robiah, A Long Term Study on The Performance of Early Streamer Emission Air Terminals in a highly Isokeraunic Region. 2-19-99.
147. Heary Bros. Lightning Protection Co. Inc., Introduction to Transient Protection Concepts.
148. Heary, Frederick, Heary Bros. Lightning Protection Co. Inc., "Personal Communication & Petitions", 2-19-99.
149. Heary, Frederick, Heary Bros. Lightning Protection Co. Inc., "Personal Communication & Petitions", 2-23-99.
150. Heary, Frederick, Heary Bros. Lightning Protection Co. Inc., "Personal Communication", 2-26-99.
151. Heary, Frederick, Heary Bros. Lightning Protection Co. Inc., "Personal Communication", 2-26-99.
152. Heary, Frederick, Heary Bros. Lightning Protection Co. Inc., "Personal Communication", 3-3-99.
153. Heary, Frederick, Heary Bros. Lightning Protection Co. Inc., "Personal Communication", 3-3-99.
154. Heary, K.P., A. Z. Chaberski, S. Gumley, J. R. Gumley, F. Richens, J. H. Moran, "An Experimental Study of Ionizing Air Terminal Performance", IEEE/PES 88SM 572-0, Portland, OR, 7-24-29-88.
155. Heary, K. P., A. Z. Chaberski, S. Gumley, J. R. Gumley, F. Richens, J. H. Moran, "An Experimental Study of Air Terminal Performance as a Function of Geometric Shapes", The France-Japan Workshop on Lightning, Deauville, 7-17-21-89.
156. Heary, Kenneth P., United States Patent, Patent Number Des 305.104, Lightning Arrestor, 12-19-89.
157. Heary, Kenneth P., Lightning Preventor of America Inc., Deposition in U.S. District court, State of New York, Erie County, 9-30-93.
158. Heary, K. P., A. Z. Chaberski, F. Richens, J. H. Moran, "An Experimental Study of Corona-Ion Current of Air Terminals", Proceedings of the 2nd. International Conference on Applies Electrostatics Beijing, 11-4-7-93, pp. 349-354.
159. Heary, K. P., Heary Bros. Lightning Protection Co. Inc., "781 Ballot to Andrew J. O'Connor", Chair 781, 12-6-93.

160. Heary, K. P., A. Z. Chaberski, F. Richens, J. H. Moran, "Early Streamer Emission Enhanced Air Terminal Performance and Zone of Protection", IEEE Industrial Applications society, 1993, pp. 26-32.
161. Heary, Kenneth P., Heary Bros. Lightning Protection Co. Inc., "Personal Communication to George Miller", NFPA 3-22-94.
162. Heary, K. P.; A. Z. Chaberski, W. E. Heary, "An Experimental Study of Early Streamer Emission Air Terminals", 4th. Middle East Power Systems Conference, Egypt, 1-3-5-96.
163. Heary, K. P., A. Z. Chaberski, W. E. Heary, "Experimental Determination of Lightning Propagation Velocity at Low Altitude", 3rd. International Conference on Applied Electrostatics, Shanghai, 11-14-16-97.
164. Helita, Pulsar The Early Streamer Emission Lightning Conductor.
165. Hutzler, B., "Lightning Simulation", Electricite De France.
166. IEMN, High Voltage Laboratory Prevetron E.S.E. System Tests to French Safety Standard NFC 17-102, 7-25-96.
167. Inchcape Testing Services, Certificate of Conformance to Lightning Preventor of America Inc. for Their Lightning Protection System Installation Which Conforms With NFPA 781 (Proposed) 1994 edition, Chapter 4, (13 Installations) 4-18-96 to 9-26-97.
168. Indelec Lightning Protection, Prevetron 2, Douvai, France.
169. Indelec, "U.M.I.S.T. The Point, What's Wrong With UMIST's Test Report on E.S.E. Lightning Conductors?"
170. Indelec, "Early Streamer Emission Lightning Conductor Prevetron 2".
171. Indelec, "List of National Standards on E.S.E. Systems".
172. Indelec, "1996 On-Site Test Campaign", St. Privat d'Allier Lightning Station, 1996.
173. Joseph, Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication & Papers to NFPA Standards Council", 9-30-93.
174. Joesph Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication to John Barry", NFPA, 11-19-93.
175. Joseph Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication to Maureen Brodoff", NFPA, 12-6-93.
176. Joseph, Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication to NFPA Standards Council", 12-7-93.
177. Joseph, Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication to Art Cote", NFPA, 2-1-94.

178. Joseph, Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication & Papers to NFPA Board of Directors", 2-8-94.
179. Joseph, Linda H., Jaeckle, Fleischmann & Mugel, "Personal Communication to Art Cote", NFPA, 2-1-94.
180. Joseph, Linda H., Buchanan Ingersoll, "Personal Communication, Papers & CD Rom", 2-27-99.
181. Joseph, Linda H., Buchanan Ingersoll, Position Paper on Scientific and Technical Support for The Issuance of an NFPA Standard for ESE Lightning Protection systems, 2-27-99.
182. Joseph, Linda H., Buchanan Ingersoll, Position Paper Evaluating consensus Submissions Pro and Con for Issuance of an NFPA Standard for ESE Lightning Protection Systems, 2-27-99.
183. Kaiser, Bruce B., Lightning Master Corp., "781 Ballot to Andrew J. O'Connor", Chair 781, 12-4-93.
184. Kaiser, Bruce B., Lightning Master Corp., "Personal Communication to Mr. & Mrs. James Fritsch", 1-10-94.
185. Kithil, Richard, National Lightning Safety Institute, "Personal Communication", 10-28-98.
186. Kithil, Richard, National Lightning Safety Institute, "Personal Communication & Papers", 1-20-99.
187. Krasno, Daniel S., Robert L. Bear, W. Ronald Woods, Law Engineering, "Proposal for Preliminary Air Monitoring Dolphin and Swan Hotels to John Labruzzo", Tishman Hotel Corp., 10-6-92.
188. Kuwabara, Nobuo, Tetsuya Tominaga, Masaru Kanazawa and Shoich Kuramoto, "Probability Occurrence of Estimated Lightning Surge Current at Lightning Rod Before and After Installing Dissipation Array System (DAS)", Proceedings of The 1998 IEEE Conference on Electromagnetic Compatibility, pp. 1072-1077.
189. Laboratoire Haute-Tension, Test of Atmospheric High Pulse Voltage Lightning Conductor.
190. Labruzzo, John, Tishman Hotel Corp., "Personal Communication to Bud Dare", Walt Disney World, 10-29-92.
191. Langmuir Laboratory, New Mexico Tech., Lightning Rods, Socorro, NM, 2-15-99.
192. Lalonde, P., A. Bondion-Clergerie, P. Laroche, G. L. Bacchiega, A. Bonamy, I. Gallimberti, A. Eybert-Berard, J. P. Berlands, B. Bador, Modeling of The Lightning Connection Process to a Ground Structure.
193. Larson, Bruce, Larson Lightning Protection, "Personal Communication to Art Cote", NFPA, 10-15-93.
194. LEC Inc., Spline Ball Ionizer, Boulder, 12-98.

195. LeFort, Armand, Indelec, "Personal Communication to Arthur E. Cote", NFPA, 12-10-93.
196. LeFort, Armand, Indelec, "Personal Communication to George D. Miller", NFPA, 3-21-94.
197. Leforet, Armand, Indelec, "Personal Communication & Papers", 2-22-99..
198. Leite, D. M., Experience of Radioactive Lightning Aerials in Field and in Laboratories.
199. Leite, Duillo Moreira, "The Brazilian Experience With Radioactive Rods", Universidade De Sao Paulo, 1-9-95.
200. Les Renardieres Group, "Negative Discharges in Long Air Gaps at Les Renardieres-1978 Results", Electra, No. 74, 1-81.
201. Liew, Ah Choy, National University of Singapore, "Personal Communication", 2-11-99.
202. Lightning Eliminators and Consultants Inc., Dissipation Array System, 7-97.
203. Lightning Master Corp., Lightning Master is Spreading The Word...Strike Back at Lightning Damage.
204. Lightning Preventor of America Inc., Heary Bros. Lightning Protection Co. Inc., An International Standard Ionizing Air Terminal Lightning Protection Standard, 1988.
205. Lightning Preventor of America Inc., Preventor Safety Ensured.
206. Lightning Preventor of America Inc., One Lightning Preventor.
207. Lightning Preventor of America Inc., A Rebuttal to: "Comparison of Corona Current - 2/11/91" and "Study of Lightning Strikes-11/8/91.
208. Lightning Prevention Systems, Lightning Prevention Systems Inc. ALS-1000.
209. Lightning Prevention Systems, Installation Instructions for The ALS-3000 Lightning Prevention System.
210. Lightning Prevention Systems, "How to protect Your Home From Lightning, Berlin, NJ, 1994.
211. Lightning Protection International, System 3000 Advanced Integrated Lightning Protection. Hobart, Australia, 1988.
212. Lightning Protection International, Protection of Industrial and communications Equipment. Hobart, Australia, 4-90.
213. Lightning Protection International, Airport Lightning Protection.
214. Lightning Protection International, LCI Interceptor, Hobart, Australia.

215. Lobnitz, Edward A., "781 Ballot to Andrew J. O'Connor", Chair 781, 12-15-93.
216. Lockwood, Jonathan S., "Personal Communication", 2-26-99.
217. Mackerras, D., M. Darveniza, Ah Choy Liew, "Standard and Non-Standard Lightning Interception Methods", Symposium on Non-Conventional Methods of Lightning Protection, College of Electrical Engineers, Institution of Engineers, Australia, Sydney, 10-24-86.
218. Mackerras, D., M. Darveniza, and A.C. Liew, "Standard and Non-Standard Lightning Protection Methods", Journal of Electrical and Electronics Engineering Australia, Vol. 2, No. 2, June 1987.
219. Mackerras, D., M. Darveniza and A.C. Liew, "Review of Claimed Enhanced Lightning Protection of Buildings by Early Stream Emission Air Terminals", IEE Proceedings - Science Measurement Technology, Vol. 144, No.1, 1-97, pp. 1-10.
220. Mackerras, D., M. Darveniza and A.C. Liew, "Standard and Non-Standard Lightning Protection Methods", Journal of Electrical and Electronics Engineering Australia, Vol. 7, No. 7.
221. Mackerras, D. and M. Darveniza, University of Queensland, "Personal Communication & Papers", 2-24-99.
222. Maicas, J., "781 Ballot to Andrew J. O'Connor", Chair 781, 12-14-93.
223. Masic, Barbara A., IRS, Application and Affidavit, U. S. District Court, Western district of New York, 8-17-93.
224. Masetti, C., Comitato Electrotecnico Italiano, "Personal Communication", 2-25-99.
225. Matias, Cornelio, Melisa Materiales Electricos Industriales, S.A., "Personal Communication", 1-13-99.
226. Mazen, Absel-Salam, Umar Saleh Al-Abdul-Latif, "Simulation of Energized Franklin Rods for Lightning Protection", IEEE Transactions on Industry Applications, Vol. 33, No. 3, 5-6-97, pp. 651-659.
227. Mazzetti, Carlo and Zdobyslaw Flisowski, Universita Delgli Studi Di Roma "Lasapienza", "Personal Communication", 2-22-99.
228. McAfee, D. E., "Personal Communication & 781 Ballot to Andrew J. O'Connor", Chair 781, 12-8-93.
229. McAfee, D. E., "personal communication to Andrew J. O'Connor", Chair 781, 1-27-94.
230. McIvor, Scott D., Roy B. Carpenter, Jr. and Mark M. Drabkin, Evaluation of Early Streamer Air Terminals.
231. McKeever, Robert, Affidavit, Buffalo, NY, 2-26-99.

232. Menemenlis, Christos, Patras University, Greece, "Personal Communication", 2-25-99.
233. Mercure, Hubert, Hydro Quebec, "Personal Communication", 2-17-99.
234. Metton, Mike, Georgia Speciality Constructors Inc., "Personal Communication-Petition", 1-28-99.
235. Miller, George D., NFPA, "Personal Communication to Kenneth P. Heary", Lightning Preventor of America Inc., 4-4-94.
236. Montandon, Eric, Consultant-Switzerland, "Personal Communication & Papers", 2-16-99.
237. Moore, C. B., "Improved Configurations of Lightning Rods and Air Terminals", Journal of The Franklin Institute, Vol. 315, No. 1, 1-83.
238. Moore, Charles B., New Mexico Tech., Resume, 8-17-90.
239. Moore, Charles B., New Mexico Tech., "Personal Communication Diagrams & Photos to Alan P. Steffes", Thompson Lightning Protection Inc., 9-23-93.
240. Moore, Charles B., Preliminary Report on The 1993 Exposure of The Indelec Prevector and The Lightning Preventor of America Air Terminals on South Baldy Peak in New Mexico, New Mexico Tech, Langmuir Laboratory for Atmospheric Research, Socorro, NM, 9-23-93.
241. Moore, Charles B., New Mexico Tech., "Personal Communication to Conrad R. Kindsfather", 12-20-93.
242. Moore, Charles B., New Mexico Tech., "Personal Communication to NFPA Standards Council", 6-10-95.
243. Moore, Charles B., New Mexico Tech., "Personal Communication to Subcommittee of NFPA Board of Directors", 9-4-95.
244. Moore, C. B., William Rison and James Mathis, Lightning Rods and The Electric Fields Required for Propagation of Positive Discharges in Air, New Mexico Tech., Langmuir Laboratory for Atmospheric Research, Socorro, NM, 11-29-97.
245. Moore, C. B., William Rison, James Mathis and Gordon Aulich, Lightning Rod Design Considerations, New Mexico Tech., Langmuir Laboratory for Atmospheric Research, Socorro, NM, 2-28-98.
246. Moore, C. B., Professor Emeritus, Measurements of The Responses of a "Preventor" to Nearby Lightning, New Mexico Tech., Langmuir Laboratory for Atmospheric Research, Socorro, NM, 11-11-98.
247. Moore, Charles B., Deposition U.S. District Court, District of Arizona, pp. 128-135, 152-159, 188-191, Exhibits 15, 16, 19, 20, 29, 30, 34, 11-17-98.

248. Moore, C. B., William Rison, and G. D. Aulich, An Assessment of The Radioactive "Preventor" as an Early Streamer Emitting Lightning Protector, New Mexico Tech., Langmuir Laboratory for Atmospheric Research, Socorro, NM, 12-29-98.
249. Moore, Charles B., New Mexico Tech., "Personal Communication, Papers & Photos", 2-16-99.
250. Moran, John H., Jr., Deposition in U. S. District Court, Western district of New York, pp. 1-7, 12-18-91.
251. Moran, John H., Jr., Resume, 7-89.
252. Morgan, Jon, "Ravens' Defensive Plans Include Lightning", The Baltimore sun, 6-20-98, pp. 1D, 7D.
253. Mousa, Abdul M., British Columbia Hydro, "Additional References on Early Streamer Emission Lightning Rods for Use in the NFPA Research Project", 10-94.
254. Mousa, Abdul M., British Columbia Hydro, "Effectiveness of Early Streamer Emission Lightning Rods".
255. Mousa, Abdul M., British Columbia Hydro, "Beyond The NIST Review-Early Streamer Lightning Rods and The Proposed NFPA Standard 781", submitted to NFPA Standards Council, 7-18-95.
256. Mousa, Abdul M., "The Applicability of Lightning Elimination Devices to Substations and Power Lines", IEEE Transactions on Power Delivery, Vol. 13, No. 4, 10-98, pp. 1120-1127.
257. Mousa Abdul M., British Columbia Hydro, "Personal Communication to Donald W. Zipse", 1-22-99.
258. Mousa, Abdul M., British Columbia Hydro, "Personal Communication", 3-1-99.
259. Mousa, Abdul M., British Columbia Hydro, "Personal Communication", 3-10-99.
260. Munn, J. Knox, Commercial Insurance Concepts Inc., "Personal Communication to Bob Rapp", National. Lightning Protection Corp., 4-22-97.
261. Munn, J. Knox, Commercial Insurance Concepts Inc., "Personal Communication to Paul Resler, 3-1-99.
262. Nagy, James, Jr., Deposition, U.S. District Court, Western District of New York, pp. 4-8, 21-23, 49, 2-26-93.
263. NFPA, Standard Council Minutes, Quincy, MA, 7- 9-11-86, pp. 4, 7-8.
264. NFPA, Standard Council Minutes, Washington, D.C., 4-14-15-88, pp. 10-13.
265. NFPA, Standard Council Minutes, Asheville, NC, 4-6-7-89, pp. 3-4.

266. NFPA, Transcript of Standards Council Hearing, "The Creation of a New Standard for Lightning Protection and a New Technical Committee", Incline Village, NV, 4-24-90, pp. 1-47.
267. NFPA, Decision of The Standards Council, "The Request of Lightning Preventor of America Inc. and Heary Bros. Lightning Protection co. Inc.", Incline Village, NV, 4-24-90.
268. NFPA, Standard Council Minutes, Incline Village, NV, 4-24-25-90, pp. 9-10.
269. NFPA, Standard Council Minutes, Halifax, NS, 7-18-20-90, p. 6.
270. NFPA, Standard Council Minutes, Baltimore, MD, 10-9-10-90, p. 4.
271. NFPA, Standard Council Minutes, San Francisco, CA, 4-11-12-91, p. 2.
272. NFPA, Standard Council Minutes, Charleston, SC, 10-3-4-91, p. 2.
273. NFPA, Transcript of Technical Report Session, "NFPA 78", New Orleans, LA, 5-21-92, pp. 54-55.
274. NFPA, Transcript of Standard council Hearing, "NFPA 781", Kansas City, MO, 10-14-93, pp. 1-52.
275. NFPA, Decision of Standards Council Hearing, "NFPA 781", Kansas City, MO, 10-14-93, p. 1.
276. NFPA, Transcript of Technical Committee Report Session, "NFPA 781", Phoenix, AZ, 11-18-93, pp. 15-47.
277. NFPA, 1993 Fall Meeting Technical Committee Documentation (Comments), Phoenix, AZ, 11-15-18-93, pp. 419-494.
278. NFPA, 1993 Fall Meeting Technical Committee Reports (Proposals), Phoenix, AZ, 11-15-18-93, pp. 576-597.
279. NFPA, Transcript of Standards Council Hearing, "NFPA 781", Sanibel, FL, 1-12-94, pp. 1-44.
280. NFPA, Decision of Standards Council Hearing, "NFPA 781", Sanibel, FL, 1-12-94, p. 1.
281. NFPA, Decision of The Board of Directors, "The Appeal Regarding Proposed NFPA 781", Quincy, MA, 4-29-94, pp. 1-2.
282. NFPA, Transcript of Technical Committee Report Session, "NFPA 780", Denver, CO, 5-24-95, pp. 67-73.
283. NFPA, 1995 Annual Meeting Report on Comments, Denver, CO, 5-22-25-95, pp. 67-79.
284. NFPA, 1995 Annual Meeting Report on Proposals, Denver, CO, 5-22-25-95, pp. 185-198.

285. NFPA, Transcript of Standards Council Hearing, "NFPA 781", Quincy, MA, 7-18-95, pp. 1-139.
286. NFPA, Transcript of Standards Council Hearing, "NFPA 780", Quincy, MA, 7-18-95, pp. 139-221.
287. NFPA, Decision of The Standards Council, "The Issuance of Proposed NFPA 781", Quincy, MA, 7-18-95, pp. 1-5.
288. NFPA, Decision of The Standards Council, "The Withdrawal of NFPA 780", Quincy, MA, 7-18-95, pp. 1-4.
289. NFPA, Decision of The Board of Directors, "Appeal of NFPA 781", Quincy, MA, 12-7-95, pp. 1-4.
290. NFPA, Decision of The Board of Directors, "Appeal of NFPA 780", Quincy, MA, 12-7-95, pp. 1-3.
291. NFPA, Transcript of Technical Committee Technical Report Session, Los Angeles, CA, 5-21-97, pp. 29-31.
292. NFPA, 1997 Annual Meeting Report on Comments, Los Angeles, CA, 5-19-22-97, pp. 134-137.
293. NFPA, 1997 Annual Meeting Report on Proposals, Los Angeles, CA, 5-19-22-97, pp. 92-121.
294. NFPA, NFPA 780 Standard for The Installation of Lightning Protection Systems, Quincy, MA, 1997.
295. NFPA, Transcript of The Standards Council Hearing, "NFPA 781", West Point, NY, 10-8-98, pp. 1-28.
296. NFPA, Decision of The Standards Council, "NFPA 781", West Point, NY, 10-8-98, p. 1.
297. NFPA, Agreement of Settlement and Release, "ESE Lightning Protection Systems", West Point, NY, 10-8-98, pp. 1-8.
298. NFPA, National Fire Protection Association 1999 Directory, Quincy, MA, 11-98.
299. National Lightning Protection Corp., Early Streamer Emission (ESE) Lightning Protection Air Terminal Field Tests & Analysis.
300. National lightning Protection Corp., Indelec Background.
301. National Lightning Protection Corp., Prevelectron "Standard".
302. National Lightning Protection Corp., Indelec Since 1956.
303. National Lightning Protection Corp., Patented Ionizing Lightning Protection.

304. Nelson, Harold E., Hughes Associates, "Personal Communication to Art Cote", NFPA, 1-5-94.
305. Ng, Aik Huat, Public Works Department-Singapore, "Personal Communication to Barry Buckley", Lightning Protection International.
306. Noack, Ingl, Habil F. Noack, "Personal Communication", 3-3-99.
307. Nucci, Gario Alberto, Universita Deglistudi Di Bologna, "Personal Communication", 2-28-99.
308. O'Connor, Andrew J., Chair 781, "Personal Communication to NFPA Standards Council", 10-4-93.
309. O'Connor, Andrew J., Chair 781, "Personal Communication & Attachment to NFPA 781 Committee Members", 11-24-93.
310. O'Connor, Andrew J., Chair 781, "Record of 781 Ballot", 12-15-93.
311. O'Connor, Andrew J., Chair 781, "Personal Communication to NFPA 781 Committee Members", 12-16-93.
312. Pederson, Aage, A. Bondiv-Clargerie, V. Cooray and L. Deller, "Lightning Threat and Protection in Perspective", International Conference on Lightning Protection, ICLP, Birmingham, 9-98, pp. 1-10.
313. Pederson, Aage, Gentofte, Denmark, "Personal Communication", 2-18-99.
314. Pederson, Aage, Gentofte, Denmark, "Personal Communication", 2-21-99.
315. Petrov, N. I. and R. T. Waters, "Determination of The Striking Distance of Lightning to Earthed Structures", Proceedings of Royal Society, London, Vol. A450, 1995, pp. 589-601.
316. Petrov, N. I. and R. T. Waters, "Striking Distance of Lightning to Earthed Structures: Effect of Structure Geometry", International Symposium on High Voltage Engineering, IEE, London, 8-98.
317. Petrov, N. I. and R. T. Waters, "Striking Distance to Earthed Structures; Stroke Polarity", International Symposium on High Voltage Engineering, IEE, London, 8-98.
318. Podgorski, Andrew, National Research Council of Canada, "Personal Communication & Statement of Work to NFPA", 7-12-91.
319. Popolansky, E., EGU-Power Institute Brno, "Personal Communication", 3-1-99.
320. Porrin, Adalberto, Emillo Garbagnati, Marina Bernardi, CESI, Italy, "Personal Communication", 2-26-99.
321. Portfleet, Terrance, Michigan Lightning Protection Inc., "Personal Communication", 2-25-99.
322. Priestley, Will, Priestley Lightning Protection, "Personal Communication", 2-23-99.

323. Rapp, R. W., National Lightning Protection Corp., "Personal Communication to NFPA Standards Council", 1-12-93.
324. Rapp, R. W., National Lightning Protection Corp. "781 Ballot to Andrew J. O'Connor", Chair 781, 12-14-93.
325. Rapp, R. W., National Lightning Protection Corp., "Personal Communication to George D. Miller", NFPA, 3-15-94.
326. Rapp, R. W., National Lightning Protection Corp., "Personal Communication to NFPA Board of Directors", 3-21-94.
327. Rapp, R. W. National Lightning Protection Corp., "Personal Communication & Papers", 2-26-99.
328. Richardson, Robert A., Reynolds, Smith & Hills Inc., "Personal Communication to NFPA Standards Council", 9-29-93.
329. Richardson, Robert A., Reynolds, Smith & Hills Inc., "Personal Communication & 781 Ballot to Andrew J. O'Connor", Chair 781, 12-13-93.
330. Richardson, Robert A., Reynolds, Smith & Hills Inc., "Personal Communication to Leona Nesbit", NFPA, 12-17-93.
331. Richardson, Robert A., Reynolds, Smith & Hills Inc., "Personal Communication to George Miller", NFPA, 3-22-94.
332. Richardson, Robert A., Reynolds, Smith & Hills Inc., "Personal Communication", 2-26-99.
333. Riley, Tony A., Advanced Lightning Technology Inc., "Personal Communication & Papers", 2-24-99.
334. Rison, William, New Mexico Tech., Resume, 1988.
335. Rison, William, A Comparison of The Corona Current From a Radioactive and Non-Radioactive Preventor, Langmuir Laboratory, New Mexico Tech., Socorro, NM, 2-11-91.
336. Rison, William, A Study of Lightning Strikes in The Vicinity of a Radioactive Preventor, Langmuir Laboratory, New Mexico Tech., Socorro, NM, 11-8-91.
337. Rison, W., C. B. Moore, J. Mathis and G. D. Aulich, "Comparative Tests of Sharp and Blunt Lightning Rods", Birmingham, 24th. International conference on Lightning Protection, 9-14-18-98.
338. Rison, William, New Mexico Tech., "Personal Communication", 2-22-99.
339. Rood, Alicia, Affidavit, 2-26-99.
340. Rousseau, alain, Erico, "Personal Communication", 1-3-99.
341. Russell, Timothy E., "Personal Communication & 781 Ballot to Andrew J. O'Connor", Chair 781, 12-2-93.