

553.885 Carbon monoxide alarm required.—

(1) Every separate building or addition to an existing building, other than a hospital, an inpatient hospice facility, or a nursing home facility licensed by the Agency for Health Care Administration, constructed on or after July 1, 2008, and having a fossil-fuel-burning heater or appliance, a fireplace, an attached garage, or other feature, fixture, or element that emits carbon monoxide as a byproduct of combustion shall have an approved operational carbon monoxide alarm installed within 10 feet of each room used for sleeping purposes in the new building or addition, or at such other locations as required by the Florida Building Code. The requirements of this subsection may be satisfied with the installation of a hard-wired or battery-powered carbon monoxide alarm or a hard-wired or battery-powered combination carbon monoxide and smoke alarm. **For a new hospital, an inpatient hospice facility, a nursing home facility licensed by the Agency for Health Care Administration, or a new state correctional institution, an approved operational carbon monoxide detector shall be installed inside or directly outside of each room or area within the hospital or facility where a fossil-fuel-burning heater, engine, or appliance is located. This detector shall be connected to the fire alarm system of the hospital or facility as a supervisory signal.** This subsection does not apply to existing buildings that are undergoing alterations or repairs unless the alteration is an addition as defined in subsection (3).