

ACCESSIBILITY ADVISORY COUNCIL

GROUNDS FOR APPROVAL

- **Economic Hardship**
 - Does the cost of providing vertical accessibility meet or exceed 20% of the cost of the alteration to the primary function area?
 - If the 20% threshold is met, the waiver SHALL be granted.
 - Does not apply to new construction.

- **Historic Nature**
 - Has the applicant provided documentation of the historic significance of the building?
 - Would the historic significance of the structure be negatively impacted by the alterations applicant would have to make to provide accessibility?
 - Can be combined with Technical Infeasibility or Economic Hardship

- **Technical Infeasibility**
 - Is the structure built in a way that would otherwise place unnecessary, unreasonable, or extreme hardship on the applicant, if they were required to provide accessibility?
 - Has the applicant provided comments from a licensed design professional?
 - Would have to rebuild, demolish, encroach on property lines, etc.

ACCESSIBILITY ADVISORY COUNCIL

Peter Rogers - WAV # 294

Issue: Toilet rooms.

Project Type:

Project Progress: In Plan Review

Compliance estimate + Amount spent on accessible features: \$25,000

Project Construction Cost + Construction Cost Over Past 3 Years: \$0

Analysis:

The applicant is requesting a waiver from providing the size requirement of toilet rooms for a restaurant with 2,160 square feet. The Applicant is not doing any work to the building. Marion county planning department will not issue a certificate of Occupancy to open a small Pizza restaurant, due to the size of the existing bathrooms that are 54"X54". If the bathrooms have to be expanded the HVAC and electrical will also have to be moved. The building has always been a small sports grill and has had the same owner for 30 years. They submitted an estimate of \$25,000.00 to bring the restrooms up to code.

Uploaded Documents:

1. Plans/Pictures

STAFF RECOMMENDATION:

Note-

Based on staff discussion with the building official, the project in question is a change of use from a thrift store to a restaurant and the trigger for the upgrade to the restroom facility is the plumbing code.

Staff recommends denial of the waiver application on the basis that the Commission has no authority to waive the code requirement of the FBC, Plumbing.

Items to be waived:

Vertical accessibility to the structure, as required by section 553.509, Florida Statutes.

553.509 Vertical accessibility. This part and the Americans with Disabilities Act Standards for Accessible Design do not relieve the owner of any building, structure, or facility

ACCESSIBILITY ADVISORY COUNCIL

governed by this part from the duty to provide vertical accessibility to all levels above and below the occupiable grade level, regardless of whether the standards require an elevator to be installed in such building, structure, or facility, except for:

- (a) Elevator pits, elevator penthouses, mechanical rooms, piping or equipment catwalks and automobile lubrication and maintenance pits and platforms;
 - (b) Unoccupiable spaces, such as rooms, enclosed spaces and storage spaces that are not designed for human occupancy, for public accommodations or for work areas; and
 - (c) Occupiable spaces and rooms that are not open to the public and that house no more than five persons, including, but not limited to equipment control rooms and projection booths.
 - (d) Theaters, concert halls, and stadiums, or other large assembly areas that have stadium-style seating or tiered seating if ss. 221 and 802 of the standards are met.
 - (e) All play and recreation areas if the requirements of chapter 10 of the standards are met.
 - (f) All employee areas as exempted in s. 203.9 of the standards.
 - (g) Facilities, sites, and spaces exempted by s. 203 of the standards.
- (2) However, buildings, structures, and facilities must, as a minimum, comply with the Americans with Disabilities Act Standards for Accessible Design.

206.2.4 Spaces and Elements. At least one accessible route shall connect accessible building or facility entrances with all accessible spaces and elements within the building or facility which are otherwise connected by a circulation path unless exempted by 206.2.3 Exceptions 1 through 7.

402.2 Components Accessible routes shall consist of one or more of the following components: Walking surfaces with a running slope not steeper than 1:20, doorways, ramps, curb ramps excluding the flared sides, elevators, and platform lifts. All components of an accessible route shall comply with the applicable requirements of Chapter 4 and 208.3.1.

Waiver Criteria: There is no specific guidance for a waiver of this requirement in the code. The Commission's current rule, authorized in Section 553.512, Florida Statutes, provides criteria for granting waivers and allows consideration of unnecessary or extreme hardship to the Applicant if the specific requirements were imposed.

MOTIONS

ACCESSIBILITY ADVISORY COUNCIL

- I move to recommend that the Florida Building Commission approve this request for waiver on the grounds of _____.
 - Economic Hardship
 - Historic Nature
 - Technical Infeasibility

- I move to recommend that the Florida Building Commission deny this application.
 - No rationale necessary.

- I move to recommend that the Florida Building Commission defer this request for waiver to the next meetings of the Council and the Commission for the purpose of allowing the applicant to _____:
 - Submit requested information
 - Contact building official or building department
 - Etc.