



1920 Corporate Drive
 Boynton Beach, FL 33426
 Office: (561) 742-0068
 Fax: (561) 742-0069

Amendment
 DCA07-DEC-065
 FILING AND ACKNOWLEDGEMENT
 FILED, on this date, with the designated
 Clerk, receipt of which is hereby
 acknowledged.
Paula P. Ford 4/11/07
 Paula P. Ford
 Commission Clerk

Fax Cover Letter

To: E.J. WOZNIAK	From: ANDREW JOHNSTON
Fax Number: 18504148436	Pages: 1 (Including Cover Sheet)
Date: 4/6/07	RE:
cc:	E-mail:

Urgent ___ **For Your Review** ___ **Reply ASAP** ___ **Please Comment** ___

Attn: Florida Building Commission

An Amendment to DCA07-DEC-065

Code: Building

Section: EB: 505.1

In the matter of 505.1, our company has encountered this difference of interpretation, for building code 505.1, on more than one occasion. With that said it is our intent to include, or be able to use, this declaratory statement at any Municipal Building Department that may have this difference of interpretation.

Here is an example of what we come across:

Home owner Joe Schmoe wants to have his windows replaced with impact. All of his bed room windows are single hung windows with measurements (26" X 37"). Because of Joes strict guidelines set by his Home Owners Association he is not allowed to replace his windows with a different series (example, casement window).

Obviously the (26" X 37") window does not meet current egress requirements.

Question: is this home owner not entitled to have his windows replaced without making the window opening size bigger because his house was built in 1980.

This is one of the many predicaments our company comes across due to the misinterpretation of this code.

Thank you for your time in this matter,

Andrew Johnston
 Harbor Home Improvements



1920 Corporate Drive
 Boynton Beach, FL 33426
 Office: (561) 742-0068
 Fax: (561) 742-0069

DCR07-DEC-065
 FILING AND ACKNOWLEDGEMENT
 FILED, on this date, with the designated
 Agency Clerk, receipt of which is hereby
 acknowledged.

Miriam Snipes 4/2/07
 Miriam Snipes Date
 Deputy Agency Clerk

Fax Cover Letter

To: FLORIDA BUILDING	From: ANDREW JOHNSTON
Fax Number: 18504148436	Pages: 1 (Including Cover Sheet)
Date: 3/27/07	RE:
cc:	E-mail:

Urgent ___ **For Your Review** ___ **Reply ASAP** ___ **Please Comment** ___

Attn: Florida Building Commission.

In the Matter of Harbor Home Improvements Vs City of Boynton Beach

Code: Building

Section: EB 505.1

Our company has replaced windows in a residential house in the City of Boynton Beach. It was to our understanding that when doing a level 1 restoration (replacing windows), that the opening sizes at the time of the buildings original permit are acceptable. At the time of our final inspection the Boynton Beach Building inspector failed us for not having the windows in the bedrooms brought up to current egress.

So the question at hand is, is it the intent of section 505.1 FBC- existing buildings, to allow the contracting company to use the original window sizes when replacing windows without having to bring the windows up to current egress requirement?

Please Review This matter and provide us with a Declaratory Statement.
 Feel free to call me at our office or my cell phone 561-706-3399 ↔

Andrew Johnston
 Permitting Manager