

Florida Building Code 2010

Chapter 9 Fire Protection Systems

Quiz

1. Provided a modification to a fire protection system is small, no approval is needed by the building or fire official
 - a. True
 - b. False

2. Every automatic sprinkler system must be monitored except
 - a. One and two family dwellings
 - b. Systems with fewer than 6 sprinkler heads
 - c. Jurisdictions that do not require Central Station Service as outlined in NFPA 72
 - d. Both A & B
 - e. All of the Above
 - f. None of the above, they always have to be monitored

3. A system designed to alert individuals of the potential threat from hazardous materials is referred to as a
 - a. Fire alarm system
 - b. Threat level assessment system
 - c. Emergency alarm system
 - d. Class D system

4. A Supervising Station is
 - a. A Central Station as defined in NFPA 72
 - b. A Remote Station as defined in NFPA 72
 - c. A facility that receives signals and at which personnel are in attendance at all times to respond to these signals
 - d. A constantly attended station with trained personnel available to respond immediately to the emergency

5. Which of the following is not a mandatory requirement to be included on shop drawings?
 - a. Battery Calculations
 - b. The name of the Authority Having Jurisdiction
 - c. Floor plans
 - d. Detailed information from manufacturer's data sheets identifying the equipment being installed

6. Because fire alarm designs are dictated by code, they do not have to comply with the guidelines for accessibility.
 - a. True
 - b. False

7. Because of new types of construction and the advent of zoning and zoned reporting, there is no longer a need for any of the fire alarm equipment to be red in color.
 - a. True
 - b. False

8. When a building is fully sprinklered with an approved supervised sprinkler system, there is no requirement for a smoke detector to be installed above the control equipment.
 - a. True
 - b. False
 9. Protective Covers installed on alarm boxes must always be provided with a local annunciator to indicate when the cover has been tampered with or dislodged.
 - a. True
 - b. False
 10. Fire alarm systems required by Chapter 9, or by the Florida Fire Prevention Code must be monitored by an approved Central Station in accordance with NFPA 72
 - a. True
 - b. False
-

Answers

1. B
2. D
3. C
4. C
5. B
6. B
7. B
8. A
9. B
10. B