

1. Exhaust hood sizes can be calculated by square feet in the new code.
 - a. True
 - b. False**
2. Equipment changeouts do not require a permit and inspection.
 - a. True
 - b. False**
3. There are two methods to comply with code, one is prescriptive, what is the other?
 - a. Performance**
 - b. Execution
 - c. Rescriptive
 - d. Fulfillment
4. Cooling equipment sizing must be done by building orientation.
 - a. True**
 - b. False
5. A CO alarm is required in all buildings that have fossil fuel burning heaters, a fireplace, or an attached garage.
 - a. True**
 - b. False
6. CO2 Alarms should be placed within ____ feet of a room used for sleeping purposes.
 - a. 3
 - b. 5
 - c. 13
 - d. 10**
7. The IECC does not give credit for higher efficiency systems.
 - a. True**
 - b. False
8. Piping insulation requirements have been changed in the new code.
 - a. True
 - b. False**
9. Normally, how far can a clothes dryer exhaust system run?
 - a. 14 Feet
 - b. 25 Feet**
 - c. 4 Feet
 - d. 30 Feet
10. How many inches above a roof surface must an exhaust hood be?
 - a. 30
 - b. 40**
 - c. 20
 - d. 10