

**DSE Test Suite Results****Software Name:** EnergyGauge USA v.4.0

User input data fields indicated by pale yellow

Test result fields indicated by pale green

**Results:**

Base Cases	Heat/cool	Fan	Total	% change	
HVAC-3a	837	656	85.94	---	base for cases 3b - 3d
HVAC-3e	5485	968	6453	---	base for cases 3f - 3h

Test Cases	Heat/cool	Fan	Total	% change	Criteria:			Pass/Fail
					max	avg	min	
HVAC-3b	1059	624	108.03	25.7%	31.4%	26.4%	21.4%	pass
HVAC-3c	888	646	91.00	5.9%	12.5%	7.5%	2.5%	pass
HVAC-3d	1020	706	104.41	21.5%	25.0%	20.0%	15.0%	pass
HVAC-3f	7199	1275	8474	31.3%	36.2%	31.2%	26.2%	pass
HVAC-3g	5931	1047	6978	8.1%	16.5%	11.5%	6.5%	pass
HVAC-3h	6881	1206	8087	25.3%	31.1%	26.1%	21.1%	pass

