

WITHDRAWN BY APPLICANT
City of Miami Police Department Marine Patrol WAV #158

Issue: Vertical accessibility to the second floor and toilet rooms.

Analysis: The applicant is requesting a waiver from providing vertical accessibility to the second floor and the two toilet rooms of a Police Department Marine Operations facility built in the 1940's. They are remodeling the interior of the second floor with no structural work with a cost of \$30,000.00. The first floor has a tenant. They submitted a bid of \$63,500 for an elevator and it doesn't include other work needed to install the elevator. Substantial financial costs will be incurred by the owner if the waiver is denied.

Uploaded Documents:

1. Owner Authorization
2. Elevator Quotes
3. Licensed Design Professional: Comments
4. Plans

Project Progress: This project is in plan review and an alteration.

Good Afternoon Chip,

We would like to retract our Application for our Accessibility Waiver.

Please let me know what steps we need to take to do so.

Feel free to give me a call at 305-371-8400.

Thank you.

Best,

Priscilla



PRISCILLA PAGAN

Project Architect

Assoc. AIA

p +1 (305) 371-8400 **w** galvarezstudio.com

a 1428 Brickell Ave, Suite 202, Miami, FL 33131



Items to be waived:

Vertical accessibility to the structure, as required by section 553.509, Florida Statutes.

553.509 Vertical accessibility. This part and the Americans with Disabilities Act Standards for Accessible Design do not relieve the owner of any building, structure, or facility governed by this part from the duty to provide vertical accessibility to all levels above and below the occupiable grade level, regardless of whether the standards require an elevator to be installed in such building, structure, or facility, except for:

- (a) Elevator pits, elevator penthouses, mechanical rooms, piping or equipment catwalks and automobile lubrication and maintenance pits and platforms;
 - (b) Unoccupiable spaces, such as rooms, enclosed spaces and storage spaces that are not designed for human occupancy, for public accommodations or for work areas; and
 - (c) Occupiable spaces and rooms that are not open to the public and that house no more than five persons, including, but not limited to equipment control rooms and projection booths.
 - (d) Theaters, concert halls, and stadiums, or other large assembly areas that have stadium-style seating or tiered seating if ss. 221 and 802 of the standards are met.
 - (e) All play and recreation areas if the requirements of chapter 10 of the standards are met.
 - (f) All employee areas as exempted in s. 203.9 of the standards.
 - (g) Facilities, sites, and spaces exempted by s. 203 of the standards.
- (2) However, buildings, structures, and facilities must, as a minimum, comply with the Americans with Disabilities Act Standards for Accessible Design.

206.2.4 Spaces and Elements. At least one accessible route shall connect accessible building or facility entrances with all accessible spaces and elements within the building or facility which are otherwise connected by a circulation path unless exempted by 206.2.3 Exceptions 1 through 7.

402.2 Components Accessible routes shall consist of one or more of the following components: Walking surfaces with a running slope not steeper than 1:20, doorways, ramps, curb ramps excluding the flared sides, elevators, and platform lifts. All components of an accessible route shall comply with the applicable requirements of Chapter 4 and 208.3.1.

Waiver Criteria: There is no specific guidance for a waiver of this requirement in the code. The Commission's current rule, authorized in Section 553.512, Florida Statutes, provides criteria for granting waivers and allows consideration of unnecessary or extreme hardship to the applicant if the specific requirements were imposed.