

ACCESSIBILITY ADVISORY COUNCIL

GROUNDS FOR APPROVAL

- **Economic Hardship**

- Does the cost of providing vertical accessibility meet or exceed 20% of the cost of the alteration to the primary function area?
- If the 20% threshold is met, the waiver SHALL be granted.
- Does not apply to new construction.
 - Fit-outs/Build-outs are considered new construction

- **Historic Nature**

- Has the applicant provided documentation of the historic significance of the building?
- Would the historic significance of the structure be negatively impacted by the alterations applicant would have to make to provide accessibility?
- Can be combined with Technical Infeasibility or Economic Hardship

- **Technical Infeasibility**

- Is the structure built in a way that would otherwise place unnecessary, unreasonable, or extreme hardship on the applicant, if they were required to provide accessibility?
 - Has the applicant provided comments from a licensed design professional?
 - Would have to rebuild, demolish, encroach on property lines, etc.

ACCESSIBILITY ADVISORY COUNCIL

333 Jefferson Holdings, LLC - WAV # 453

Issue: Vertical accessibility to the second floor.

Project Type: Alteration to an existing building or facility

Project Progress: In Plan Review

Compliance estimate + Amount spent on accessible features: \$533,851+\$82,611 = \$616,462

Project Construction Cost + Construction Cost Over Past 3 Years: \$470,435.30

$$\frac{616,462}{470,435.30} = 131\%$$

Analysis:

The applicant is requesting a waiver from providing vertical accessibility to the second floor of a 2 story hotel. This is a change of use from four apartment buildings to a hotel. The 4 buildings are building 343 - a 2 story building with 2,716 SF and 4 units, building 345 - a 1-story building with 3,123 SF and 6 units, building 337 - a 2 story building with 2,702 SF and 4 units and building 333 - a 2 story building with 3,782 SF and 6 units. The lots for the four buildings are being connected by a unity of title and converted into 20 units with a staffed lobby and a new handicap accessible ramp. The project alteration cost is \$ 470,435.30. The alteration will include a new ramp, new accessible room, structural repairs, new flooring and new plumbing fixtures. Estimates for three elevators were submitted as follows: \$175,223 and \$178,246 for building 333, \$176,755 and 178,246 for building 337 and, \$186,521 and \$181,873 for building 343. The total cost of the three elevators is \$533,851. The Architect stated that the addition of the elevators would significantly alter the structure of the buildings. The buildings are located on a confined site that does not allow for further development due to established setbacks. The applicant alleges that the hardship is caused by a condition or set of conditions affecting the owner which does not affect owners in general and that substantial financial costs will be incurred by the owner if the waiver is denied.

Uploaded Documents:

1. Owner Authorization
2. Construction Cost
3. Cost Estimates For Compliance
4. Project Plans/ Photos
5. Licensed Design Professional Comments

STAFF RECOMMENDATION:

Staff recommends granting the request for waiver for vertical accessibility on the grounds of economic hardship.

ACCESSIBILITY ADVISORY COUNCIL

Items to be waived:

Vertical accessibility to the structure, as required by section 553.509, Florida Statutes.

553.509 Vertical accessibility. This part and the Americans with Disabilities Act Standards for Accessible Design do not relieve the owner of any building, structure, or facility governed by this part from the duty to provide vertical accessibility to all levels above and below the occupiable grade level, regardless of whether the standards require an elevator to be installed in such building, structure, or facility, except for:

- (a) Elevator pits, elevator penthouses, mechanical rooms, piping or equipment catwalks and automobile lubrication and maintenance pits and platforms;
 - (b) Unoccupiable spaces, such as rooms, enclosed spaces and storage spaces that are not designed for human occupancy, for public accommodations or for work areas; and
 - (c) Occupiable spaces and rooms that are not open to the public and that house no more than five persons, including, but not limited to equipment control rooms and projection booths.
 - (d) Theaters, concert halls, and stadiums, or other large assembly areas that have stadium-style seating or tiered seating if ss. 221 and 802 of the standards are met.
 - (e) All play and recreation areas if the requirements of chapter 10 of the standards are met.
 - (f) All employee areas as exempted in s. 203.9 of the standards.
 - (g) Facilities, sites, and spaces exempted by s. 203 of the standards.
- (2) However, buildings, structures, and facilities must, as a minimum, comply with the Americans with Disabilities Act Standards for Accessible Design.

206.2.4 Spaces and Elements. At least one accessible route shall connect accessible building or facility entrances with all accessible spaces and elements within the building or facility which are otherwise connected by a circulation path unless exempted by 206.2.3 Exceptions 1 through 7.

402.2 Components Accessible routes shall consist of one or more of the following components: Walking surfaces with a running slope not steeper than 1:20, doorways, ramps, curb ramps excluding the flared sides, elevators, and platform lifts. All components of an accessible route shall comply with the applicable requirements of Chapter 4 and 208.3.1.

Waiver Criteria: There is no specific guidance for a waiver of this requirement in the code. The Commission's current rule, authorized in Section 553.512, Florida Statutes, provides criteria for granting waivers and allows consideration of unnecessary or extreme hardship to the

ACCESSIBILITY ADVISORY COUNCIL

applicant if the specific requirements were imposed.

MOTIONS

- I move to recommend that the Florida Building Commission approve this request for waiver on the grounds of _____.
 - Economic Hardship
 - Historic Nature
 - Technical Infeasibility

- I move to recommend that the Florida Building Commission deny this application.
 - No rationale necessary.

- I move to recommend that the Florida Building Commission defer this request for waiver to the next meetings of the Council and the Commission for the purpose of allowing the applicant to _____:
 - Submit requested information
 - Contact building official or building department
 - Etc.