



Official Response

June 11, 2018

Al Salem
Albert Salem and Associates, PA
4600 W Kennedy Blvd., Suite 100
Tampa, FL 33609
(813) 286-3000

SUBJECT: Vertical Accessibility Requirements 553.501-553.513, F.S (The Park Apartments Re-Construction of Building # 1)

Per Florida Building Code Sixth Edition (2017) Accessibility section 201.1.1 (Vertical Accessibility Section 553.501-553.513, F.S.) the owner of any building, structure or facility governed by the Florida Statutes to provide vertical accessibility to all levels above and below the occupiable grade level and you are required to provide vertical Accessibility for re-construction of Building # 1 in the Park Apartments Complex. Binding interpretation from Building Official Association of Florida or Florida Building Commission will not be acceptable to City of Temple Terrace. Florida Building Commission could grant you exemption of this requirements, but you must file exemption application and request waiver of this requirements.

Thank you,

Amir Anisi
Community Development Director
Building Official