



City of Miami Beach, 1700 Convention Center Drive, Miami Beach, FL 33139, www.miamibeachfl.gov

Building Department, Administration Services Division
Tel: 305.673.7610, E-mail: ltrigo@miamibeachfl.gov

July 28, 2015

Members of the Florida Building Commission & Accessibility Advisory Council
Office of Codes & Standards, Florida Department of Community Affairs
1940 North Monroe Street
Tallahassee, Florida 32399-2100

RE: 8118 Harding Avenue- Permlt #B1501480
WAVR#91-R0

Dear Members of the Florida Building Commission & Accessibility Advisory Council,

This project consists of a structure that is designated as contributing to the National Historic District.

Pursuant to Florida Statutes 553.509 Vertical Accessibility and the Florida Building Code 2010, Accessibility - Section 201.1.1, vertical accessibility shall be provided to all levels above and below the occupiable grade level. In order to achieve compliance, the owner will incur disproportionate financial costs and the construction will affect the historic nature of the property. However, the proposed renovations will provide a lift in order to gain access to the lobby and ground floor units. In addition, an accessible guest room with all required mobility features as per FBC 2010, Accessibility - Table 224.2 and guestrooms with communication features as per Table 224.4 will also be provided on the ground floor only.

Based on the reasons stated above we recommend that the requested waiver be granted.

Sincerely,

Mariano V. Fernandez, P.E., BU 689
Building Department Director / Building Official