

From: [Green, Jesse](#)
To: [Madani, Mo](#)
Cc: ["FCSchillingjr@att.net"](mailto:FCSchillingjr@att.net)
Subject: Objections to Staff Analysis for Declaratory Statement Request DS2018-066
Date: Tuesday, September 25, 2018 11:45:45 AM
Attachments: [image002.png](#)
[image003.png](#)
[image004.png](#)
[image005.png](#)

Objections to Staff Analysis for Declaratory Statement Request DS2018-066

To the Question, " Does section R403.5.1 state all single family dwelling Must have install hot water recirculation systems?. The Answer is " NO" The requirement of the 6th Edition (2017) Florida Building Code FBC, Energy Conservation do not apply to the project in question. This section is mandatory if a heated water circulation system is installed.

The Objection;

Staffs Analysis gives an arbitrary conclusion of facts not stated or contained in section R403.5.1 of the Energy code as stated above. I do understand the Petitioners request ,this matter is normally left up to the Jurisdiction Having Authority until the next update to the code. I already have Architects stating this section of the energy code is unenforceable referencing this Declaratory Statement, Thereby defeating the Energy saving.

Thank you for your attention in this matter.

Jesse Green , Senior Plumbing & Gas Plans Examiner, Inspector & Medical Gas Inspector
PX3582, BN6575, CFCA22596, PCC049546, ASSE 6020

City of Boca Raton, Development Services Department

200 NW 2 Avenue • Boca Raton, FL 33432

P 561-393-7959 | C 561-239-0356 | jgreen@myboca.us

Stay connected...



Please note: Florida has a very broad public records law. Most written communications to or from local officials regarding city business are public records, and are available to the public and media upon request. Your e-mail communications may therefore be subject to public disclosure. The City of Boca Raton scanned this outbound message for viruses, vandals and malicious content and found this message to be free of such content.