

Staff comments:

- Compliance certificate box should be revised for consistency with Section C103.1.1 of the 6th Edition (2017) Florida Building Code, Energy Conservation
- Compliance report should be revised to provide for specific documentation of the proposed building design energy measures for the applicable building systems (building Envelope, Lighting, HVAC, Service Water Heating...etc.)
- Compliance report should document compliance with the mandatory requirements of Section 11; Energy cost Budget Method of ASHRAE 90.1 – 13.
- Baselines energy measures should be locked and users should not be allowed to edit them.