

Tavern on Tennessee– WAV #104

This application was withdrawn from the October 1st meeting by the Applicant and then asked to reinstate the application.

Issue: Vertical accessibility to the second floor.

Analysis: The applicant is requesting a waiver from providing vertical accessibility to the second floor of a bar and restaurant. The project consists of minor demolition to open up the upper level, and the lower level will only consist of equipment changing and no reconfiguration. In addition, the owner will be modifying the restrooms to be fully accessible on the upper level and the lower level currently has accessible restrooms with an estimated cost of \$38,000. Estimates of \$42,600 and \$43,000 for an elevator were submitted to substantiate financial costs will be incurred by the owner if the waiver is denied.

Project Progress:

This project is an alteration and is under design.

Items to be waived:

Vertical accessibility to the structure, as required by section 553.509, Florida Statutes.

553.509 Vertical accessibility. This part and the Americans with Disabilities Act Standards for Accessible Design do not relieve the owner of any building, structure, or facility governed by this part from the duty to provide vertical accessibility to all levels above and below the occupiable grade level, regardless of whether the standards require an elevator to be installed in such building, structure, or facility, except for:

- (a) Elevator pits, elevator penthouses, mechanical rooms, piping or equipment catwalks and automobile lubrication and maintenance pits and platforms;
 - (b) Unoccupiable spaces, such as rooms, enclosed spaces and storage spaces that are not designed for human occupancy, for public accommodations or for work areas; and
 - (c) Occupiable spaces and rooms that are not open to the public and that house no more than five persons, including, but not limited to equipment control rooms and projection booths.
 - (d) Theaters, concert halls, and stadiums, or other large assembly areas that have stadium-style seating or tiered seating if ss. 221 and 802 of the standards are met.
 - (e) All play and recreation areas if the requirements of chapter 10 of the standards are met.
 - (f) All employee areas as exempted in s. 203.9 of the standards.
 - (g) Facilities, sites, and spaces exempted by s. 203 of the standards.
- (2) However, buildings, structures, and facilities must, as a minimum, comply with the Americans with Disabilities Act Standards for Accessible Design.

206.2.4 Spaces and Elements. At least one accessible route shall connect accessible building or facility entrances with all accessible spaces and elements within the building or facility which are otherwise connected by a circulation path unless exempted by 206.2.3 Exceptions 1 through 7.

402.2 Components Accessible routes shall consist of one or more of the following components: Walking surfaces with a running slope not steeper than 1:20, doorways, ramps, curb ramps excluding the flared sides, elevators, and platform lifts. All components of an accessible route shall comply with the applicable requirements of Chapter 4 and 208.3.1.

Waiver Criteria: There is no specific guidance for a waiver of this requirement in the code. The Commission's current rule, authorized in Section 553.512, Florida Statutes, provides criteria for granting waivers and allows consideration of unnecessary or extreme hardship to the applicant if the specific requirements were imposed.

Hello Chip,

I want to thank you very much for offering to help/assist us in having the Commission reinstate the Vertical Accessibility Waiver that had been previously canceled (Accessibility Waiver #104-0). Unfortunately there was a misunderstanding with the client, which resulted in us canceling the waiver. I understand that the Commission will not meet for another couple of months, but any help reintroducing the application and hopefully avoid additional fees is extremely appreciated. Please let me know if there is anything else you may need from me. Thank you once again for all!

Kindest regards,

David B. Chase

CAD/PM

Conn & Associates Architects, Inc.

1960-C Buford Boulevard

Tallahassee, Florida 32308

p 850-878-8784