

WU RICHARD LEE WU

REGISTERED ARCHITECT - FLORIDA CERTIFICATE #AR0012785

2910 KERRY FOREST PKWY. D4-164 - TALLAHASSEE, FL 32309

(850) 933-1955

rlwuarchitect@earthlink.net

October 27, 2016

Dr. Harbinder Ghulldu
c/o Central Florida Recovery Centers
6900 Turkey Lake Road. Suite 1-2
Orlando, FL 32819

Project: Central Florida Recovery Center
Address: 1124 Park Avenue
Apopka, Florida

To Dr. Harbinder Ghulldu or Whom It May Concern:


As requested, I have reviewed the drawings of the proposed rear building with the proposed sleeping rooms shown on the second floor. Although this facility does not meet the exception for size in Chapter 206.1 since it exceeds the 3,000 square feet per level, it seems Sections 206.4 and 206.5 do apply in your case.

Also, I think the biggest argument that you have is based on disproportionality; the cost of providing vertical access far exceeds the 20% factor of the total renovation.


As a Florida Architect my opinion is, as a design professional, that the vertical accessibility for this project should not be required.

Certified by:

RICHARD LEE WU, ARCHITECT



Richard Lee Wu, AR0012785



Attach.

cc: Apopka Holdings LLC
9846 Camberley Circle , Orlando, FL32836