

**STRUCTURAL TECHNICAL ADVISORY COMMITTEE
TELECONFERENCE MEETING FROM TALLAHASSEE, FLORIDA**

WEB UR: <https://global.gotomeeting.com/join/330537565>

AUDIO: DIAL-IN NUMBER 1 877 309 2070

CONFERENCE CODE: 330-537-565

December 2, 2016

10:00 A.M.

MINUTES

STRUCTURAL TAC PRESENT:

David Compton (acting Chairman)
Steve Strawn
Michael Goolsby for Daniel Lavrich
Warner Chang
Craig Parrino

CW Macomber
Joe Hetzel
Jamie Gascon
Cris Fardelmann

STRUCTURAL TAC NOT PRESENT:

Jim Schock, Chairman

Do Y. Kim

STAFF PRESENT:

Mo Madani
April Hammonds
Chris Howell
Jim Hammers

Thomas Campbell
Nick DuVal
Joe Bigelow
Marlita Peters

Welcome:

Time: 10:00 a.m.

Ms. Peters welcomed everyone to the meeting of the Structural TAC. She provided information for the callers on how to mute systems to avoid background noise.

Roll Call:

Ms. Peters performed roll call for the Structural TAC. A quorum was determined with 8 members present at roll call with Steven Strawn joining shortly after the start of the meeting providing quorum of 9 members present.

Agenda Approval:

Mr. Macomber entered a motion to approve the agenda for today's meeting as posted. Mr. Gascon seconded the motion. The motion passed unanimously with a vote of 8 to 0.

Approval of the Minutes from October 4, 2016

Mr. Compton entered a motion to approve the minutes from the October 4, 2016 meeting. Mr. Gascon seconded the motion. The motion passed unanimously with a vote of 8 to 0.

To Consider and discuss the following Declaratory Statement: DS 2016-083 by Paul Zilio of Bliss & Nyitray, Inc.

Gabriel Leitz of Bliss and Nyitry, Inc. was present on the call.

Mr. Madani requested that Mr. Leitz provide a brief summary of the declaratory statement request.

Mr. Leitz provided the TAC with the summary and remained on the line for any questions.

Mr. Madani provided the TAC with the response given from the petitioner and the staff option 2 response. He expanded his explanation with direct link to the Code.

Question: Is the live load 40psf for the hotel upper level corridor that serves only private rooms but also serves as exit access from each room to the exit (stairways)?

Option #2/Staff: Yes. As per Table 1607.1 (Item 25) of the 5th Edition (2014) Florida Building Code, Building, the live load for the corridor in question is 40psf.

Structural TAC
December 2, 2016
Page 3

To Consider and discuss the following Declaratory Statement: DS 2016-083 by Paul Zilio of Bliss & Nyitray, Inc. (cont.):

Mr. Compton entered a motion to recommend Option 2 staff analysis to answer the petition. Mr. Parrino seconded the motion. The motion passed unanimously with a vote of 9 to 0.

Final Roll Call:

Ms. Peters performed a final roll call; all nine members remained on the call.

Adjournment:

The meeting was adjourned at 10:12 a.m.