

**SWIMMING POOL TECHNICAL ADVISORY COMMITTEE
TELECONFERENCE MEETING FROM TALLAHASSEE, FLORIDA**

WEB UR: <https://global.gotomeeting.com/join/200876885>

AUDIO: DIAL-IN NUMBER 1-877-309-2070

CONFERENCE CODE: 200-876-885

Wednesday, November 29, 2017

2:00 PM

Minutes

SWIMMING POOL TAC PRESENT:

James Batts, Chairman
Cris Fardelmann
John O'Connor
Bob Vincent
Corky Williams

Jordan Clarkson
Kevin Flanagan
Mark Pabst
John Wahler

SWIMMING POOL TAC NOT PRESENT:

Jim LePetrie

STAFF PRESENT:

Thomas Campbell
Justin Vogel
Chip Sellers
Marlita Peters

Mo Madani
Chris Howell
Jim Hammers

Time: 1:00 p.m.

Ms. Peters welcomed everyone to the teleconference meeting of the Swimming Pool TAC.

Roll Call:

Ms. Peters performed roll call for the Swimming Pool TAC. A quorum was determined with 9 of 10 members present.

Agenda Approval:

Mr. O'Connor entered a motion to approve the agenda for today's meeting as posted. Mr. Pabst seconded the motion. The motion passed unanimously with a vote of 9 to 0.

Approval of Minutes from May 30, 2017.

Mr. O'Conner entered a motion to approve the minutes from May 30, 2017 as posted. Mr. Wahler seconded the motion. The motion passed unanimously with a vote of 9 to 0.

To Consider and discuss the following Declaratory Statement: DS 2017-070 by John (JC) Centera of Aquatic Design Services, LLC:

Mr. Centera petitioner was on the call but deferred comments to Jennifer Hatfield to explain the detail of the request.

Ms. Hatfield provided detail of the request in the petition.

Mr. Madani provided the staff response to the petitioner stating there were two options that were available for the TAC to consider.

Option #1/Petitioner:

Yes, the grout line can be included when meeting the 1"x 1" tile requirements set forth in section 454.1.2.1 if the tile is sold and distributed as 1"x 1" nominal or trade size tile.

Option #2/Staff:

Yes, as per the definition of the term "Nominal" of section 202 of the 2014 FBC, Building and the 2017 FBC, Building, the grout line can be included when meeting the 1"x 1" tile requirements set forth in section 454.1.2.1 if the tile is sold and distributed as 1"x 1" nominal or trade size tile.

Public To Consider and discuss the following Declaratory Statement: DS 2017-070 by John (JC) Centera of Aquatic Design Services, LLC (cont.):

Mr. O'Connor entered a motion to recommend staff option #2 reply to the declaratory statement request. Mr. Williams seconded the motion.

Mr. Fardelmann asked what the purpose of the additional language was in the staff option.

Mr. Madani provided the background and reason for the language.

Discussion followed regarding issues that may or may not appear.

Mr. Vincent spoke on his comment that was submitted as part of the agenda. He stated DOH does not have issues with staff response but would like all of the areas in the code be addressed where this subject matter is referred to.

Mr. Vogel stated that we can only respond to the specific question in the petition and it only requested that 454.1.2.1 be addressed.

Mr. Vincent stated again he would like all areas addressed in the declaratory statement.

Mr. Madani stated this cannot be accomplished as it was not a listed part of the declaratory statement.

Mr. Campbell also stated that Mr. Vogel, has advised the TAC as their legal counsel that they cannot respond to questions outside of the declaratory request. He further stated if they wish to have the other sections addressed there may be a need for an additional declaratory statement request.

Mr. Flanagan stated he is with staff recommendation and requested the vote be called.

The motion to recommend the staff option #2 was called to vote. The motion passed unanimously with a vote of 9 to 0.

Comment: None

Final Roll Call:

Ms. Peters performed the final roll call all 9 members were remaining on the call.

The meeting was adjourned at 2:23 p.m.