

Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

Code Change Cycle: 2013 Triennial Original Modification 7/1/2012 - 8/2/2012

Standing Motion: Greiner/2nd Hamrick

TAC: Fire **Total Mods for this TAC:** 39

SubCode: Building

1-Scope and Administration

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5690	1	102.1	Brad Schiffer	Allow methods of compliance in The Florida Fire Prevention Code that are not mentioned in Florida Building Code.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 1Y-8N Second: Schock
NAR – No Florida specific need and potentially conflicting with law.						
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5639	1	202	Joseph Belcher	Adds definition for Means of Escape		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Schock


2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5191	2	202	Joe Bigelow	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Schock

3-Use and Occupancy Classification

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5105	3	307	Joe Bigelow	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 8Y-0N Second: Schock</p>					

4-Special Detailed Requirements Based on Use and

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5170	4	403.4.7 Smoke removal	amador barzaga	Maintaining smoke control requirements for High-Rise Buildings	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 8Y-2N Second: Schock</p>					

5-General Building Heights and Areas


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5106	5	505.2	Joe Bigelow	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Belcher</p>					

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5107	5	510.4	Joe Bigelow	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-1N Second: Belcher</p>					

7-Fire and Smoke Protection Features

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review


TAC: Fire		Total Mods for this TAC:			39
Mod # 5108	Chapter 7	Section 706	Proponent Joe Bigelow	Summary To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 9Y-1N	Second: Greiner
Mod # 5109	Chapter 7	Section 708.3	Proponent Joe Bigelow	Summary To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Schock

9-Fire Protection Systems

Mod # 5110	Chapter 9	Section 901.1	Proponent Joe Bigelow	Summary To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Greiner
Mod # 5111	Chapter 9	Section 903.2.11.3	Proponent Joe Bigelow	Summary To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
				TAC Vote: 10Y-0N	Second: Belcher

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5113	9	916	Joe Bigelow	To carry forward carbon monoxide provisions of the 2010 FBC, to be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Greiner

10-Means of Egress

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5638	10	1002.1	Joseph Belcher	Add Means of Escape to list of definitions.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Greiner

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5640	10	1008.1.4.5	Joseph Belcher	Adds provisions allowing opening protection of emergency escape and reduce opening with impact resistant covers provided a means of escape is provided.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Greiner

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5719	10	1008.1.7	Jim Heise	to maintain exceptions under 1008.1.7 Thresholds	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 10Y-0N					Second: Schock

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5985	10	1015	Ken Cureton	Modify SECTIONS 1015.1 and 1015.2.1	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 4Y-6N Second: Schock</p> <p>NAR – No Florida specific need. Reference to the year should be included in this language. This conflicts with 1015.1 section1. Legal asks that language references statute.</p>					
5796	10	1029.1	Joseph Belcher	Retains provision referring to hurricane devices on emergency escape and rescue openings.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Greiner</p>					

26-Plastic

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4961	26	2601.1	Michael Goolsby	Section formatting	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Schock</p>					

35-Referenced Standards


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5003	35	UL	Bryan Holland	Add standard UL 325 to list.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 0Y-10N Second: Greiner</p> <p>NAR – language is not clear regarding intent.</p>					

SubCode: Existing Building

6-Repairs

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5771	6	604.1	Jim Heise	window & door dimension 5% reduction clause	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 10Y-0N Second: Belcher</p>					

11-Additions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5158	11	1102	Ken Cureton	Modify SECTION 1102.3	
<p>Comment <input type="checkbox"/> AS <input checked="" type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second:</p> <p>Schock motion to accept the modification and to include A1 = using the language "fire area" instead of "allowable area". 2nd Gross Vote 10Y-0N</p>					

2904-Type of Construction

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5162	2904	APPENDIX D	Ken Cureton	Add APPENDIX D as indicated	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 4Y-6N Second: Schwab</p> <p>NAR – No Florida specific need.</p>					

SubCode: Mechanical

5-Exhaust Systems

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5173	5	513 Smoke Control Systems	amador barzaga	Maintaining smoke control requirements for High-Rise Buildings	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 8Y-2N Second: Schiffer</p>					

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

SubCode: Residential

2-Definitions


Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5424	2	R202	Ken Cureton	Modify SECTION R202 (Fire)		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Greiner
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5716	2	R202	Joseph Belcher	Adds definition for means of escape.		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second: Greiner
Motion to modify as all new language and should be completely underlined. By Greiner 2 nd Gross Vote 10Y-0N						

3-Building Planning

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5994	3	303.4	Alfonso Fernandez-Fraga	We need to eliminate the requirement to require outside air to be introduced into single family homes and townhouses		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 1Y-8N Second: Schock
NAR – correct reference. (also not only reference carbon dioxide, more appropriately utilize either one. Joe)						
Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5902	3	R302.1	Joseph Belcher	Retains provision granting exception to fire resistance rating of screen enclosure walls of insect screening.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Schiffer

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

Mod #	Chapter	Section	Proponent	Summary	Pending Review
6011	3	R302.2	Joseph Belcher	Retains single two-hour fire rated wall exception for townhouses.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-1N Second: Schwab
5904	3	R302.3	Joseph Belcher	Retains provision granting exception to fire resistance rating of screen enclosure walls of insect screening.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N Second: Schiffer
5417	3	R302.5.2	Jack Glenn	Allow continued use of Class I duct board in garages in addition to metal ductwork.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N Second: Greiner
5419	3	R310.1	Jack Glenn	Maintain the provision for means of escape to a screen enclosure	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Staff to check punctuation/grammar.					TAC Vote: 10Y-0N Second: Belcher
5717	3	R310.4	Joseph Belcher	Adds provision permitting the temporary installation of or closing of opening protection on emergency escape and rescue openings.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 10Y-0N Second: Schock

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Fire		Total Mods for this TAC: 39			
Mod # 5415	Chapter 3	Section R311.3	Proponent Jack Glenn	Summary Retain current code criteria to limit water intrusion while providing maximum better wind resistance.	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 10Y-0N Second: Schiffer
Mod # 5438	Chapter 3	Section R315	Proponent Ken Cureton	Summary Modify SECTIONS R315.1 through R315.3	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 1Y-8N Second: Schock
NAR – covered by the base code.					
Mod # 5995	Chapter 3	Section R324	Proponent Alfonso Fernandez-Fraga	Summary Adds carbon dioxide alarm requirement, where called for by other sections of the Code.	Pending Review
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Dies for lack of 2 nd .					
Mod # 5437	Chapter 3	Section SECTION R313 - AUTOMA TIC FIRE SPRINKLER SYSTEMS	Proponent Ken Cureton	Summary Modify SECTION R313	Pending Review
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR <input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 7Y-2N Second: Schock

18-Chimneys and Vents

TAC Recommendations Key

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation W = Withdrawn I = Insufficient (incomplete or does not meet criteria)



Fire

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Fire **Total Mods for this TAC:** 39

Mod #	Chapter	Section	Proponent	Summary	Pending Review
4978	18	1801.9	Michael Goolsby	Section formatting	

Comment AS AM NAR W I **TAC Vote:** 0Y-9N **Second:** Greiner

NAR – based on previous TAC action at proponents request.

44-HVHZ

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5019	44	4412	Michael Goolsby	Eliminating unnecessary duplication of Chapter 44 HVHZ provisions	

Comment AS AM NAR W I **TAC Vote:** 10Y-0N **Second:** Schock

SubCode: Building

10-Means of Egress

Mod #	Chapter	Section	Proponent	Summary	Withdrawn
5119	10	1008.1.3.5	Joe Bigelow	To carry forward Commission Dec statement and to implement the Commission plan to update the 2013 code	

Comment AS AM NAR W I **TAC Vote:** **Second:**

Withdrawn by proponent.

Search Criteria

Modification #:	ALL	Code Version:	2013
Code Change Cycle:	ALL	Sub Code:	ALL
Chapter & Topic:	ALL	Section:	ALL
Date Submitted From:	ALL	Date Submitted To:	ALL
TAC:	F	TAC Recommendation:	ALL
Commission Action:	ALL	Proponent Last Name:	ALL
Proponent First Name:	ALL	Text of Modification:	ALL
Related Modifications:	ALL	Affects HVHZ:	ALL

TAC Recommendations Key

AS = Approved as Submitted **AM** = Approved as Modified **NAR** = No Affirmative Recommendation **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)