

Code Change Cycle: 2013 Triennial Original Modification 7/1/2012 - 8/2/2012 Frank Frail – Standing Motion

TAC: Special Occupancy

Total Mods for this TAC: 120

SubCode: Building

1-Scope and Administration

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5254	1	102.7, 107.3.5, 110.3, 111.2, 1612.5	Rebecca Quinn obo DEM	Carry forward 2010 FBC flood-related provisions in Chapter 1, including plan review criteria, required inspections, and certificate of occupancy and consistency change to 1612.5.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Fentriss
Mod #	Chapter	Section	Proponent	Summary	Pending Review
5255	1	107.6 and 117 (new)	Rebecca Quinn obo DEM	Two administrative amendments that FEMA has deemed necessary to ensure that enforcement of the flood provisions of the FBC remain consistent with the NFIP.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Fentriss

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5259	2	202, 1612., 3109.2	Rebecca Quinn obo DEM	Carry forward from 2010 FBC, correct an NFIP-specific definition, and modify definitions of "substantial improvement" and "dry floodproofing" for consistency with 2015 IBC proposal Approved as Submitted.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Fentriss


4-Special Detailed Requirements Based on Use and

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified
NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)



Special Occupancy Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5689	4	419.3.6.4	Ralph Koerber	This proposals removes the requirement for flex duct to have a CPE inner core and be tested to a "modified" UL181 Impact Test using 25 pound weight dropped from a height of 10 feet. It also clarifies the limitations for Class 1 Air Connectors per NFPA 90A & 90B.		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Fentriss
Modification to adjust grammar. 419.3.6.4.2 remove "be". Fentriss –motion approval as amended. Second – Frail.						
5910	4	449.3.14.3	skip gregory	Dletes the requirement for toggle switches to be colored.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Fentriss
5864	4	449.3.3	skip gregory	Revises the rquirements for mobile testing and diagnostic.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Fentriss
Motion – Young – modify to add the word 'General' before anesthetic. Withdrawn.						
5894	4	449.3.4	skip gregory	Revisions this section for clarity. Deletes some out of date requirements.		
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Frail
Motion adopt info submitted by prononant. Fentriss – 2 nd Frail. A-3 Withdrawn. Motion – move 3894 with addition of A3 – Fentriss – 2 nd Frail. Friendly amendment – 449.3.4.6-.8 strike should be removed. Frail amended						

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5899	4	449.3.6.1	skip gregory	This modification clarifies where equipment may be located.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Frail
5900	4	449.3.6.4	skip gregory	Revises this section to provide the correct criteria for flexible ductwork.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5907	4	449.3.6.5	skip gregory	Section modified to be correct.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
Withdrawn by proponent.						
5933	4	449.4.2.9.5	skip gregory	Adds a separation for electrical wiring in hospitals.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Frail

TAC Recommendations

<p>AS = Approved as Submitted AM = Approved as Modified</p> <p>NAR = No Affirmative Recommendation</p>	<p>W = Withdrawn</p>	<p>I = Insufficient (incomplete or does not meet criteria)</p>
--	-----------------------------	---



Special Occupancy Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5935	4	450.3.11.11	skip gregory	Removes an outdated requirement.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Fentriss
5923	4	450.3.11.16	skip gregory	Revises the requirement for drinking fountain.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Pg 44 – requirement correct.					TAC Vote: 9Y-0N /Cannard Second:
5921	4	450.3.11.21	skip gregory	Revises the requirements for access panels in nursing homes	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Fentriss
5913	4	450.3.22.3	skip gregory	This revision makes the ANSI RP-28-7 mandatory.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Fentriss

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5896	4	450.3.25	skip gregory	Revises the code to make the code clearer regarding intent.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second: Fentriss (For the previous twelve mods by Skip Gregory – Motion – young – 2nd fentriss 9-0 submitted on behalf of state agency and affecting agency regulations.)</p>					
5919	4	450.3.25	skip gregory	Add supervision to the nurse call system.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input checked="" type="checkbox"/> W <input type="checkbox"/> I TAC Vote: Second: Withdrawn by proponent.</p>					
5911	4	450.3.26.4	skip gregory	Deletes the requirement for toggle switches to be colored.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second: Fentriss</p>					
5908	4	450.3.3.12	skip gregory	Revises language for clarity.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second: Fentriss Check unusual markings.</p>					

TAC Recommendations

<p>AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation</p>	<p>W = Withdrawn</p>	<p>I = Insufficient (incomplete or does not meet criteria)</p>
--	-----------------------------	---



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5926	4	450.3.3.14	skip gregory	Revises the requirement for bathing room in a nursing home.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Frail
5929	4	450.3.3.14	skip gregory	Revises the requirement for not having a rinsing device in the toilet room	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote: Second:
5927	4	450.3.4.3.5.4	skip gregory	Revises the requirement for bathing room in a nursing home.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote: Second:
5928	4	450.3.4.3.5.5	skip gregory	Revises the requirement for bathing room in a nursing home.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote: Second:

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified
NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5924	4	450.3.7.2	skip gregory	Revises the requirement for drinking fountain and public telephone.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	
Withdrawn by proponent.						
					TAC Vote:	Second:
5934	4	450.4.2.9.5	skip gregory	Adds a separation for electrical wiring in hospitals.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
Drafting error - Use base language which refers to resident not patient.						
					TAC Vote: 9Y-0N	Second: Young
5930	4	450.4.2.9.7	skip gregory	Revise the requirement for a quick connect to a nursing home.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
Drafting error – add word electrical after branch/before system.						
					TAC Vote: 9Y-0N	Second: Fentriss
5914	4	451.3.11.1	skip gregory	Revises the requirement for all nurse call systems to be supervised.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	
Correct errant symbols.						
					TAC Vote: 9Y-0N	Second: Frail

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5912	4	451.3.13.4	skip gregory	Deletes the requirement for toggle switches to be colored.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Young
5931	4	451.3.13.9	skip gregory	Adds lighting to the emergency electrical system of an ASC.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Frail
5971	4	451.3.14	skip gregory	Establishes standards for fire protection for ASC.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Fentriss
5972	4	451.3.14	skip gregory	Establishes standards for medical gas installation for ASC.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Section should be 451.3.15 not .14					TAC Vote: 9Y-0N Second: Fentriss

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified
NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5918	4	451.3.3.4.4	skip gregory	Adds a new paragraph to the details of an ASC.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Frail
5917	4	451.3.6.2	skip gregory	Revises the requirements for VAV in an ASC.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote: Second:
5916	4	451.3.6.3	skip gregory	Revises the standard for flexible ducts in ASC.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Use language from 5689					TAC Vote: 0Y-9N Second: Fentriss
5909	4	451.3.X	skip gregory	Adds a new section on fire sprinklers in ASC.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I
Withdrawn by proponent.					TAC Vote: Second:

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified
NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)



Special Occupancy Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review		
5915	4	451.3X	skip gregory	This is a new section for medical gas installations.			
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote:	Second:
Withdrawn by proponent.							
5196	4	453.10.10	Jon Hamrick	Delete unneeded language			
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10	Second: Cannard
Hamrick – abstention - proponent							
5194	4	453.10.2.4	Jon Hamrick	Add an exception for guards at vertical drops in assembly seating where the guards would interfere with sight lines.			
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10	Second: Fentriss
Hamrick – abstention - proponent							
5195	4	453.10.7	Jon Hamrick	Changes Xeriscape to Florida-friendly landscaping to correspond to change in Section 373.185, Florida Statutes			
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10	Second: Cannard
Hamrick – abstention - proponent							

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5197	4	453.12.5	Jon Hamrick	Add requirement for roofing exterior stairways serving as a means of egress	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Frail
5198	4	453.13.8.2	Jon Hamrick	Clarify that the restriction of projecting or awning windows also applies to play areas where a student can be injured by running into an open window.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Frail
5577	4	453.15.4	Jon Hamrick	Correct a grammatical error.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Cannard
5199	4	453.16	Jon Hamrick	Delete duplicate language regarding wall finishes that is found in another part of the Florida Building Code.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Frail

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5200	4	453.18.1.1	Jon Hamrick	Correct metric equivalent.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Frail
5152	4	453.2.2	Jon Hamrick	Corrects referenced Florida statute number	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Fentriss
5203	4	453.20.3	Jon Hamrick	Add a metric equivalent for a distance given in feet.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Frail
5205	4	453.20.5	Jon Hamrick	Add requirement for a dousing shower and an eye wash in custodial receiving areas.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-10 Second: Frail

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5206	4	453.22.4	Jon Hamrick	Correct metric equivalent.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Cannard
5207	4	453.25.1	Jon Hamrick	Change evacuation categories to match Department of Emergency Management new designations.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Correct reference to DCA. Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Cannard
5208	4	453.25.3.2	Jon Hamrick	Correct metric equivalent	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Cannard
5209	4	453.25.4.3.2	Jon Hamrick	Add a metric equivalent for ventilation rate provided in cfm.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Frail

TAC Recommendations

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation	W = Withdrawn	I = Insufficient (incomplete or does not meet criteria)
--	----------------------	--



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5214	4	453.25.4.3.2	Jon Hamrick	Add a metric equivalent for view panel width.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Correct section reference. Mod is ok. Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-1O Second: Cannard
5210	4	453.25.6	Jon Hamrick	Correct statute reference.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-1O Second: Fentriss
5211	4	453.26.3.2	Jon Hamrick	Correct metric equivalent.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-1O Second: Cannard
5212	4	453.27.1	Jon Hamrick	Delete a requirement that only applies to existing relocatables and does not belong in the building code.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Correct reference to DCA and reference to section 428 Hamrick – abstention - proponent					
					TAC Vote: 8Y-0N-1O Second: Fentriss

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified
NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)




Special Occupancy Tracking Chart - All Mods 2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5213	4	453.27.4	Jon Hamrick	Correct the title for the guidelines for accessibility standards for children.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Verify that it is named correctly in Ch 35. Hamrick – abstention - proponent					TAC Vote: 8Y-0N-10 Second: Fentriss
5172	4	453.3.6	Jon Hamrick	Correct dollar amount before a licensed contractor is required for maintenance projects and clarify maintenance projects are required to be review for code compliance.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-10 Second: Fentriss
5177	4	453.4.3	Jon Hamrick	Delete a Florida statute number that no longer exist.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-10 Second: Cannard
5178	4	453.4.5	Jon Hamrick	Corrects handbook title to "Public Playground Safety Handbook.";	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Confirm Hamrick – abstention - proponent correct in Ch 35.					TAC Vote: 8Y-0N-10 Second: Frail

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5180	4	453.4.8	Jon Hamrick	Correct title of publication and title of Office of Educational Facilities		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10 Second: Frail
Confirm correct in Ch. 35. Hamrick – abstention - proponent						
5184	4	453.5.11	Jon Hamrick	Align definition of owner with Rule 6A-2.0010, FAC.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10 Second: Frail
Hamrick – abstention - proponent						
5181	4	453.5.3	Jon Hamrick	Adds correct Florida statute reference and deletes obsolete date.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10 Second: Frail
Hamrick – abstention - proponent						
5182	4	453.5.5.1	Jon Hamrick	Clarify that the distance mention is travel distance.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N-10 Second: Frail
Hamrick – abstention - proponent						

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5183	4	453.5.5.3	Jon Hamrick	Adds clarifying language to the definition of a roofed courtyard.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Cannard
5185	4	453.7.1	Jon Hamrick	Clarify that in assembly occupancies, exit access doorways are also required to exit into separate atmospheres.	
Comment <input type="checkbox"/> AS <input checked="" type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Motion Approve with modification A-1 in lieu of the original with proposed findings. Fentriss 2 nd – Frail. Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second:
5186	4	453.7.8	Jon Hamrick	Add the word “resistance” to “one-hour fire rated construction” verbage.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Consider removing the word ‘rated’ by comment. Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Frail
5187	4	453.7.9	Jon Hamrick	Exempt exit passageways and horizontal exits from public educational facilities.	
Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I Hamrick – abstention - proponent					TAC Vote: 8Y-0N-1O Second: Boutin

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy		Total Mods for this TAC: 120			
Mod #	Chapter	Section	Proponent	Summary	Pending Review
5192	4	453.8.7	Jon Hamrick	Correct Florida statute reference	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Hamrick – abstention - proponent</p>					<p>TAC Vote: 8Y-0N-10 Second: Fentriss</p>
5193	4	453.8.8	Jon Hamrick	Insert formal name of DOE/OEF and include title of publication available from DOE "Florida Safe School Design Guidelines."	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Confirm correct in Ch 35 Hamrick Obtained – proponent.</p>					<p>TAC Vote: 8Y-0N-10 Second: Frail</p>
5326	4	453	Paul Coats	This modification eliminates the Florida-specific construction type restrictions for public schools in Special Occupancy Section 453 in favor of using the construction type provisions for schools in Chapters 5 and 6 of the Florida Building Code, which are based on the IBC.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Denied due to concerns about lifecycle costs, use of public educational facilities as shelters including those serving special needs, maintenance based on environmental concerns and lack of funding for maintenance, and environmental safety, fire, toxins from termite treatment.</p>					<p>TAC Vote: 0Y-9N Second: Chalecki</p>
5970	4	469	skip gregory	Establishes a new section for an office surgery suite.	
<p>Comment <input type="checkbox"/> AS <input checked="" type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Motion to adopt the mod 5970 as amended by A-1 and adopt the supporting information provided by the proponent.</p>					<p>TAC Vote: 9Y-0N Second: Young- 2nd Fentriss</p>

TAC Recommendations

AS = Approved as Submitted AM = Approved as Modified W = Withdrawn I = Insufficient (incomplete or does not meet criteria)
 NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5922	4	Table 3.18.1	skip gregory	Revises the plumbing fixture table for nursing homes	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Underline 'per resident floor' as new language.</p> <p style="text-align: right;">TAC Vote: 9Y-0N Second: Fentriss</p>					

10-Means of Egress

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5120	10	1008.1.1	Joe Bigelow	To be consistent with the Florida Accessibility Code and to implement the Commission plan to update the 2013 code	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p style="text-align: right;">TAC Vote: 9Y-0N Second: Fentriss</p>					

16-Structural Design

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5263	16	1601.1, 1801.1	Rebecca Quinn obo DEM	Carry forward from 2010 FBC to specify that in HVHZ the requirements of 1612 apply in flood hazard areas.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p style="text-align: right;">TAC Vote: 9Y-0N Second: Fentriss</p>					

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5271	16	1612, 202, 1403.7, 1603.1.7, 1804.4	Rebecca Quinn obo DEM	Limits application of Coastal A Zone requirements only if the CAZ is delineated on a map or designated by the community. Submitted as public comment at suggestion of IBC Structural Committee (S102-12).	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I</p> <p>Denied to allow the ASCE committee to further consider and finalize their updated standard.</p> <p style="text-align: right;">TAC Vote: 0Y-9N Second: Chalecki</p>					

TAC Recommendations

AS = Approved as Submitted AM = Approved as Modified W = Withdrawn I = Insufficient (incomplete or does not meet criteria)
 NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5274	16	1612, 202, 1403.7, 1603.1.7, 1804.4	Rebecca Quinn obo DEM	Achieves terminology consistency between the building code, the residential code and ASCE 24. Approved as Submitted for the 2015 IBC (S103-12).	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Fentriss
5265	16	1612.1	Rebecca Quinn obo DEM	Florida-specific addition of a table that identifies the location of all flood provisions in the family of Florida Building Codes.	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Chalecki
5267	16	1612.4	Rebecca Quinn obo DEM	Permit dry floodproofing of nonresidential buildings in flood hazard areas identified as Coastal A Zones if they are designed in accordance with ASCE 24 to account for wave loads and the potential for erosion and local scour. Approved as 2010 FBC glitch	Pending Review	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Chalecki
5269	16	1612.5	Rebecca Quinn obo DEM	Modifies foundation code to use Florida-specific title for professionals licensed by the state to perform land (and elevation) surveys.	Pending Review	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 0Y-8N Second: Chalecki
Denied due to no authority to define the scope of licensure to perform construction related activities.						

18-Soils and Foundations

TAC Recommendations

AS = Approved as Submitted AM = Approved as Modified NAR = No Affirmative Recommendation	W = Withdrawn	I = Insufficient (incomplete or does not meet criteria)
--	----------------------	--



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5801	18	1816.1.7	Steven Dwinell	Modify language to state that contracts offered for termite protection comply with Chapter 482, F.S., the Florida Structural Pest Control Act.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Chalecki

45-Plumbing Systems

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5224	29	2902.2	Suzanne Davis	To be consistent with the Florida Statutes and to implement the Commission plan to update the 2013 Code	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Neg vote - Frail					TAC Vote: 7Y-1N Second: Chalecki


38-Elevators and Conveying Systems

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5463	30	3003	DOUG MELVIN	DELETE 3003.3 in the 2012 base code & REPLACE section strikethrough in its entirety with underlined text to read as follows:	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Neg vote - Frail					TAC Vote: 8Y-1N Second: Boutin

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5242	30	3007	DOUG MELVIN	REVISE Section 3007.7 to DELETE Section reference 708.14.1 and REPLACE it with Section reference 713.14.1:	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Neg vote - Frail					TAC Vote: 8Y-1N Second: Cannard

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5245	30	3007	DOUG MELVIN	REVISE Section 3007.6 to DELETE Section reference 708 and REPLACE it with Section reference 713:		
Comment	<input checked="" type="checkbox"/> AS Neg vote - Frail	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-1N Second: Boutin
5251	30	3008	DOUG MELVIN	DELETE SECTION NUMBER section 3008.2 and strikethrough text from Florida Supplement and RENUMBER as section number 3008.1.2 and ADD underline text to read as follows:		
Comment	<input checked="" type="checkbox"/> AS Neg vote - Frail	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-1N Second: Boutin
5272	30	3012	DOUG MELVIN	ADD & REVISE Sections 3012.1.3, 3012.1.4 and 3012.1.7 in the 2010 Florida Building Code with additional text, to ADD to the Florida Supplement and to 2013 FBC regarding Bulletin Boards.		
Comment	<input type="checkbox"/> AS Denied due to lack of demonstration to be a Florida Specific need.	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 1Y-8N Second: Boutin

39-Special Construction

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5676	31	3109	Gene Chalecki	This is to correct a scrivener's error that was introduced into the 2010 FBC.		
Comment	<input checked="" type="checkbox"/> AS 1 objection – Chalecki – proponent.	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-0N -1O Second: Fentriss

35-Referenced Standards

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5138	35	3500	Rebecca Quinn obo DEM	Update reference to ASCE 24, Flood Resistant Design and Construction, to the upcoming 2012 edition. Approved as Submitted for 2015 IBC.	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 0Y-9N Second: Fentriss</p> <p>Denied because standard is not available.</p>					
4919	35	NFPA	Bryan Holland	Updates the NFPA 780 reference to the most current edition (2011).	
<p>Comment <input type="checkbox"/> AS <input type="checkbox"/> AM <input checked="" type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 0Y-9N Second: Fentriss</p> <p>Denied due to referenced standard not being submitted.</p>					

SubCode: Existing Building

2-Definitions


Mod #	Chapter	Section	Proponent	Summary	Pending Review
5277	2	202	Rebecca Quinn obo DEM	Carry forward from 2010 FBC, Existing Building and modify definition of "substantial improvement" for consistency with 2015 IBC proposal Approved as Submitted (G23-12).	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second: Chalecki</p>					

4-Prescriptive Compliance Method

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5573	4	402.2, 403.2, 404.5, 408.2, 601.3, 606.2.4,	Rebecca Quinn obo DEM	For compliance with flood provisions, refer to the FBC, Building or FBC, Residential, as applicable. Approved as Submitted (EB-14) and FEMA will submit public comment to extend to rest of the EB as shown here.	
<p>Comment <input type="checkbox"/> AS <input checked="" type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second:</p> <p>2nd withdrawn. Motion to accept with IBC references changed to reference Florida Residential Code by Fentriss -. 2nd Frail</p>					

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

11-Additions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5279	11	1103.5	Rebecca Quinn obo DEM	Separates new and replacement foundations from repairs of foundations. Approved as Submitted for 2015 IEBC (EBG13-12).	
<p>Comment <input type="checkbox"/> AS <input checked="" type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second:</p> <p>MotiOn to approve with amendment to reflect the FBC and adopting the supporting information offered by the proponent as being unaffected. By Fentriss – 2nd Frail</p>					

SubCode: Fuel Gas

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5282	2	202	Rebecca Quinn obo DEM	Achieves consistency in the definitions across all codes. Approved as Submitted by FEMA as G8-12.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second: Chalecki</p>					

SubCode: Mechanical

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5283	2	202	Rebecca Quinn obo DEM	Achieves consistency in the definitions across all codes. Approved as Submitted by FEMA as G8-12.	
<p>Comment <input checked="" type="checkbox"/> AS <input type="checkbox"/> AM <input type="checkbox"/> NAR <input type="checkbox"/> W <input type="checkbox"/> I TAC Vote: 9Y-0N Second: Frail</p>					

3-General Regulations

TAC Recommendations

AS = Approved as Submitted AM = Approved as Modified W = Withdrawn I = Insufficient (incomplete or does not meet criteria)
 NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5679	3	M301.13.1	Rebecca Quinn obo DEM	Limits application of Coastal A Zone requirements only if the CAZ is delineated on a map or designated by the community. Submitted as public comment at suggestion of IBC Structural Committee (S102-12).	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Frail
Mod #	Chapter	Section	Proponent	Summary	Pending Review
5682	3	M301.13	Rebecca Quinn obo DEM	Achieves terminology consistency between the building code, the residential code and ASCE 24. Approved as Submitted for the 2015 IBC (S103-12).	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Fentriss

5-Exhaust Systems

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5223	5	515	Ann Stanton	Add Florida-specific criteria for mausoleums.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Chalecki


SubCode: Plumbing

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5285	2	202	Rebecca Quinn obo DEM	Achieves consistency in the definitions across all codes. Approved as Submitted by FEMA as G8-12.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Chalecki

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5322	2	202	Joe Bigelow	To be consistent with Florida Statute (ss. 381.0065-381.0067) and to implement the Commission plan to update the 2013 Code		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Fentriss
5997	2	202	Eberhard Roeder	Make definitions consistent with Florida Statutes and onsite sewage treatment and disposal regulations in 64E-6, Florida Administrative Code		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Ursin
5999	2	202	Eberhard Roeder	Eliminate old grease trap language; provide for 750 gallon minimum passive or gravity grease interceptor volume as in Florida's onsite sewage regulations.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Ursin

3-General Regulations

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5996	3	301.3	Eberhard Roeder	Delete language for gray water landscape irrigation systems. Such systems are onsite sewage treatment and disposal systems in the jurisdiction of the Dept. of Health (381.0065(2)(j); 381.0065(3)(a)(b)(k), Fl. Statutes). 64E-6, FAC, provides specifications.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y=0N Second: Ursin

TAC Recommendations

AS = Approved as Submitted	AM = Approved as Modified	W = Withdrawn
NAR = No Affirmative Recommendation		
I = Insufficient (incomplete or does not meet criteria)		



Special Occupancy Tracking Chart - All Mods 2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5287	3	309.2	Rebecca Quinn obo DEM	Reformat the exception to eliminate awkward and confusing placement. Approved as Submitted by FEMA for 2015 IPC as P20-12	
Comment	<input type="checkbox"/> AS	<input checked="" type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Motion to accept with references changed from IBC to FBC and information submitted by the proponent as unaffected by the amendment. Fentriss 2 nd Frail					
					TAC Vote: 9Y-0N Second:
Mod #	Chapter	Section	Proponent	Summary	Pending Review
5684	3	M309.3	Rebecca Quinn obo DEM	Limits application of Coastal A Zone requirements only if the CAZ is delineated on a map or designated by the community. Submitted as public comment at suggestion of IBC Structural Committee (S102-12).	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y – 0N Second: Frail
Mod #	Chapter	Section	Proponent	Summary	Pending Review
5683	3	P309.3	Rebecca Quinn obo DEM	Achieves terminology consistency between the building code, the residential code and ASCE 24. Approved as Submitted for the 2015 IBC (S103-12).	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Chalecki

10-Traps, Interceptors and Separators

Mod #	Chapter	Section	Proponent	Summary	Pending Review
6002	10	1003.3; 1003.5	Eberhard Roeder	Consolidate gravity grease interceptor exception languages. Replace language that mirrors grease interceptor requirements for onsite sewage systems in 64E-6, Florida Administrative Code, with a simple reference to 64E-6. Editorial change to section numbering	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
					TAC Vote: 9Y-0N Second: Ursin

13-Gray Water Recycling Systems

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5892	13	1301 and 1303	Eberhard Roeder	Delete language for gray water landscape irrigation systems. Such systems are onsite sewage treatment and disposal systems in the jurisdiction of the Dept. of Health (381.0065(2)(j); 381.0065(3)(a)(b)(k), Fl. Statutes). 64E-6, FAC, provides specifications. Keep language as in previous Appendix C.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Ursin

SubCode: Residential

2-Definitions

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5428	2	R202	Ken Cureton	Modify SECTION R202 (Special Occupancy)	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Chalecki

3-Building Planning

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5290	3	R301.1, Table R301.2(1), 202, R443.13	Rebecca Quinn obo DEM	Carry forward from 2010 FBC the definition and reference to local floodplain management ordinance and clarify that buildings in HVHZ that are also in flood hazard areas shall also comply with flood requirements.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Cannard
5292	3	R301.2.4.1, R322.1.1	Rebecca Quinn obo DEM	This carries forward – but simplifies - a change approved for 2010 FBC, R, to permit use of ASCE 24 as an alternative in all flood hazard areas, including Zone V (foundation code) and Zone A (Florida amendment).	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Chalecki

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy Tracking Chart - All Mods


2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5434	3	R306	Ken Cureton	Modify SECTION R306.3		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Fentriss
5436	3	R311	Ken Cureton	Modify SECTION R311.2		
Comment	<input checked="" type="checkbox"/> AS Neg vote - Young	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 8Y-1N Second: Fentriss
5416	3	R318.7	Jack Glenn	Reformat the Termite Inspection requirements by moving section R704 to a new Section R381.7		
Comment	<input checked="" type="checkbox"/> AS Section numbers to be adjusted by staff to correlate with remainder of section.	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Chalecki
5293	3	R322.1.10	Rebecca Quinn obo DEM	Modifies the foundation code to use Florida-specific title for professionals licensed by the state to perform land (and elevation) surveys.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 1Y-8N Second: Chalecki

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation



Special Occupancy

Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review	
5680	3	R322.1.10	Rebecca Quinn obo DEM	Modifies foundation code to use Florida-specific title for professionals licensed by the state to perform land (and elevation) surveys.		
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input checked="" type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: Second:
5294	3	R322.2, R322.3 and R4101.4.2.1	Rebecca Quinn obo DEM	Carry forward from 2010 FBC to bring provisions for pools into the body of the code.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Chalecki
5295	3	R322.3.2	Rebecca Quinn obo DEM	In Coastal High Hazard Areas (Zone V), eliminate elevation difference based on orientation of lowest horizontal structural member to match revised ASCE 24-12 (in development). FEMA will propose for 2015 IRC.		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Chalecki
5296	3	R322.3.4	Rebecca Quinn obo DEM	Match phrasing in the 2012 IBC at Section 1612.5(2.2) for loads on breakaway walls. FEMA is submitting for the 2015 IRC (Group B).		
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I	TAC Vote: 9Y-0N Second: Chalecki

38-Sanitary Drainage

TAC Recommendations

AS = Approved as Submitted	AM = Approved as Modified	W = Withdrawn	I = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation			



Special Occupancy Tracking Chart - All Mods

2013 Florida Building Code - TAC review

TAC: Special Occupancy **Total Mods for this TAC:** 120

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5964	30	P3009.1,P3009.2,P3009.14	Eberhard Roeder	Delete language for gray water landscape irrigation systems. Such systems are onsite sewage treatment and disposal systems in the jurisdiction of the Dept. of Health (381.0065(2)(j); 381.0065(3)(a)(b)(k), Fl. Statutes). 64E-6, FAC, provides specifications. Keep language as in previous Appendix O.	
Comment	<input checked="" type="checkbox"/> AS	<input type="checkbox"/> AM	<input type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
TAC Vote: 9Y-0N					Second: Ursin

45-Referenced Standards

Mod #	Chapter	Section	Proponent	Summary	Pending Review
5289	45	4500	Rebecca Quinn obob DEM	Update reference to ASCE 24, Flood Resistant Design and Construction, to the upcoming 2012 edition. FEMA will propose for the 2015 IRC to be consistent with Approved as Submitted for the 2015 IBC.	
Comment	<input type="checkbox"/> AS	<input type="checkbox"/> AM	<input checked="" type="checkbox"/> NAR	<input type="checkbox"/> W	<input type="checkbox"/> I
Denied due to reference standard not yet completed.					
TAC Vote: 0Y-9N					Second: Fentriss

Search Criteria

Modification #:	ALL	Code Version:	2013
Code Change Cycle:	ALL	Sub Code:	ALL
Chapter & Topic:	ALL	Section:	ALL
Date Submitted From:	ALL	Date Submitted To:	ALL
TAC:	SP	TAC Recommendation:	ALL
Commission Action:	ALL	Proponent Last Name:	ALL
Proponent First Name:	ALL	Text of Modification:	ALL
Related Modifications:	ALL	Affects HVHZ:	ALL

TAC Recommendations

AS = Approved as Submitted **AM** = Approved as Modified **W** = Withdrawn **I** = Insufficient (incomplete or does not meet criteria)
NAR = No Affirmative Recommendation