

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010865.05
DATE: 12/12/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document..

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, WV 26104 | Series "7700/9900" Vinyl Double Hung Window Configuration: X/X Reinforced Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-2134mm(84") Sash: W-1343m(52.88") H-1057mm(41.63") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------------------|---|
| AAMA/WDMA/CSA 101/LS.2/A440-05 | H-LC25 1422 x 2134 (56 x 84) Design Pressure: 1200 Pa (25 psf) Negative Design Pressure: 1200 Pa (25 psf) Water Penetration Resistance Test Pressure: 290 Pa 6.06 psf) |

Product Tested By: Architectural Testing, Inc.
Report No: 77369.04-501-47
Expiration Date: **December 31, 2015**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122