

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010865.06
DATE: 12/12/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document..

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, WV 26104	Series "7700/9900" Vinyl Double Hung Window Configuration: X/X Reinforced Glazing: Insulating Glass (Annealed) Frame: W-940mm(37") H-1930mm(76") Sash: W-860m(33.88") H-956mm(37.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-05	H-LC50 940 x 1920 (37 x 76) Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa 7.72 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 77369.04-501-47
Expiration Date: **December 31, 2015**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122