

# Hallmark® Certificate of Conformance and License (CCL)



VELUX AMERICA INC.

Mfr#: 426

PO BOX 5001

GREENWOOD, SC 29648-5001

TEL: (864) 941-4828

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-684.00	VCM/VCE 4646 2004B and smaller / VCM/VCE 4646 2008B and smaller	101/I.S.2/A440-08	Class CW-PG40; Size Tested 1302x1302mm (51x51in)-SKG; Design Pressure (DP) = 7900pa (165psf); Canadian Air Infiltration/Exfiltration Level = A2; Water Penetration Resistance Test Pressure = 720pa (15.04psf)	1302mm	1302mm	93405.02-109-44	01/19/2010	09/29/2013
426-H-684.01	VCM/VCE 4646 2004B and smaller / VCM/VCE 4646 2008B and smaller	101/I.S.2/A440-05	SKG-C40; Design Pressure (DP) = 7900pa (165psf); Canadian Air Infiltration/Exfiltration Level = A2; Water Penetration Resistance Test Pressure = 720pa (15.04psf)	1302mm	1302mm	93405.03-109-44	01/19/2010	09/29/2013
426-H-684.02	VCM/VCE 4646 2004B and smaller / VCM/VCE 4646 2008B and smaller	101/I.S.2/NAFS-02	SKG-C150 60	1302mm	1302mm	93405.04-109-44	01/19/2010	09/29/2013
426-H-684.03	VCM/VCE 4646 2006B and smaller	ASTM E-1996-05 / ASTM E-1886-05	Wind Zone 3, Missile Level C, Cycle Pressure +/-50	1302mm	1302mm	96108.01-109-44	03/02/2010	09/29/2013

WDMA HEREBY CERTIFIES that the aforesaid Company (“Licensee”), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the products set forth above were tested and found to comply with the standards.

By: John McFee John McFee, Certification Mgr, WDMA Hallmark

Program Sponsor:  
Window and Door Manufacturers Assoc  
401 N. Michigan Ave.  
Chicago, IL 60611  
TEL (312)673-4828 www.wdma.com

Program Administrator:  
Administrative Management Services, Inc.  
PO Box 730, 100 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 staff@amscert.com