

**A·L·I**

(Validator / Operations Administrator)

**AAMA  
CERTIFICATION PROGRAM  
WAIVER OF RETEST APPROVAL**



January 21, 2015

Croft LLC  
P.O. Box 826  
McComb, MS 39648

Attn: Dennis Anders

Dear Dennis,

Per your written request you are hereby granted a waiver of retest for your flange frame modification to the Series 52 Single Hung windows based on the certification performance testing of your Series 50 Single Hung Window. As indicated in the drawings submitted with your request, the only change involves the addition of a flange at the outermost edge of the frame extrusion exterior face. The purpose of the flange is to assist in installation, and will not degrade the performance of the finished assembly. All other sash profiles and construction features remain unchanged.

This waiver approval is based on the drawings submitted with your request, and applies only to air, water and structural performance.

Sincerely,

Handwritten signature of Brad Schultz in black ink.

Brad Schultz  
Associated Laboratories, Inc.

Handwritten signature of Jason T. Seals in black ink.

Jason T. Seals  
AAMA Certification Program