

Document Title:	Document No.		F	RM	B1-43	
CERTIFICATION AUTHORIZATION REPORT	Revision No.	1	Page:	1	Of:	1
Required By: PRO B1-03						

FMA Keystone Impact Certification Program Certification Authorization Report

CAR & Product ID Number: 138 - 204

Issue Date: 11/17/2005 Revision Date: 6/4/2007 Expiration Date: 8/29/2009

Company Code: 138

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of FMA Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Company Information:		Product Information:		
Custom Window Systems, Inc 1900 SW 44th Avenue		Model: 8100 Vinyl Single Hung w/ Fin Operator Type: H		
Ocala	FL 34474	Config: EM/AII, GS - 5/16" Lami IG Max Width: 36 Max Height: 62 Corresponding Structural CARs: 138-176		

Referenced Standard:	Product Rating:	
ASTM E1886/E1996-02	Missile Level D, Wind Zone 4, DP +/-70.0 psf, 36x62	

Qualifying Test Information:			
Test Report No:	NCTL-210-3168-2A		
Test Report Expiration:	8/29/2009		

Authorized	Signature:
-------------------	------------

Keystone Certifications, Inc.

1790 Old Trail Road, Suite D Etters, Pennsylvania 17319 Phone: 717-932-8500

Fax: 717-932-8501