

# Hallmark® Certificate of Conformance and License (CCL)





VELUX America Inc.  
PO Box 5001  
Greenwood, SC 29648-5001

Mfr ID: 426  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website:  
TEL: 864-941-4828

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-705.00	VELUX SUN TUNNEL™ (Residential) [TGF, TGR, TMF or TMR] + [010, 014 or 022] + [0000, 1000, 0000E0 or E1, 1000E0]	101/I.S.2/A440-11	TDDCC-PG125; Size Tested 559mm dia. (22 in); Positive (Download) Design Pressure, (DP) = 14,364 Pa(300 psf)	559mm dia.	n/a	D2092.01-109-44-R2	2/6/2014	12/18/2021
426-H-705.03	VELUX SUN TUNNEL™ (Residential) [TGF, TGR, TMF or TMR] + [010, 014 or 022] + [1000 or 1000E0]	ASTM E-1996-05 / ASTM E-1886-05	Wind Zone 3, Large Missile (C); Cycle Pressure = ± 50 psf	559mm dia.	n/a	D2104.01-109-44-R0	2/6/2014	11/29/2021

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 100 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)