

# Hallmark® Certificate of Conformance and License (CCL)

VELUX America Inc.  
PO Box 5001  
Greenwood, SC 29648-5001

*Mfr#:* 426

*TEL:* 864-941-4828



<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
426-H-626.05	TSR 010 0000	101/I.S.2/A440-11	TDDCC-PG210; Size tested 254 mm dia. (10"); Positive Design Pressure (DP) = 19, 150 Pa (+400 psf); Canadian Air Infiltration/Exfiltration Level = A3; Water Penetration Resistance Test Pressure = 720 Pa (15 psf)	254mm dia		C4771.02-109-44	02/01/2013	04/03/2017
426-H-626.06	TSR 010 0000	101/I.S.2/A440-08	SP-PG155; Size tested 254 mm dia.(10 ") -TDD; DP = 11,970 Pa (+250 psf); Canadian Air Infiltration/Exfiltration = A3; Water Penetration Resistance Test Pressure = 720 Pa (15 psf)	254mm dia		C4771.01-109-44r1	02/18/2013	04/03/2017

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the products set forth above were tested and found to comply with the standards.

*By:*  *John McFee, Certification Mgr, WDMA Hallmark*

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 www.wdma.com

Program Administrator:  
Administrative Management Services, Inc.  
PO Box 730, 100 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 staff@amscert.com