



# BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

127 W. Fairbanks Ave.  
Suite 438  
Winter Park, FL 32789  
407.644.6957 PH  
407.644.2366 FX  
contact@buildingdrops.com

**April 30, 2012**

**TO:** Whom It May Concern

**FROM:** Hermes F. Norero, P.E.  
Registered Florida Professional Engineer #73778

**MANUFACTURER:** Diversified Window Solutions, Inc.  
215 Pineda Street  
Unit 141  
Longwood, FL 32750

**FLORIDA PRODUCT APPROVAL #:** FL5580

**PRODUCT CATEGORY:** Shutters

**PRODUCT SUB-CATEGORY:** Storm Panels

**SUBJECT:** Product Conformance to the 2010 Florida Building Code

Dear Sir (Madam),

I have reviewed the referenced Florida Product Approval and associated documents and found all drawings, reports, referenced test standards, and associated ancillary tests as noted in the currently approved documents listed below to be in compliance with the 2010 Edition of the Florida Building Code.

It has been concluded that no revisions or changes to the referenced standards and standard years has occurred between Chapter 35 of the 2007 and Chapter 35 of the 2010 Editions of the Florida Building Code. Therefore, all test standards listed below are valid for the 2010 Edition of the Florida Building Code.



# BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

127 W. Fairbanks Ave.  
Suite 438  
Winter Park, FL 32789  
407.644.6957 PH  
407.644.2366 FX  
contact@buildingdrops.com

<i>SECTION</i>	<i>DRAWING</i>	<i>EVALUATION REPORT</i>	<i>QUALITY ASSURANCE</i>	<i>QA EXPIRATION</i>	<i>TEST STDS.</i>
5580.1	DWS001	1175	NAMI	12/31/2012	ASTM E1886-02 ASTM E1996-02 ASTM E330-02 TAS 201/202/203-94
5580.2	DWS002	1177	NAMI	12/31/2012	ASTM E1886-02 ASTM E1996-02 ASTM E330-02 TAS 201/202/203-94


To the best of my knowledge, all referenced & included test standards, methods of installation, details, and performance ratings have been found to comply with the 2010 edition of the Florida Building Code.

This product is manufactured under a quality assurance program currently approved by the Florida Building Commission.

Please note that I do not have, nor will I acquire, a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

I also do not have, nor will I acquire, any financial interest with the Laboratory that performed the test(s), or with the Engineer witnessing the test(s) and sealing the test report(s).

Respectfully submitted,



Hermes F. Norero, P.E.  
Florida Registered Professional Engineer #73778