

*L. Roberto Lomas P.E.*

1432 Woodford Rd.  
Lewisville, NC 27023  
336-945-9695

## Engineering Evaluation Report

Report No.: 511529

**Manufacturer:**           **Door Innovations**  
                                  **9943 Kemp Forest Drive**  
                                  **Houston, TX 77080**

**Product Line:**    Weathertight Aluminum Clad Wood Outfold Door – Non-Impact

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Community Affairs for Statewide Acceptance per Rule 9B-72.070 method 1(d). The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-00971, titled Weathertight Aluminum Clad Wood Outfold Door – Non-Impact, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: ATI 92219.01-801-18-R1 signed by Andy Cost Architectural Testing, Inc., Southlake, TX.  
ASTM E330-02 Design pressure:   ±35.0psf  
Water penetration resistance    0.0psf
3. Anchor calculations, report number 511529-1, prepared, signed and sealed by Luis Roberto Lomas P.E.
4. Comparative Analysis, report number 511529-2, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure:            See approval document
- Maximum panel size:                 36" x 95 1/4"
- Maximum unit height:                99 1/4"
- Approved configurations:            Unlimited number of panels is applicable as long as individual panels do not exceed tested panel size.
  
- Units must be glazed per ASTM E 1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Unit was not tested for water infiltration and is to be installed only where the water requirement is not needed.
- Frame material to be Extruded Aluminum 6063-T5 .100" thick.
- Panel material to be Laminated Finger Jointed Pine with .050" Veneer on interior and Extruded Aluminum 6063-T5 Cladding .060" thick on the exterior.

**Installation:**       Units must be installed in accordance with approval document, 08-00971.

**Certification of Independence:**   Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

