

**EVALUATION REPORT OF
UNION CORRUGATING COMPANY
'26 GA. PBR PANEL'**

**FLORIDA BUILDING CODE 5TH EDITION (2014)
FLORIDA PRODUCT APPROVAL
FL 18717.1
STRUCTURAL COMPONENTS
ROOF DECK**

**Prepared For:
Union Corrugating Company
P. O. Box 229
Fayetteville, NC 28302
Telephone: (910) 483-0479
Fax: (910) 483-8897**

**Prepared By:
Bala Sockalingam, Ph.D., P.E.
Florida Professional Engineer #62240
1216 N Lansing Ave., Suite C
Tulsa, OK 74106
Telephone: (918) 492-5992
FAX: (866) 366-1543**

**This report consists of
Evaluation Report (3 Pages including cover)
Installation Details (1 Page)
Load Span Table (1 Page)**

**Report No. C2055-1
Date: 10.20.15**



Manufacturer: Union Corrugating Company

Product Name: PBR Panel

Panel Description: 36" wide coverage with (4) 1-1/4" high ribs

Materials: Min. 26 ga., 80 ksi steel or min. 24 ga., 50 ksi steel. Galvanized coated steel (ASTM A653) or Galvalume coated steel (ASTM A792) or painted steel (ASTM A755).

Support Description: Min. 16 ga., 50 ksi steel section. (Must be designed by others)

Slope: 1/2:12 or greater in accordance with FBC 2014 Section 1507.4.2

Design Pressure:
(Factor of Safety = 2)
(3 or more spans)

-45.5 psf @ support spacing of 60 o.c.
-163.0 psf @ support spacing of 20 o.c.
32 psf @ support spacing of 60 o.c.
96 psf @ support spacing of 20 o.c.

Panel Attachment:

At panel ends #12-14 x 1-1/4" long SDS with washer @ 7"-5"-7" o.c. across panel width

At interior supports #12-14 x 1-1/4" long SDS with washer @ 12" o.c. across panel width

Sidelap Attachment: 1/4"-14 x 7/8" long SDS with washer @ 24" o.c.


Test Standards: Roof assembly tested in accordance with ASTM E1592-05 'Test Method for Structural Performance of Sheet Metal Roof and Siding Systems by Uniform Static Air Pressure Difference' and FM 4470 Section 5.5 'Resistance to Foot Traffic'.

Code Compliance: The product described herein has demonstrated compliance with FBC 2014 Section 1507.4


Product Limitations: Design wind loads shall be determined for each project in accordance with FBC 2014 Section 1609 or ASCE 7-10 using allowable stress design. The maximum support spacing listed herein shall not be exceeded. The design pressure for support spacing may be computed using rational analysis prepared by a Florida Professional Engineer or based on Union load span table. This evaluation report is not applicable in High Velocity Hurricane Zone. Fire classification is not within scope of this Evaluation Report. Refer to FBC 2014 Section 1505 and current approved roofing materials directory or ASTM E108/UL790 report from an accredited laboratory for fire ratings of this product.

Supporting Documents: ASTM E1592 Test Reports
ENCON Technology Inc.
Project No. C2054-1, Reporting Date 10/16/15


FM 4470 Test Report
ENCON Technology Inc.
C1583-1, Reporting Date 7/24/08



TYPICAL PANEL INSTALLATION X-SECTION



SECTION VIEW



DETAIL 1

GENERAL NOTES:

1. STRUCTURAL ROOF PANEL HAS BEEN DESIGNED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE (FBC).
2. PANELS SHALL BE MIN. 26 GA. (t = 0.0175"). EFFECTIVE COVERING WIDTH OF PANEL = 36".
3. ROOF PANELS SHALL BE INSTALLED OVER STRUCTURE AS SPECIFIED ON THIS DRAWING.
4. REQUIRED DESIGN WIND LOADS SHALL BE DETERMINED FOR EACH PROJECT. THIS PANEL SYSTEM MAY NOT BE INSTALLED WHEN THE REQUIRED DESIGN WIND LOADS ARE GREATER THAN THE ALLOWABLE WIND LOADS SPECIFIED ON THIS DRAWING.
5. ALL FASTENERS MUST BE IN ACCORDANCE WITH THIS DRAWING & THE FLORIDA BUILDING CODE. IF A DIFFERENCE OCCURS BETWEEN THE MINIMUM REQUIREMENTS OF THIS DRAWING & THE CODE, THE CODE SHALL CONTROL.
6. PURLINS/JOISTS/TRUSSES MUST BE DESIGNED TO WITHSTAND WIND LOADS AS REQUIRED FOR EACH APPLICATION AND ARE THE RESPONSIBILITY OF OTHERS.

NO.	REVISION DESCRIPTION	BY	DATE

DRAWN BY:	B.S.	CHECKED BY:	J.S.
DATE:	16/17/15		

DRAWING TITLE	PBR ROOF PANEL
CONSULTANTS	BALA SOCKALINGAM, PH.D., P.E.
MANUFACTURER	UNION CORRUGATING CO. 701 S. KING STREET FAYETTEVILLE, NC 28301 COMPANY PHONE NUMBER?
1216 N. LANSING AVE., SUITE C TULSA, OK 74106	PHONE: 918-492-5992 FAX: 866-366-1543

DRAWING NO.	2055-1	REV.	
PAGE NO.	1	OF	1

UNION CORRUGATING COMPANY

PBR Roof Panel

Allowable Design Loads

Support Spacing (in)	Allowable Design Loads (psf)	
	Gravity	Uplift
20	96.0	-163.0
22	87.3	-148.2
24	80.0	-135.8
27	71.1	-120.7
30	64.0	-108.7
33	58.2	-98.8
36	53.3	-90.6
39	49.2	-83.6
42	45.7	-77.6
45	42.7	-72.4
48	40.0	-67.9
51	37.6	-63.0
54	35.6	-56.2
57	33.7	-50.4
60	32.0	-45.5

Notes:

1. Allowable load is the lowest value of panel strength, connection strength & deflection limit of L/180
2. Allowable load is applicable to three or more spans conditions.
3. Panels must be installed as per Evaluation Report FL 18717.1 and Union current installation procedure.
4. The structural capacity of support beam are not considered and must be examined independently.
5. Minimum support thickness is 16 ga.



1216 N Lansing Ave., Suite C
Tulsa, Ok 74106
918 492 5992

Bala Sockalingam, Ph.D., P.E.
FL 62240