

Equivalency Evaluation Report

Rule 61G20 F.A.C. | Report No. ACE-1013 | Project No. ACE-2018-117 | 1/11/19 | Page 1 of 2

Product Manufacturer

Polygal Inc.
1100 Bond Street
Charlotte, NC 28208

Product Name, Model, Series and/or Description

Polygal SG 16mm Clear (3-Wall) Storm Panel L.M. Impact (HVHZ)
Polygal Titan Sky 16mm Clear (5-Wall) Storm Panel L.M. Impact (HVHZ)

Code: Current Edition of the Florida Building Code including the 6th Edition (2017) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Testing:

- QAI Laboratories, Tulsa, OK, Test Report No. TJ0498-1, dated 4/11/12, Polygal, Inc. Titan Sky, signed by Gregory Ertel & J. Brian McDonald
 - ASTM E84-11, Surface Burning Characteristics
 - Flame Spread; 5
 - Smoke Developed; 70
- QAI Laboratories, Tulsa, OK, Test Report No. TJ0498-2, dated 4/11/12, Polygal, Inc. Titan Sky y, signed by Gregory Ertel & J. Brian McDonald
 - ASTM D635-06, Rate of Burning
 - CC1 classification
- SGS, Charlotte, NC Test Report No. 97808-9, dated 5/9/07, Polygal, Inc. Titan Sky, signed by Brian Ortega and Greg Banasky
 - ASTM E1929-01, Ignition Temperature
 - Self-Ignition Temperature; 968°F
- SGS, Charlotte, NC Test Report No. 97808-2, dated 5/9/07, Polygal, Inc. SG, signed by Brian Ortega and Greg Banasky
 - ASTM E84-11, Surface Burning Characteristics
 - Flame Spread; 70
 - Smoke Developed; 200
- SGS, Charlotte, NC Test Report No. 97808-4, dated 5/9/07, Polygal, Inc. SG, signed by Brian Ortega and Greg Banasky
 - ASTM D635-06, Rate of Burning
 - CC2 classification
- SGS, Charlotte, NC Test Report No. 97808-8, dated 5/9/07, Polygal, Inc. SG, signed by Brian Ortega and Greg Banasky
 - ASTM E1929-01, Ignition Temperature
 - Self-Ignition Temperature; 968°F

Equivalency Evaluation of Product Testing

6th Edition (2017) Florida Building Code

- ASTM D1929-12
- ASTM D635-10
- ASTM E84-13a

Testing conducted in the test reports listed above have been reviewed against the requirements of the 6th Edition (2017) Florida Building Code and found to be in conformance.

Robert J. Amoruso, P.E., 12472 Lake Underhill Rd., Orlando, FL 32828
robert.amoruso@comcast.net | FBPE FL P.E. No. 49752

Equivalency Evaluation Report

Rule 61G20 F.A.C. | Report No. ACE-1013 | Project No. ACE-2018-117 | 1/11/19 | Page 2 of 2

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E. does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752