

December 14, 2011

Florida Department of Business and Professional Regulation 1940 North Monroe Street Tallahassee, FL 32399

Regarding:

Transparent Protection Systems, Inc.

ClearGuard Polycarbonate Storm Panels (Non-HVHZ)

Project #08-TPS-0008

To Whom It May Concern:

This office has reviewed test reports showing structural performance of the above-noted product. These test reports pertain to testing performed in accordance with ASTM E 1996-05 Standard Specification for Performance of Exterior Windows, Glazed Curtain Walls, Doors and Storm Shutters Impacted by Wind Borne Debris in Hurricanes. This standard is not adopted in the 2010 Florida Building Code; however, for the purpose of determining the performance of the product, this standard is equivalent to ASTM E 1996-06, which is an adopted standard in the above referenced building code.

