

**Manufacturer:** Vista Window Company (C.I.)  
3850 Elm Rd  
Warren, OH 44483

**Product Line:** Series CP55 PVC Casement Picture Window Non-Impact

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Community Affairs for Statewide Acceptance per Rule 9B-72.070 method 1(d). The product listed herein complies with the 2004 Florida Building Code.

**Product description:** Casement Picture Window, impact resistant made out of white rigid PVC with mitered and welded corners. Tested frame included flange and fin configurations.

**Supporting Technical Documentation:**

1. Approval document: drawing number FL 00324 dated 11/26/07 sheets 1 of 3, titled CP55 PVC Casement Picture Window Non-Impact, prepared, signed and sealed by L. Roberto Lomas P.E.
2. Test report No.: ATI 73952.03-501-47, signed by Corey Eisenhut and Michael L. Mackereth  
Architectural Testing Inc.  
AAMA/WDMA/CSA 101/I.S.2/A440-05  
Design pressure: ±50.0 psf  
Water penetration resistance: 7.5 psf
3. Anchor calculations, report number 510431, prepared, signed and sealed by L. Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: ±50 psf
- Maximum unit size: 72" x 72"
- Maximum D.L.O.: 65 ¾" x 65 ¾"
- Units must be glazed per ASTM E 1300-02.
- This product is not rated to be used in the HVHZ.
- This product is non-impact resistant and requires impact protection.
- Frame material to be white rigid PVC

**Installation:**

- Units must be installed in accordance with approval document, FL 00324

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

