

Manufacturer: Vista Window Company (C.I.)
3850 Elm Rd
Warren, OH 44483

Product Line: Series CA55WW PVC Casement Window Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Community Affairs for Statewide Acceptance per Rule 9B-72.070 method 1(d). The product listed herein complies with the 2004 Florida Building Code.

Product description: Casement Window, impact resistant made out of white rigid PVC with mitered and welded corners. Tested frame included flange and fin configurations.

Supporting Technical Documentation:

1. Approval document: drawing number FL 00330 dated 11/26/07 sheets 1 of 2, titled CA55WW PVC Casement Window Non-Impact, prepared, signed and sealed by L. Roberto Lomas P.E.
2. Test report No.: AT1 73528.02-501-47, signed by Michael D. Stremmel P.E. and Michael L. Mackereth Architectural Testing Inc.
AAMA/WDMA/CSA 101/I.S.2/A440-05
Design pressure: ±50.0 psf
Water penetration resistance: 10.66 psf
3. Anchor calculations, report number 510443, prepared, signed and sealed by L. Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±50 psf
- Maximum unit size: 36" x 72"
- Maximum D.L.O.: 30" x 66"
- Units must be glazed per ASTM E 1300-02.
- This product is not rated to be used in the HVHZ.
- This product is non-impact resistant and requires impact protection.
- Frame material to be white rigid PVC

Installation:

- Units must be installed in accordance with approval document, FL 00330.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

