

Manufacturer: Vista Window Company (C.I.)
3850 Elm Rd
Warren, OH 44483

Product Line: Series 4700 PVC Single Hung Window Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Community Affairs for Statewide Acceptance per Rule 9B-72.070 method 1(d). The product listed herein complies with the 2004 Florida Building Code.

Product description: Single Hung Window, impact resistant made out of white rigid PVC with mitered and welded corners. Tested frame included flange and fin configurations.

Supporting Technical Documentation:

1. Approval document: drawing number FL 00332, dated 11/26/07 sheets 1 of 3, titled 4700 PVC Single Hung Window Non-Impact, prepared, signed and sealed by L. Roberto Lomas P.E
2. Test report No.: 72842.03-501-47, signed by Michael Clay and Lynn George Architectural Testing Inc.
AAMA/WDMA/CSA 101/I.S.2/A440-05
Design pressure: ± 50.0 psf
3. Anchor calculations, report number 510448, prepared, signed and sealed by L. Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 50 psf
- Maximum unit size: 52 1/8"x75 3/4"
- Maximum D.L.O.: 47"x33 1/2"
- Units must be glazed per ASTM E 1300-02.
- This product is not rated to be used in the HVHZ.
- This product is non-impact resistant and requires impact protection.
- Frame material to be white rigid PVC

Installation:

- Units must be installed in accordance with approval document, FL 00332.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

