

# Product Evaluation Report

FL13771

Robert L. Clark, P.E.  
823 Harrowood Ct  
Sarasota, FL 34232  
(941) 342-8239

7/23/10  
Revised 11/22/2011

**Product Description:** Hinged Door Hurricane Screen  
Aluminum Hinged Door Hurricane Screen with Stainless Steel Screen

**Manufacturer:** Crimsafe  
3020 Reynolds Road  
Suite 1-3  
Lakeland, FL 33803


**Statement of Compliance:** The products listed in this evaluation report, meet the requirements of the Florida Product Approval Rule, 9B-72.0700. This product complies with the requirements of the 2010 Florida Building Code.

**Technical Documentation:** Elevations, anchorage and installation drawings  
Test Reports from ATI (Architectural Testing) 98889.01-401-18 and 98889.03-401-18 tested to Protocols for the High Velocity Hurricane Zone, Protocols TAS 201-94, TAS 202-94, and TAS 203-94. Test Report from ATI (Architectural Testing) 98889.02-401-44 and 98889.04-401-44 tested to ASTM E 330/1886/1996. Supplemental anchor calculations to verify installation instructions.

**Installation:** installation instructions.

**Limits of Use:** 1. Maximum Design Pressures and sizes to be as listed in the test report, unless attached documentation shows lower DP's or smaller sizes.  
2. This product is Impact Resistant and does not require shutters in windborne debris regions.  
3. This product is for use outside the High Velocity Hurricane Zone (HVHZ) only.

**Certification of Independence:** I do not have, nor will I acquire, a financial interest in Crimsafe or any company manufacturing or distributing products for which this report is being issued. I do not have, nor will I acquire, a financial interest in any other entity involved in the approval process of this product.



Robert L. Clark  
P.E. # 39712