

**Product Evaluation Report**

**Report No.: FL-15213.11**

**Date: February 16, 2012**

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Plastpro Inc. 5200 W. Century Blvd. Los Angeles, CA Phone 440.969.9773	Smooth / Wood Grain / White Wood Grain Rustic / Mahogany Series Fiberglass Door Inswing/Outswing - "Non-Impact"

**Scope:** Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Plastpro Inc., based on Rule Chapter No. 9N-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

**Limitations:**

1. This product has been evaluated and is in compliance with the 2010 Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with Section 1609.1.2 of the 2010 FBC.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of this drawing require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-15213.11 for size and design pressure limitations.

**Supporting Documents:**

1. <b>Test Report No.</b> ETC 03-209-14024.1 ETC 03-209-14205.1 NCTL-210-2040-1,2,3	<b>Test Standard</b> ANSI/AAMA/NWWDA 101/I.S.2-97 ANSI/AAMA/NWWDA 101/I.S.2-97 TAS 202-94	<b>Testing Laboratory</b> ETC Laboratories ETC Laboratories NCTL	<b>Signed by</b> Art Murray Art Murray Barry Portnoy, P.E.
2. <b>Drawing No.</b> No. FL-15213.11	<b>Prepared by</b> RW Building Consultants, Inc. (CA #9813)		<b>Signed &amp; Sealed by</b> Lyndon F. Schmidt, P.E.
3. <b>Calculations</b> Anchoring	<b>Prepared by</b> RW Building Consultants, Inc. (CA #9813)		<b>Signed &amp; Sealed by</b> Lyndon F. Schmidt, P.E.

4. **Quality Assurance**

Certificate of Participation issued by National Accreditation and Management Institute, certifying that Plastpro Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.  
FL PE No. 43409  
2/24/2012