

BUILDING DROPS

A Perfect Solution in Every Drop Certificate of Authorization: 29578 398 East Dania Beach Suite 338 Dania Beach, FL 33004 954.399.8478 PH 954.744.4738 FX contact@buildingdrops.com

Product Evaluation Report

of

Croft, LLC. "Series 75/95/97" Picture Window

for

Florida Product Approval

FL# 15586

Report No. 4154

Current Florida Building Code


Method: Category: Sub – Category: Product: Material: Product Dimensions: 1 – A (Certificate Method) Windows Fixed Series 75/95/97 Picture Window 6063-T5 Aluminum 72" x 42" (Flange Frame) 59" x 59" (Fin Frame)

Prepared For:

Croft, LLC. P.O. Box 826 McComb, MS 39649

Prepared by:

Hermes F. Norero, P.E. Florida Professional Engineer # 73778 Date: 02/11/2016 <u>Contents:</u> Evaluation Report Pages 1 – 4





Manufacturer:		Croft, LLC.		
Product Category:		Windows		
Product Sub-Category:		Fixed		
Compliance Method:		State Product Approval Rule (1)(a)		
Product Name:		Series 75/95/97 Picture Window 72" x 42" (Flange Frame) 59" x 59" (Fin Frame)		
Scope:	on <u>Method 1a</u>	roduct Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for Croft, LLC. based <u>d 1a of the State of Florida Product Approval, Department of Business and Professional n - Florida Building Commission.</u>		
	ero, P.E. does not have nor will acquire financial interest in the company g or distributing the product or in any other entity involved in the approval process of amed herein.			
This product ha		as been evaluated for use in locations adhering to the Florida Building Code.		
	See Installation specific use pa	tion Instructions CRF013 , signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for parameters.		
Limits of Use:				
	•	roduct has been evaluated and is in compliance with the Florida Building Code, ling the "High Velocity Hurricane Zone" (HVHZ).		
	2. Produ	ct anchors shall be as listed and spaced as shown on details. Anchor embedment into ate material shall be beyond wall dressing or stucco.		
	3. When	used in areas requiring wind borne debris protection this product complies with		
	4. Site co	er 16 of the Florida Building Code and <u>does</u> require an impact resistant covering. Inditions that deviate from the details of drawing CRF013 require further engineering		
	analys	is by a licensed engineer or registered architect.		

5. See Installation Instructions **CRF013** for size and design pressure limitations.

Hermes F. Norero, P.E. Florida No. 73778 Page 2 of 4



Certification Agency: The manufacturer has demonstrated compliance of window products in Accordance with the Florida Building Code and State Rules for manufacturing under an approved certification agency through **American Architectural Manufacturers Association** (FBC Organization #: CER1498).

(FBC Organization #: CER1498)

Performance Standards:	The p	The product described herein has been tested per:		
	• AAMA/WDMA/CSA 101/I.S.2/A440-08			
Referenced Data:	1.	Product Testing performed by Architectural Testing (FBC Organization # TST1795) Report #: B7510.01-801-47, Report Date: 04/20/12 Report #: B3407.01-801-47, Report Date: 10/07/11		
	2.	Certification Agency American Architectural Manufacturers Association		

Hermes F. Norero, P.E. Florida No. 73778 Page 3 of 4



Installation: 1. Approved anchor types and substrates are as follows:

Flange Frame:

- A. For two by (2X) wood frame substrate, use **#10 Wood Screws** type wood frame anchors of sufficient length to achieve minimum embedment of 1.50" into wood framing.
- B. For concrete or masonry substrate where one by (1X), non-structural, wood bucking is employed, use **3/16" diameter ITW** type concrete screw anchors of sufficient length to achieve minimum embedment of 1.25" into concrete or masonry.
- C. For concrete or masonry substrate where wood bucking is NOT employed, use **3/16**" **diameter ITW** type concrete screw anchors of sufficient length to achieve minimum embedment of 1.25" into concrete or masonry.
- D. For steel stud substrate, use **#10-16 Self-Tapping** type metal stud anchors of sufficient length to achieve a minimum of 3 threads of penetration beyond metal structure.

Fin Frame:

- A. For two by (2X) wood frame substrate, use **#10 Wood Screws** type wood frame anchors of sufficient length to achieve minimum embedment of 1.50" into wood framing.
- B. For steel stud substrate, use **#10-16 Self-Tapping** type metal stud anchors of sufficient length to achieve a minimum of 3 threads of penetration beyond metal structure.

Refer to Installation Instructions (**CRF013**) for anchor spacing and more details of the installation requirements.

Design Pressure:	72 x 42	DP = +/- 35 PSF
	59 x 59	DP = +/- 40 PSF

Hermes F. Norero, P.E. Florida No. 73778 Page 4 of 4