

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97TH Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: PORTILLO SERIES BOCA DOORS

MANUFACTURER: LAG DESIGN OF FLORIDA
3850 BYRON DRIVE, #1
RIVIERA BEACH, FL 33404

To all concerned,

The Portillo Series Boca Door, manufactured by Lag Design of Florida, is a wood and glass outswing bi-fold door or pair of doors set in a wood frame. The Boca doors have been tested per Florida Building Code protocols TAS 201, TAS 202, and TAS 203 by Architectural Testing Inc, with results shown in test report B3858.02-450-18.

Technical Documentation:

1. Portillo Series Boca Door Drawings (#001), signed and sealed by Scott Wolters, PE.
2. Test Report B3858.02-450-18 from Architectural Testing, Inc.
3. Portillo Series Boca Door Calculations, signed and sealed by Scott Wolters, PE

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 5th Edition (2014) Florida Building Code generally, and chapters 10, 11,16, 23, and 24 specifically, including the HVHZ provisions.

Limitations:

Overall Dimensions:

Maximum frame size:	148 1/2" x 98" (OXXO)
Maximum design pressure:	+/- 65 psf
Maximum door panel:	36" x 96"
Maximum glass size:	25" x 81"

Glass Type:

7/16" Safety Plus II Laminated Glass:

3/16" Annealed

0.090" Safety-Plus II Polyam Interlayer (NOA# 13-0909.10)*
with PET film at perimeter

3/16" Annealed

* I have evaluated the Safety-Plus II interlayer in the NOA referenced above and find that it complies with the requirements of the 5th Edition (2014) Florida Building Code for use in this product.

Locks:

Active Leaf:	GU "Wolverine" 3-point locking system.
In-Active Leaf:	Deltana Stainless Steel Flush Bolts. (Head and Sill)
Bi-Fold Meeting Stiles:	Centor DF Drop Bolts. (Head and Sill)

Hinges:

Deltana Brass Hinges (4 per Leaf)

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
AUG 27 2015

