

*L. Roberto Lomas P.E.*

233 W. Main St.  
Danville, VA 24541  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 512524A

**Manufacturer:** US Aluminum – Division of R.C. Laurence Co., Inc.  
720 Cel-River Road  
Rock Hill, SC 29730

**Product Line:** Series 800 Aluminum Double Door

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-01837 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: CCLI-12-180 signed by Jeffrey Crump  
Construction Consulting Laboratory Int., Carrollton, TX  
ASTM E330-02 Design pressure  $\pm 20.0$ psf
3. Test report No.: CCLI-12-181 signed by Jeffrey Crump  
Construction Consulting Laboratory Int., Carrollton, TX  
ASTM E330-02 Design pressure  $\pm 35.0$ psf
4. Anchor calculations, report number 512524-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: Refer to installation instructions.
- Maximum panel size: 47 13/16" x 95 3/16"
- Units must be glazed per ASTM E1300-04.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T5.

**Installation:** Units must be installed in accordance with approval document, 08-01837 Revision A.

**Certification of Independence:** Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

