

Product Evaluation Report**Report No.:** FL-21891.3**Date:** April 11, 2017

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	MILLWORK 360 12941 Memorial Hwy Tampa, FL 33635 (813) 854-3100	Impact 360 Series Wood Glazed or Opaque Single Door w/ Transom w/ or w/out Sidelite(s) Inswing / Outswing - "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for MILLWORK 360 based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

R W Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 5th Edition (2014) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection, this product complies with Section 1609.1.2 of the FBC and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E1996 and Section 1609.1.2.2 of the FBC.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-21891.3 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-21891.3 for size and design pressure limitations.

1. **Test Report No.**
TEL 06801716

Test Standard
ASTM E330-02
ASTM E1886-05/E1996-09

Testing Laboratory
Testing Evaluation Lab.

Signed by
V.K. Wright

2. **Miami-Dade NOA**
15-1201.11

Materials Testing
Saflex® PVB Interlayer (Eastman Chemical Co.)

3. **Drawing No.**
No. FL-21891.3

Prepared by
RW Building Consultants, Inc. (CA #9813)

Signed & Sealed by
Lyndon F. Schmidt, P.E.


4. **Calculations**
Product Anchoring

Prepared by
RW Building Consultants, Inc. (CA #9813)

Signed & Sealed by
Lyndon F. Schmidt, P.E.

5. **Quality Assurance**

Certificate of Participation issued by National Accreditation and Management Institute, certifying that MILLWORK 360 is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.
FL PE No. 43409
4/11/2017